

ANALYTICAL REPORT

Job Number: 420-193732-1

SDG Number: Valls Gate

Job Description: Orange-Ulster BOCES

For:

Orange-Ulster BOCES

53 Gibson Road

Goshen, NY 10924

Attention: Jack DeGraw

Meredith Ruthven

Meredith W Ruthven

Customer Service Manager

mruthven@envirotestlaboratories.com

04/19/2021

NYSDOH ELAP does not certify for all parameters. EnviroTest Laboratories does hold certification for all analytes where certification is offered by ELAP unless otherwise specified in the Certification Information section of this report. Pursuant to NELAP, this report may not be reproduced, except in full, without written approval of the laboratory. EnviroTest Laboratories LLC certifies that the analytical results contained herein apply only to the samples tested as received by our laboratory. All questions regarding this report should be directed to the EnviroTest Customer Service Representative. All services performed by EnviroTest Laboratories LLC are subject to our Terms and Conditions available at envirotestlabs/terms.com. As of 12/23/19, EnviroTest Laboratories LLC acquired substantially all of the lab and testing assets of EnviroTest Laboratories Inc, including its name.

EnviroTest Laboratories, LLC. Certifications and Approvals: NYSDOH 10142, NJDEP NY015, CTDOH PH-0554

Envirotest Laboratories

315 Fullerton Avenue, Newburgh, NY 12550

Tel (845) 562-0890 Fax (845) 562-0841 www.envirotestlaboratories.com

METHOD SUMMARY

Client: Orange-Ulster BOCES

Job Number: 420-193732-1

SDG Number: Valls Gate

Description	Lab Location	Method	Preparation Method
Matrix: Water			
ICPMS Metals by 200.8	EnvTest	EPA 200.8 Rev.5.4	
200 Series Drinking Water Prep Determination Step	EnvTest		EPA 200.7/200.8

Lab References:

EnvTest = EnviroTest

Method References:

EPA = US Environmental Protection Agency

METHOD / ANALYST SUMMARY

Client: Orange-Ulster BOCES

Job Number: 420-193732-1

SDG Number: Valls Gate

Method	Analyst	Analyst ID
EPA 200.8 Rev.5.4	Luis, Carlos	CL

SAMPLE SUMMARY

Client: Orange-Ulster BOCES

Job Number: 420-193732-1

SDG Number: Valls Gate

Lab Sample ID	Client Sample ID	Client Matrix	Date/Time Sampled	Date/Time Received
420-193732-1	Kitchen BS	Drinking Water	03/19/2021 0413	03/24/2021 1045
420-193732-2	Kitchen KS #1	Drinking Water	03/19/2021 0415	03/24/2021 1045
420-193732-3	Kitchen KS #2	Drinking Water	03/19/2021 0415	03/24/2021 1045
420-193732-4	Kitchen KS #3	Drinking Water	03/19/2021 0416	03/24/2021 1045
420-193732-5	Kitchen KF	Drinking Water	03/19/2021 0416	03/24/2021 1045
420-193732-6	Kitchen KSP	Drinking Water	03/19/2021 0417	03/24/2021 1045
420-193732-7	RM 163 BS	Drinking Water	03/19/2021 0420	03/24/2021 1045
420-193732-8	RM 1A BS	Drinking Water	03/19/2021 0421	03/24/2021 1045
420-193732-9	RM 167 BS	Drinking Water	03/19/2021 0422	03/24/2021 1045
420-193732-10	164 BS	Drinking Water	03/19/2021 0423	03/24/2021 1045
420-193732-11	RM 1D BS	Drinking Water	03/19/2021 0424	03/24/2021 1045
420-193732-12	RM 157 BS	Drinking Water	03/19/2021 0426	03/24/2021 1045
420-193732-13	O/S 152 BF#1	Drinking Water	03/19/2021 0427	03/24/2021 1045
420-193732-14	O/S 152 BF#2	Drinking Water	03/19/2021 0427	03/24/2021 1045
420-193732-15	O/S 152 Boys BS#1	Drinking Water	03/19/2021 0428	03/24/2021 1045
420-193732-16	O/S 152 Boys BS#2	Drinking Water	03/19/2021 0428	03/24/2021 1045
420-193732-17	O/S 149 Girls BS#1	Drinking Water	03/19/2021 0429	03/24/2021 1045
420-193732-18	O/S 149 Girls BS#2	Drinking Water	03/19/2021 0429	03/24/2021 1045
420-193732-19	Rm 149 CS	Drinking Water	03/19/2021 0430	03/24/2021 1045
420-193732-20	Rm 148 CS	Drinking Water	03/19/2021 0431	03/24/2021 1045
420-193732-21	Rm 147 CS	Drinking Water	03/19/2021 0431	03/24/2021 1045
420-193732-22	Rm 146 CS	Drinking Water	03/19/2021 0432	03/24/2021 1045
420-193732-23	Rm 144 CS	Drinking Water	03/19/2021 0433	03/24/2021 1045
420-193732-24	Rm 145 CS	Drinking Water	03/19/2021 0433	03/24/2021 1045
420-193732-25	Rm 143 KS	Drinking Water	03/19/2021 0434	03/24/2021 1045
420-193732-26	Rm 143 BS	Drinking Water	03/19/2021 0434	03/24/2021 1045
420-193732-27	O/S 143 Faculty BS	Drinking Water	03/19/2021 0435	03/24/2021 1045
420-193732-28	O/S Library Boys BS#1	Drinking Water	03/19/2021 0436	03/24/2021 1045
420-193732-29	O/S Library Boys BS#2	Drinking Water	03/19/2021 0436	03/24/2021 1045
420-193732-30	O/S Library BF	Drinking Water	03/19/2021 0437	03/24/2021 1045
420-193732-31	O/S Library Girls BS#1	Drinking Water	03/19/2021 0438	03/24/2021 1045
420-193732-32	O/S Library Girls BS#2	Drinking Water	03/19/2021 0438	03/24/2021 1045
420-193732-33	Library BS	Drinking Water	03/19/2021 0439	03/24/2021 1045
420-193732-34	Library KS	Drinking Water	03/19/2021 0440	03/24/2021 1045
420-193732-35	Rm 136 CS #1	Drinking Water	03/19/2021 0443	03/24/2021 1045
420-193732-36	Rm 136 CS #2	Drinking Water	03/19/2021 0444	03/24/2021 1045
420-193732-37	Rm 136 BS	Drinking Water	03/19/2021 0444	03/24/2021 1045
420-193732-38	Rm 135 CS	Drinking Water	03/19/2021 0445	03/24/2021 1045
420-193732-39	Rm 133 CS	Drinking Water	03/19/2021 0445	03/24/2021 1045
420-193732-40	Rm 130 CS	Drinking Water	03/19/2021 0446	03/24/2021 1045
420-193732-41	O/S 130 BF	Drinking Water	03/19/2021 0447	03/24/2021 1045
420-193732-42	Rm 131 CS	Drinking Water	03/19/2021 0448	03/24/2021 1045
420-193732-43	Rm 129 CS	Drinking Water	03/19/2021 0448	03/24/2021 1045
420-193732-44	Rm 127 CS	Drinking Water	03/19/2021 0449	03/24/2021 1045
420-193732-45	Rm 125 CS	Drinking Water	03/19/2021 0450	03/24/2021 1045
420-193732-46	O/S 125 BF#1	Drinking Water	03/19/2021 0450	03/24/2021 1045

SAMPLE SUMMARY

Client: Orange-Ulster BOCES

Job Number: 420-193732-1

SDG Number: Valls Gate

Lab Sample ID	Client Sample ID	Client Matrix	Date/Time Sampled	Date/Time Received
420-193732-47	O/S 125 BF#2	Drinking Water	03/19/2021 0451	03/24/2021 1045
420-193732-48	O/S 125 Boys BS#2	Drinking Water	03/19/2021 0452	03/24/2021 1045
420-193732-49	O/S 123 Girls BS#1	Drinking Water	03/19/2021 0453	03/24/2021 1045
420-193732-50	O/S 123 Girls BS#2	Drinking Water	03/19/2021 0453	03/24/2021 1045
420-193732-51	123 CS	Drinking Water	03/19/2021 0454	03/24/2021 1045
420-193732-52	Rm 121 CS	Drinking Water	03/19/2021 0455	03/24/2021 1045
420-193732-53	Rm 118 CS	Drinking Water	03/19/2021 0456	03/24/2021 1045
420-193732-54	Rm 119 CS	Drinking Water	03/19/2021 0453	03/24/2021 1045
420-193732-55	Rm 116 CS	Drinking Water	03/19/2021 0457	03/24/2021 1045
420-193732-56	Rm 117 CS	Drinking Water	03/19/2021 0458	03/24/2021 1045
420-193732-57	Rm 115 CS	Drinking Water	03/19/2021 0458	03/24/2021 1045
420-193732-58	Rm 111 CS	Drinking Water	03/19/2021 0459	03/24/2021 1045
420-193732-59	Rm 113 CS	Drinking Water	03/19/2021 0500	03/24/2021 1045
420-193732-60	Rm 109 CS	Drinking Water	03/19/2021 0501	03/24/2021 1045
420-193732-61	O/S 109 BF#1	Drinking Water	03/19/2021 0501	03/24/2021 1045
420-193732-62	O/S 109 BF#2	Drinking Water	03/19/2021 0502	03/24/2021 1045
420-193732-63	O/S 109 Boys BS#1	Drinking Water	03/19/2021 0502	03/24/2021 1045
420-193732-64	O/S 109 Boys BS#2	Drinking Water	03/19/2021 0503	03/24/2021 1045
420-193732-65	O/S 109 Girls BS#1	Drinking Water	03/19/2021 0503	03/24/2021 1045
420-193732-66	O/S 109 Girls BS#2	Drinking Water	03/19/2021 0504	03/24/2021 1045
420-193732-67	Rm 107 CS	Drinking Water	03/19/2021 0504	03/24/2021 1045
420-193732-68	Rm 108 CS	Drinking Water	03/19/2021 0505	03/24/2021 1045
420-193732-69	Rm 105 CS	Drinking Water	03/19/2021 0505	03/24/2021 1045
420-193732-70	Rm 106 CS	Drinking Water	03/19/2021 0506	03/24/2021 1045
420-193732-71	Rm 104 CS	Drinking Water	03/19/2021 0506	03/24/2021 1045
420-193732-72	Rm 102 CS	Drinking Water	03/19/2021 0507	03/24/2021 1045
420-193732-73	Girls Locker Room BS	Drinking Water	03/19/2021 0508	03/24/2021 1045
420-193732-74	Boys Locker Room BS	Drinking Water	03/19/2021 0509	03/24/2021 1045
420-193732-75	Office KS	Drinking Water	03/19/2021 0511	03/24/2021 1045
420-193732-76	O/S Safe BS	Drinking Water	03/19/2021 0511	03/24/2021 1045
420-193732-77	AP Bath BS	Drinking Water	03/19/2021 0512	03/24/2021 1045
420-193732-78	Work Room KS	Drinking Water	03/19/2021 0513	03/24/2021 1045
420-193732-79	Principal BS	Drinking Water	03/19/2021 0513	03/24/2021 1045

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193732-1
Sdg Number: Valls Gate

Client Sample ID: Kitchen BS
Lab Sample ID: 420-193732-1

Date Sampled: 03/19/2021 0413
Date Received: 03/24/2021 1045
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/13/2021	2149	
Prep Method: 200.7/200.8			Date Prepared: 04/11/2021	1200	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193732-1
Sdg Number: Valls Gate

Client Sample ID: Kitchen KS #1
Lab Sample ID: 420-193732-2

Date Sampled: 03/19/2021 0415
Date Received: 03/24/2021 1045
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/13/2021	2151	
Prep Method: 200.7/200.8			Date Prepared: 04/11/2021	1200	
Pb	1.19	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193732-1
Sdg Number: Valls Gate

Client Sample ID: Kitchen KS #2
Lab Sample ID: 420-193732-3

Date Sampled: 03/19/2021 0415
Date Received: 03/24/2021 1045
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/13/2021	2153	
Prep Method: 200.7/200.8			Date Prepared: 04/11/2021	1200	
Pb	1.52	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193732-1
Sdg Number: Valls Gate

Client Sample ID: Kitchen KS #3
Lab Sample ID: 420-193732-4

Date Sampled: 03/19/2021 0416
Date Received: 03/24/2021 1045
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/13/2021	2155	
Prep Method: 200.7/200.8			Date Prepared: 04/11/2021	1200	
Pb	2.47	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193732-1
Sdg Number: Valls Gate

Client Sample ID: Kitchen KF
Lab Sample ID: 420-193732-5

Date Sampled: 03/19/2021 0416
Date Received: 03/24/2021 1045
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/13/2021 2202	
Prep Method: 200.7/200.8			Date Prepared:	04/11/2021 1200	
Pb	2.34	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193732-1
Sdg Number: Valls Gate

Client Sample ID: Kitchen KSP
Lab Sample ID: 420-193732-6

Date Sampled: 03/19/2021 0417
Date Received: 03/24/2021 1045
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/13/2021 2204	
Prep Method: 200.7/200.8			Date Prepared:	04/11/2021 1200	
Pb	5.48	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193732-1
Sdg Number: Valls Gate

Client Sample ID: RM 163 BS
Lab Sample ID: 420-193732-7

Date Sampled: 03/19/2021 0420
Date Received: 03/24/2021 1045
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/13/2021 2208	
Prep Method: 200.7/200.8			Date Prepared:	04/11/2021 1200	
Pb	4.40	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193732-1
Sdg Number: Valls Gate

Client Sample ID: RM 1A BS
Lab Sample ID: 420-193732-8

Date Sampled: 03/19/2021 0421
Date Received: 03/24/2021 1045
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/13/2021 2211	
Prep Method: 200.7/200.8			Date Prepared:	04/11/2021 1200	
Pb	4.01	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193732-1
Sdg Number: Valls Gate

Client Sample ID: RM 167 BS
Lab Sample ID: 420-193732-9

Date Sampled: 03/19/2021 0422
Date Received: 03/24/2021 1045
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/13/2021	2213	
Prep Method: 200.7/200.8			Date Prepared: 04/11/2021	1200	
Pb	7.14	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193732-1
Sdg Number: Valls Gate

Client Sample ID: 164 BS
Lab Sample ID: 420-193732-10

Date Sampled: 03/19/2021 0423
Date Received: 03/24/2021 1045
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/13/2021	2215	
Prep Method: 200.7/200.8			Date Prepared: 04/11/2021	1200	
Pb	4.25	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193732-1
Sdg Number: Valls Gate

Client Sample ID: RM 1D BS
Lab Sample ID: 420-193732-11

Date Sampled: 03/19/2021 0424
Date Received: 03/24/2021 1045
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/13/2021	2217	
Prep Method: 200.7/200.8			Date Prepared: 04/11/2021	1200	
Pb	1.96	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193732-1
Sdg Number: Valls Gate

Client Sample ID: RM 157 BS
Lab Sample ID: 420-193732-12

Date Sampled: 03/19/2021 0426
Date Received: 03/24/2021 1045
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/13/2021	2219	
Prep Method: 200.7/200.8			Date Prepared: 04/11/2021	1200	
Pb	2.39	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193732-1
Sdg Number: Valls Gate

Client Sample ID: O/S 152 BF#1
Lab Sample ID: 420-193732-13

Date Sampled: 03/19/2021 0427
Date Received: 03/24/2021 1045
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/13/2021	2222	
Prep Method: 200.7/200.8			Date Prepared: 04/11/2021	1200	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193732-1
Sdg Number: Valls Gate

Client Sample ID: O/S 152 BF#2
Lab Sample ID: 420-193732-14

Date Sampled: 03/19/2021 0427
Date Received: 03/24/2021 1045
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/13/2021	2228	
Prep Method: 200.7/200.8			Date Prepared: 04/11/2021	1200	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193732-1
Sdg Number: Valls Gate

Client Sample ID: O/S 152 Boys BS#1
Lab Sample ID: 420-193732-15

Date Sampled: 03/19/2021 0428
Date Received: 03/24/2021 1045
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/13/2021 2230		
Prep Method: 200.7/200.8			Date Prepared: 04/11/2021 1200		
Pb	1.94	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193732-1
Sdg Number: Valls Gate

Client Sample ID: O/S 152 Boys BS#2
Lab Sample ID: 420-193732-16

Date Sampled: 03/19/2021 0428
Date Received: 03/24/2021 1045
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/13/2021 2232	
Prep Method: 200.7/200.8			Date Prepared:	04/11/2021 1200	
Pb	2.10	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193732-1
Sdg Number: Valls Gate

Client Sample ID: O/S 149 Girls BS#1
Lab Sample ID: 420-193732-17

Date Sampled: 03/19/2021 0429
Date Received: 03/24/2021 1045
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/13/2021	2241	
Prep Method: 200.7/200.8			Date Prepared: 04/11/2021	1200	
Pb	1.23	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193732-1
Sdg Number: Valls Gate

Client Sample ID: O/S 149 Girls BS#2
Lab Sample ID: 420-193732-18

Date Sampled: 03/19/2021 0429
Date Received: 03/24/2021 1045
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/13/2021	2243	
Prep Method: 200.7/200.8			Date Prepared: 04/11/2021	1200	
Pb	2.54	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193732-1
Sdg Number: Valls Gate

Client Sample ID: Rm 149 CS
Lab Sample ID: 420-193732-19

Date Sampled: 03/19/2021 0430
Date Received: 03/24/2021 1045
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/13/2021	2246	
Prep Method: 200.7/200.8			Date Prepared: 04/11/2021	1200	
Pb	1.16	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193732-1
Sdg Number: Valls Gate

Client Sample ID: Rm 148 CS
Lab Sample ID: 420-193732-20

Date Sampled: 03/19/2021 0431
Date Received: 03/24/2021 1045
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/13/2021 2248	
Prep Method: 200.7/200.8			Date Prepared:	04/11/2021 1200	
Pb	5.43	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193732-1
Sdg Number: Valls Gate

Client Sample ID: Rm 147 CS
Lab Sample ID: 420-193732-21

Date Sampled: 03/19/2021 0431
Date Received: 03/24/2021 1045
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/14/2021 0106	
Prep Method: 200.7/200.8			Date Prepared:	04/11/2021 1200	
Pb	1.22	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193732-1
Sdg Number: Valls Gate

Client Sample ID: Rm 146 CS
Lab Sample ID: 420-193732-22

Date Sampled: 03/19/2021 0432
Date Received: 03/24/2021 1045
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/14/2021	0108	
Prep Method: 200.7/200.8			Date Prepared: 04/11/2021	1200	
Pb	7.31	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193732-1
Sdg Number: Valls Gate

Client Sample ID: Rm 144 CS
Lab Sample ID: 420-193732-23

Date Sampled: 03/19/2021 0433
Date Received: 03/24/2021 1045
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/14/2021	0110	
Prep Method: 200.7/200.8			Date Prepared: 04/11/2021	1200	
Pb	5.80	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193732-1
Sdg Number: Valls Gate

Client Sample ID: Rm 145 CS
Lab Sample ID: 420-193732-24

Date Sampled: 03/19/2021 0433
Date Received: 03/24/2021 1045
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/14/2021	0112	
Prep Method: 200.7/200.8			Date Prepared: 04/11/2021	1200	
Pb	6.26	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193732-1
Sdg Number: Valls Gate

Client Sample ID: Rm 143 KS
Lab Sample ID: 420-193732-25

Date Sampled: 03/19/2021 0434
Date Received: 03/24/2021 1045
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/14/2021 0114	
Prep Method: 200.7/200.8			Date Prepared:	04/11/2021 1200	
Pb	2.13	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193732-1
Sdg Number: Valls Gate

Client Sample ID: Rm 143 BS
Lab Sample ID: 420-193732-26

Date Sampled: 03/19/2021 0434
Date Received: 03/24/2021 1045
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/14/2021	0116	
Prep Method: 200.7/200.8			Date Prepared: 04/11/2021	1200	
Pb	2.18	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193732-1
Sdg Number: Valls Gate

Client Sample ID: O/S 143 Faculty BS
Lab Sample ID: 420-193732-27

Date Sampled: 03/19/2021 0435
Date Received: 03/24/2021 1045
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/14/2021 0121	
Prep Method: 200.7/200.8			Date Prepared:	04/11/2021 1200	
Pb	2.88	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193732-1
Sdg Number: Valls Gate

Client Sample ID: O/S Library Boys BS#1
Lab Sample ID: 420-193732-28

Date Sampled: 03/19/2021 0436
Date Received: 03/24/2021 1045
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/14/2021	0123	
Prep Method: 200.7/200.8			Date Prepared: 04/11/2021	1200	
Pb	1.75	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193732-1
Sdg Number: Valls Gate

Client Sample ID: O/S Library Boys BS#2
Lab Sample ID: 420-193732-29

Date Sampled: 03/19/2021 0436
Date Received: 03/24/2021 1045
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/14/2021 0125	
Prep Method: 200.7/200.8			Date Prepared:	04/11/2021 1200	
Pb	2.65	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193732-1
Sdg Number: Valls Gate

Client Sample ID: O/S Library BF
Lab Sample ID: 420-193732-30

Date Sampled: 03/19/2021 0437
Date Received: 03/24/2021 1045
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/14/2021 0132		
Prep Method: 200.7/200.8			Date Prepared: 04/11/2021 1200		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193732-1
Sdg Number: Valls Gate

Client Sample ID: O/S Library Girls BS#1
Lab Sample ID: 420-193732-31

Date Sampled: 03/19/2021 0438
Date Received: 03/24/2021 1045
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/14/2021 0134		
Prep Method: 200.7/200.8			Date Prepared: 04/11/2021 1200		
Pb	2.49	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193732-1
Sdg Number: Valls Gate

Client Sample ID: O/S Library Girls BS#2
Lab Sample ID: 420-193732-32

Date Sampled: 03/19/2021 0438
Date Received: 03/24/2021 1045
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/14/2021 0136	
Prep Method: 200.7/200.8			Date Prepared:	04/11/2021 1200	
Pb	1.91	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193732-1
Sdg Number: Valls Gate

Client Sample ID: Library BS
Lab Sample ID: 420-193732-33

Date Sampled: 03/19/2021 0439
Date Received: 03/24/2021 1045
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/14/2021 0138	
Prep Method: 200.7/200.8			Date Prepared:	04/11/2021 1200	
Pb	7.85	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193732-1
Sdg Number: Valls Gate

Client Sample ID: Library KS
Lab Sample ID: 420-193732-34

Date Sampled: 03/19/2021 0440
Date Received: 03/24/2021 1045
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/14/2021	0141	
Prep Method: 200.7/200.8			Date Prepared: 04/11/2021	1200	
Pb	1.26	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193732-1
Sdg Number: Valls Gate

Client Sample ID: Rm 136 CS #1
Lab Sample ID: 420-193732-35

Date Sampled: 03/19/2021 0443
Date Received: 03/24/2021 1045
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/14/2021	0143	
Prep Method: 200.7/200.8			Date Prepared: 04/11/2021	1200	
Pb	1.93	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193732-1
Sdg Number: Valls Gate

Client Sample ID: Rm 136 CS #2
Lab Sample ID: 420-193732-36

Date Sampled: 03/19/2021 0444
Date Received: 03/24/2021 1045
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/14/2021 0145	
Prep Method: 200.7/200.8			Date Prepared:	04/11/2021 1200	
Pb	4.50	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193732-1
Sdg Number: Valls Gate

Client Sample ID: Rm 136 BS
Lab Sample ID: 420-193732-37

Date Sampled: 03/19/2021 0444
Date Received: 03/24/2021 1045
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/14/2021 0158		
Prep Method: 200.7/200.8			Date Prepared: 04/11/2021 1200		
Pb	1.52	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193732-1
Sdg Number: Valls Gate

Client Sample ID: Rm 135 CS
Lab Sample ID: 420-193732-38

Date Sampled: 03/19/2021 0445
Date Received: 03/24/2021 1045
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/14/2021 0200	
Prep Method: 200.7/200.8			Date Prepared:	04/11/2021 1200	
Pb	6.60	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193732-1
Sdg Number: Valls Gate

Client Sample ID: Rm 133 CS
Lab Sample ID: 420-193732-39

Date Sampled: 03/19/2021 0445
Date Received: 03/24/2021 1045
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/14/2021	0202	
Prep Method: 200.7/200.8			Date Prepared: 04/11/2021	1200	
Pb	3.52	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193732-1
Sdg Number: Valls Gate

Client Sample ID: Rm 130 CS
Lab Sample ID: 420-193732-40

Date Sampled: 03/19/2021 0446
Date Received: 03/24/2021 1045
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/14/2021 0205		
Prep Method: 200.7/200.8			Date Prepared: 04/11/2021 1200		
Pb	2.79	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193732-1
Sdg Number: Valls Gate

Client Sample ID: O/S 130 BF
Lab Sample ID: 420-193732-41

Date Sampled: 03/19/2021 0447
Date Received: 03/24/2021 1045
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/14/2021 0207		
Prep Method: 200.7/200.8			Date Prepared: 04/11/2021 1200		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193732-1
Sdg Number: Valls Gate

Client Sample ID: Rm 131 CS
Lab Sample ID: 420-193732-42

Date Sampled: 03/19/2021 0448
Date Received: 03/24/2021 1045
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/14/2021 0209		
Prep Method: 200.7/200.8			Date Prepared: 04/11/2021 1200		
Pb	1.89	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193732-1
Sdg Number: Valls Gate

Client Sample ID: Rm 129 CS
Lab Sample ID: 420-193732-43

Date Sampled: 03/19/2021 0448
Date Received: 03/24/2021 1045
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/14/2021	0211	
Prep Method: 200.7/200.8			Date Prepared: 04/11/2021	1200	
Pb	2.18	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193732-1
Sdg Number: Valls Gate

Client Sample ID: Rm 127 CS
Lab Sample ID: 420-193732-44

Date Sampled: 03/19/2021 0449
Date Received: 03/24/2021 1045
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/14/2021	0213	
Prep Method: 200.7/200.8			Date Prepared: 04/11/2021	1200	
Pb	1.29	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193732-1
Sdg Number: Valls Gate

Client Sample ID: Rm 125 CS
Lab Sample ID: 420-193732-45

Date Sampled: 03/19/2021 0450
Date Received: 03/24/2021 1045
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/14/2021	0215	
Prep Method: 200.7/200.8			Date Prepared: 04/11/2021	1200	
Pb	3.07	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193732-1
Sdg Number: Valls Gate

Client Sample ID: O/S 125 BF#1
Lab Sample ID: 420-193732-46

Date Sampled: 03/19/2021 0450
Date Received: 03/24/2021 1045
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/14/2021 0218		
Prep Method: 200.7/200.8			Date Prepared: 04/11/2021 1200		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193732-1
Sdg Number: Valls Gate

Client Sample ID: O/S 125 BF#2
Lab Sample ID: 420-193732-47

Date Sampled: 03/19/2021 0451
Date Received: 03/24/2021 1045
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/14/2021 0226		
Prep Method: 200.7/200.8			Date Prepared: 04/11/2021 1200		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193732-1
Sdg Number: Valls Gate

Client Sample ID: O/S 125 Boys BS#2
Lab Sample ID: 420-193732-48

Date Sampled: 03/19/2021 0452
Date Received: 03/24/2021 1045
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/14/2021 0228		
Prep Method: 200.7/200.8			Date Prepared: 04/11/2021 1200		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193732-1
Sdg Number: Valls Gate

Client Sample ID: O/S 123 Girls BS#1
Lab Sample ID: 420-193732-49

Date Sampled: 03/19/2021 0453
Date Received: 03/24/2021 1045
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/14/2021 0308		
Prep Method: 200.7/200.8			Date Prepared: 04/12/2021 0930		
Pb	6.75	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193732-1
Sdg Number: Valls Gate

Client Sample ID: O/S 123 Girls BS#2
Lab Sample ID: 420-193732-50

Date Sampled: 03/19/2021 0453
Date Received: 03/24/2021 1045
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/14/2021 0310		
Prep Method: 200.7/200.8			Date Prepared: 04/12/2021 0930		
Pb	1.41	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193732-1
Sdg Number: Valls Gate

Client Sample ID: 123 CS
Lab Sample ID: 420-193732-51

Date Sampled: 03/19/2021 0454
Date Received: 03/24/2021 1045
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/14/2021	2324	
Prep Method: 200.7/200.8			Date Prepared: 04/12/2021	0930	
Pb	2.21	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193732-1
Sdg Number: Valls Gate

Client Sample ID: Rm 121 CS
Lab Sample ID: 420-193732-52

Date Sampled: 03/19/2021 0455
Date Received: 03/24/2021 1045
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/14/2021 2326		
Prep Method: 200.7/200.8			Date Prepared: 04/12/2021 0930		
Pb	1.99	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193732-1
Sdg Number: Valls Gate

Client Sample ID: Rm 118 CS
Lab Sample ID: 420-193732-53

Date Sampled: 03/19/2021 0456
Date Received: 03/24/2021 1045
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/14/2021	2329	
Prep Method: 200.7/200.8			Date Prepared: 04/12/2021	0930	
Pb	3.41	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193732-1
Sdg Number: Valls Gate

Client Sample ID: Rm 119 CS
Lab Sample ID: 420-193732-54

Date Sampled: 03/19/2021 0453
Date Received: 03/24/2021 1045
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/14/2021 2331		
Prep Method: 200.7/200.8			Date Prepared: 04/12/2021 0930		
Pb	3.77	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193732-1
Sdg Number: Valls Gate

Client Sample ID: Rm 116 CS
Lab Sample ID: 420-193732-55

Date Sampled: 03/19/2021 0457
Date Received: 03/24/2021 1045
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/14/2021	2333	
Prep Method: 200.7/200.8			Date Prepared: 04/12/2021	0930	
Pb	5.16	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193732-1
Sdg Number: Valls Gate

Client Sample ID: Rm 117 CS
Lab Sample ID: 420-193732-56

Date Sampled: 03/19/2021 0458
Date Received: 03/24/2021 1045
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/14/2021 2335		
Prep Method: 200.7/200.8			Date Prepared: 04/12/2021 0930		
Pb	1.87	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193732-1
Sdg Number: Valls Gate

Client Sample ID: Rm 115 CS
Lab Sample ID: 420-193732-57

Date Sampled: 03/19/2021 0458
Date Received: 03/24/2021 1045
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/14/2021	2337	
Prep Method: 200.7/200.8			Date Prepared: 04/12/2021	0930	
Pb	1.96	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193732-1
Sdg Number: Valls Gate

Client Sample ID: Rm 111 CS
Lab Sample ID: 420-193732-58

Date Sampled: 03/19/2021 0459
Date Received: 03/24/2021 1045
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/14/2021	2350	
Prep Method: 200.7/200.8			Date Prepared: 04/12/2021	0930	
Pb	1.52	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193732-1
Sdg Number: Valls Gate

Client Sample ID: Rm 113 CS
Lab Sample ID: 420-193732-59

Date Sampled: 03/19/2021 0500
Date Received: 03/24/2021 1045
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/14/2021 2353		
Prep Method: 200.7/200.8			Date Prepared: 04/12/2021 0930		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193732-1
Sdg Number: Valls Gate

Client Sample ID: Rm 109 CS
Lab Sample ID: 420-193732-60

Date Sampled: 03/19/2021 0501
Date Received: 03/24/2021 1045
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/14/2021 2355		
Prep Method: 200.7/200.8			Date Prepared: 04/12/2021 0930		
Pb	1.51	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193732-1
Sdg Number: Valls Gate

Client Sample ID: O/S 109 BF#1
Lab Sample ID: 420-193732-61

Date Sampled: 03/19/2021 0501
Date Received: 03/24/2021 1045
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/14/2021 2357		
Prep Method: 200.7/200.8			Date Prepared: 04/12/2021 0930		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193732-1
Sdg Number: Valls Gate

Client Sample ID: O/S 109 BF#2
Lab Sample ID: 420-193732-62

Date Sampled: 03/19/2021 0502
Date Received: 03/24/2021 1045
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/14/2021 2359		
Prep Method: 200.7/200.8			Date Prepared: 04/12/2021 0930		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193732-1
Sdg Number: Valls Gate

Client Sample ID: O/S 109 Boys BS#1
Lab Sample ID: 420-193732-63

Date Sampled: 03/19/2021 0502
Date Received: 03/24/2021 1045
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/15/2021 0001	
Prep Method: 200.7/200.8			Date Prepared:	04/12/2021 0930	
Pb	1.54	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193732-1
Sdg Number: Valls Gate

Client Sample ID: O/S 109 Boys BS#2
Lab Sample ID: 420-193732-64

Date Sampled: 03/19/2021 0503
Date Received: 03/24/2021 1045
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/15/2021 0004	
Prep Method: 200.7/200.8			Date Prepared:	04/12/2021 0930	
Pb	2.76	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193732-1
Sdg Number: Valls Gate

Client Sample ID: O/S 109 Girls BS#1
Lab Sample ID: 420-193732-65

Date Sampled: 03/19/2021 0503
Date Received: 03/24/2021 1045
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/15/2021 0006	
Prep Method: 200.7/200.8			Date Prepared:	04/12/2021 0930	
Pb	2.64	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193732-1
Sdg Number: Valls Gate

Client Sample ID: O/S 109 Girls BS#2
Lab Sample ID: 420-193732-66

Date Sampled: 03/19/2021 0504
Date Received: 03/24/2021 1045
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/15/2021 0008	
Prep Method: 200.7/200.8			Date Prepared:	04/12/2021 0930	
Pb	1.15	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193732-1
Sdg Number: Valls Gate

Client Sample ID: Rm 107 CS
Lab Sample ID: 420-193732-67

Date Sampled: 03/19/2021 0504
Date Received: 03/24/2021 1045
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/15/2021 0014		
Prep Method: 200.7/200.8			Date Prepared: 04/12/2021 0930		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193732-1
Sdg Number: Valls Gate

Client Sample ID: Rm 108 CS
Lab Sample ID: 420-193732-68

Date Sampled: 03/19/2021 0505
Date Received: 03/24/2021 1045
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/15/2021 0019		
Prep Method: 200.7/200.8			Date Prepared: 04/12/2021 0930		
Pb	2.84	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193732-1
Sdg Number: Valls Gate

Client Sample ID: Rm 105 CS
Lab Sample ID: 420-193732-69

Date Sampled: 03/19/2021 0505
Date Received: 03/24/2021 1045
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/15/2021 0021	
Prep Method: 200.7/200.8			Date Prepared:	04/12/2021 0930	
Pb	2.11	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193732-1
Sdg Number: Valls Gate

Client Sample ID: Rm 106 CS
Lab Sample ID: 420-193732-70

Date Sampled: 03/19/2021 0506
Date Received: 03/24/2021 1045
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/15/2021 0023		
Prep Method: 200.7/200.8			Date Prepared: 04/12/2021 0930		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193732-1
Sdg Number: Valls Gate

Client Sample ID: Rm 104 CS
Lab Sample ID: 420-193732-71

Date Sampled: 03/19/2021 0506
Date Received: 03/24/2021 1045
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/15/2021 0025		
Prep Method: 200.7/200.8			Date Prepared: 04/12/2021 0930		
Pb	1.53	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193732-1
Sdg Number: Valls Gate

Client Sample ID: Rm 102 CS
Lab Sample ID: 420-193732-72

Date Sampled: 03/19/2021 0507
Date Received: 03/24/2021 1045
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/15/2021 0028	
Prep Method: 200.7/200.8			Date Prepared:	04/12/2021 0930	
Pb	3.00	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193732-1
Sdg Number: Valls Gate

Client Sample ID: Girls Locker Room BS
Lab Sample ID: 420-193732-73

Date Sampled: 03/19/2021 0508
Date Received: 03/24/2021 1045
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/15/2021 0030	
Prep Method: 200.7/200.8			Date Prepared:	04/12/2021 0930	
Pb	7.96	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193732-1
Sdg Number: Valls Gate

Client Sample ID: Boys Locker Room BS
Lab Sample ID: 420-193732-74

Date Sampled: 03/19/2021 0509
Date Received: 03/24/2021 1045
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/15/2021 0032		
Prep Method: 200.7/200.8			Date Prepared: 04/12/2021 0930		
Pb	35.6 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193732-1
Sdg Number: Valls Gate

Client Sample ID: Office KS
Lab Sample ID: 420-193732-75

Date Sampled: 03/19/2021 0511
Date Received: 03/24/2021 1045
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/15/2021 0034	
Prep Method: 200.7/200.8			Date Prepared:	04/12/2021 0930	
Pb	17.3 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193732-1
Sdg Number: Valls Gate

Client Sample ID: O/S Safe BS
Lab Sample ID: 420-193732-76

Date Sampled: 03/19/2021 0511
Date Received: 03/24/2021 1045
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/15/2021 0041		
Prep Method: 200.7/200.8			Date Prepared: 04/12/2021 0930		
Pb	3.03	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193732-1
Sdg Number: Valls Gate

Client Sample ID: AP Bath BS
Lab Sample ID: 420-193732-77

Date Sampled: 03/19/2021 0512
Date Received: 03/24/2021 1045
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/15/2021 0043		
Prep Method: 200.7/200.8			Date Prepared: 04/12/2021 0930		
Pb	1.99	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193732-1
Sdg Number: Valls Gate

Client Sample ID: Work Room KS
Lab Sample ID: 420-193732-78

Date Sampled: 03/19/2021 0513
Date Received: 03/24/2021 1045
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/15/2021 0052		
Prep Method: 200.7/200.8			Date Prepared: 04/12/2021 0930		
Pb	8.58	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193732-1
Sdg Number: Valls Gate

Client Sample ID: Principal BS
Lab Sample ID: 420-193732-79

Date Sampled: 03/19/2021 0513
Date Received: 03/24/2021 1045
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/15/2021 0054	
Prep Method: 200.7/200.8			Date Prepared:	04/12/2021 0930	
Pb	3.10	ug/L	1.00	1.00	1.0

DATA REPORTING QUALIFIERS

Client: Orange-Ulster BOCES

Job Number:
Sdg Number: Valls Gate

Lab Section	Qualifier	Description
Metals	g	Result fails applicable NYS drinking water standards
	U	The analyte was analyzed for but not detected at or above the lowest stated limit.

Certification Information

Client: Orange-Ulster BOCES

Job Number:

Sdg Number: Valls Gate

The following analytes are Not Part of the ELAP scope of accreditation:

Sulfur, Tungsten, Bicarbonate Alkalinity, 7 Day BOD 5210C, 28 Day BOD, Soluble BOD, Carbon Dioxide Carbonate Alkalinity, CBOD Soluble, Chlorine, Cyanide (WAD), Ferrous Iron, Ferric Iron, Total Nitrogen, Total Organic Nitrogen, Dissolved Oxygen, pH, Solids (Fixed), Solids (Percent), Solids (Percent Moisture), Solids (Percent Volatile), Solids (Volatile Suspended), Temperature, TKN (Soluble), COD (Soluble), Total Inorganic Carbon, 2-Aminopyridine, 3-Picoline, 1-Methyl-2-pyrrilidinone, Aziridine, Dimethyl sulfoxide, 1-Chlorohexane, 1,2,4,5-Tetramethylbenzene, 4-Ethyl toluene, p-Diethylbenzene, Iron Bacteria, Salmonella, Sulfur Reducing Bacteria, & UOD (Ultimate Oxygen Demand).

The following analytes are Not Part of ELAP Potable Water scope of accreditation:

Ammonia (SM 4500NH3G), Biochemical Oxygen Demand (SM 5210B), Chemical Oxygen Demand (EPA 410.4), Dissolved Oxygen (SM 4500 O C), TKN (351.2), Phosphorus (365.3), Nitrate-Nitrite (353.2), Setttable Solids (SM 2540F), Total Suspended Solids (SM 2540 C), m-Xylene & p-Xylene (502.2, 524), o-Xylene (502.2, 524), Sulfide (SM4500SD), Acenaphthene (525.2), Acenaphthylene (525.2), Fluoranthene (525.2), Fluorene (525.2), Phenanthrene (525.2), Anthracene (525.2), Pyrene (525.2), Benzo[a]anthracene (525.2), Benzo[b]fluoranthene (525.2), Benzo[g,h,i]perylene (525.2), Benzo[k]fluoranthene (525.2), Indeno[1,2,3-cd]pyrene (525.2), & Dibenz(a,h)anthracene (525.2). Pyridine

The following analytes are Not Part of ELAP Solid and Hazardous Waste scope of accreditation:

Ammonia (SM 4500NH3G), TKN (351.2), Phosphorus (365.3), 1,2-Dichloro-1,1,2-trifluoroethane (8260), & Chlorodifluoromethane (8260).

The following analytes are Not Part of ELAP Non Potable Water scope of accreditation:

Dissolved Organic Carbon (5310C), Mecoprop (8151A), MCPA (8151A).

Definitions and Glossary

Client: Orange-Ulster BOCES

Job Number:

Sdg Number: Valls Gate

Abbreviation	These commonly used abbreviations may or may not be present in this report.
%R	Percent Recovery
DL, RA, RE	Indicates a Dilution, Reanalysis or Reextraction.
EPA	United States Environmental Protection Agency
MDL	Method Detection Limit - an estimate of the minimum amount of a substance that an analytical process can reliably detect. A MDL is analyte- and matrix-specific and may be laboratory-dependent.
ND	Not detected at the reporting limit (or MDL if shown).
QC	Quality Control
RL	Reporting Limit - the minimum levels, concentrations, or quantities of a target variable (e.g., target analyte) that can be reported with a specified degree of confidence.
RPD	Relative Percent Difference - a measure of the relative difference between two points.

EnviroTest Laboratories, LLC

315 Fullerton Avenue
Newburgh, NY 12550
Phone (845) 562-0890 Fax (845) 562-0841

Chain of Custody Record



Client Information		Sampler: J. Russo	Lab PM:	Deliverable Type: Level I, Level II, NYS ASP Cat B EDD (Specify):	JOB #: 193732 106 6
Client Contact: Kevin Flynn		Phone: 845-781-4887	E-Mail: joseph.russo@ouboces.org Halina.redner@ouboces.org Maureen.doherty@ouboces.org		

Company: Orange-Ulster BOCES		Analysis Requested			Page: Page 1 of 1
Address: 53 Gibson Road		Due Date Requested: Standard Turn-Around	 420-193732-B-1 Kitchen BS Date Sampled: 3/19/2021 420-1651316		
City: Goshen		TAT Requested (days):			
State, Zip: NY, 10924		PO #:	Preservation Codes: A - HCL B - NaOH C - Zn Acetate D - Nitric Acid E - H2SO4 F - MeOH G - NH4CL H - Ascorbic Acid I - Ice J - DI Water K - Sodium Thiosulfate L - EDA - Sodium Sulfite N - None O - MCAA P - Other (specify)		
Phone: 845-781-4887		PWS #:			
Email: joseph.russo@ouboces.org Halina.redner@ouboces.org Maureen.doherty@ouboces.org		Project #:	Other: D-Nitric Acid Upon Receipt Preservation verified: Y / N		
Project Name: Newburgh ECSD		Additional Contacts:			
Site: Vails Gate					

Sample Date	Sample Time	Sample Identification	Client ID (Lab ID)	Sample Type (C=Comp, G=grab)	Matrix (DW=drinking water, W=water, S=solid, O=waste/oil)	Field Filtered Sample (Yes or No)	Perform MS/MSD (Yes or No)	Chlorine Present (Yes or No)	Lead	Total Number of Containers	Special Instructions/Note:
3/19/21	413	KITCHEN BS		G	DW				1	1	
3/19/21	415	KITCHEN KS #1		G	DW				1	1	
3/19/21	415	KITCHEN KS #2		G	DW				1	1	
3/19/21	416	KITCHEN KS #3		G	DW				1	1	
3/19/21	416	KITCHEN KF		G	DW				1	1	
3/19/21	417	KITCHEN KSP		G	DW				1	1	
3/19/21	420	RM 163 BS		G	DW				1	1	
3/19/21	421	RM 1A BS		G	DW				1	1	
3/19/21	422	RM 167 BS		G	DW				1	1	
3/19/21	423	164 BS		G	DW				1	1	
3/19/21	424	RM 1D BS		G	DW				1	1	
3/19/21	426	RM 157 BS		G	DW				1	1	
3/19/21	427	O/S 152 BF #1		G	DW				1	1	
3/19/21	427	O/S 152 BF #2		G	DW				1	1	
3/19/21	428	O/S 152 BOYS BS #1		G	DW				1	1	

Container Code: P=Plastic, A=Amber, V=Vial, G=Glass, B=Bacteria, C=Cube, O=Other, T=Terracore, D=BOD Bottle		Manufacturer/Lot #:		Date:	Time:	Sample # (s):	Container Type
Preservation Added Upon Receipt:	Relinquished by:		Date/Time: 3/24/21 10:47	Company: OUBOCES	Received by:	Date/Time: 3/24/21 10:45	Company:
	Relinquished by:		Date/Time:	Company:	Received by:	Date/Time:	Company:
	Relinquished by:		Date/Time:	Company:	Received by:	Date/Time:	Company:
ICE Present: <i>No</i>	Custody Seal No.:	Custody Seals Intact: Δ	Cooler Temperature(s) °C/IR GUN #: 17.8 °C				

EnviroTest Laboratories, LLC

315 Fullerton Avenue
Newburgh, NY 12550
Phone (845) 562-0890 Fax (845) 562-0841

Chain of Custody Record



Client Information Client Contact: Kevin Flynn	Sampler: J. Russo	Lab PM:	Deliverable Type: Level I, Level II, NYS ASP Cat B EDD (Specify):	JOB #: 193732 386
	Phone: 845-781-4887	E-Mail: joseph.russo@ouboces.org Halina.redner@ouboces.org Maureen.doherty@ouboces.org		

Company: Orange-Ulster BOCES	Due Date Requested: Standard Turn-Around	Analysis Requested										Page: Page 1 of 1									
Address: 53 Gibson Road	TAT Requested (days):	Field Filtered Sample (Yes or No)	Perform MS/MSD (Yes or No)	Chlorine Present (Yes or No)	Lead															Total Number of Containers	Preservation Codes: A - HCL B - NaOH C - Zn Acetate D - Nitric Acid E - H2SO4 F - MeOH G - NH4CL H - Ascorbic Acid I - Ice J - DI Water K - Sodium Thiosulfate L- EDA - Sodium Sulfite N - None O - MCAA P - Other (specify)
City: Goshen	PO #:																				
State, Zip: NY , 10924	PWS #:	Other: D-Nitric Acid																			
Phone: 845-781-4887	Project #:	Upon Receipt Preservation verified: Y / N																			
Email: joseph.russo@ouboces.org Halina.redner@ouboces.org Maureen.doherty@ouboces.org	Additional Contacts:																				
Project Name: Newburgh ECSD																					
Site: Vails Gate																					

Sample Date	Sample Time	Sample Identification	Client ID (Lab ID)	Sample Type (C=comp, G=grab)	Matrix (DW=drinking water, W=water, S=solid, O=waste/soil)	Field Filtered Sample (Yes or No)	Perform MS/MSD (Yes or No)	Chlorine Present (Yes or No)	Lead													Total Number of Containers	Special Instructions/Note:	
3/19/21	438	O/S LIBRARY GIRLS BS #1		G	DW																	1		
3/19/21	438	O/S LIBRARY GIRLS BS #2		G	DW																	1		
3/19/21	439	LIBRARY BS		G	DW																	1		
3/19/21	440	LIBRARY KS		G	DW																	1		
3/19/21	443	RM 136 CS #1		G	DW																	1		
3/19/21	444	RM 136 CS #2		G	DW																	1		
3/19/21	444	RM 136 BS		G	DW																	1		
3/19/21	445	RM 135 CS		G	DW																	1		
3/19/21	445	RM 133 CS		G	DW																	1		
3/19/21	446	RM 130 CS		G	DW																	1		
3/19/21	447	O/S 130 BF		G	DW																	1		
3/19/21	448	RM 131 CS		G	DW																	1		
3/19/21	448	RM 129 CS		G	DW																	1		
3/19/21	449	RM 127 CS		G	DW																	1		
3/19/21	450	RM 125 CS		G	DW																	1		

Container Code: P=Plastic, A=Amber, V=Vial, G=Glass, B=Bacteria, C=Cube, O=Other, T=Terracore, D=BOD Bottle		P												Container Type
Preservation Added Upon Receipt:	Manufacturer/L of #:	Date:	Time:	Sample # (s):										
Relinquished by:	Date/Time: 10/11 3/24/21	Company: OUBOCES	Received by:	Date/Time: 3/24/21 10:15										
Relinquished by:	Date/Time:	Company:	Received by:	Date/Time:										
Relinquished by:	Date/Time:	Company:	Received by:	Date/Time:										
ICE Present:	Custody Seal No.:	Custody Seals Intact: Δ	Cooler Temperature(s) °C/IR GUN #: 17.8°C											

EnviroTest Laboratories, LLC

315 Fullerton Avenue
Newburgh, NY 12550
Phone (845) 562-0890 Fax (845) 562-0841

Chain of Custody Record



Client Information		Sampler: J. Russo	Lab PM:	Deliverable Type: Level I, Level II, NYS ASP Cat B EDD (Specify):	JOB #: 193732 <i>u of G</i>
Client Contact: Kevin Flynn		Phone: 845-781-4887	E-Mail: joseph.russo@ouboces.org Halina.redner@ouboces.org Maureen.doherty@ouboces.org		

Company: Orange-Ulster BOCES		Analysis Requested			Page: Page 1 of 1			
Address: 53 Gibson Road		Due Date Requested: Standard Turn-Around	Field Filtered Sample (Yes or No)	Perform MS/MSD (Yes or No)	Chlorine Present (Yes or No)	Lead	Total Number of Containers	
City: Goshen		TAT Requested (days):						
State, Zip: NY, 10924		PO #:						
Phone: 845-781-4887		PWS #:						
Email: joseph.russo@ouboces.org Halina.redner@ouboces.org Maureen.doherty@ouboces.org		Project Name: Newburgh ECSD			Project #:		Preservation Codes: A - HCL B - NaOH C - Zn Acetate D - Nitric Acid E - H2SO4 F - MeOH G - NH4CL H - Ascorbic Acid I - Ice J - DI Water K - Sodium Thiosulfate L - EDA M - Sodium Sulfite N - None O - MCAA P - Other (specify)	
Site: Vails Gate		Additional Contacts:			Other: D-Nitric Acid		Upon Receipt Preservation verified: Y / N	

Sample Date	Sample Time	Sample Identification	Client ID (Lab ID)	Sample Type (C=comp, G=grab)	Matrix (DW=drinking water, W=water, S=solid, O=waste/oil)	Field Filtered Sample (Yes or No)	Perform MS/MSD (Yes or No)	Chlorine Present (Yes or No)	Lead	Total Number of Containers	Special Instructions/Note:
3/19/21	450	O/S 125 BF #1		G	DW				1	1	
3/19/21	451	O/S 125 BF #2		G	DW				1	1	
3/19/21	452	O/S 125 BOYS BS #2		G	DW				1	1	
3/19/21	453	O/S 123 GIRLS BS #1		G	DW				1	1	
3/19/21	453	O/S 123 GIRLS BS #2		G	DW				1	1	
3/19/21	454	123 CS		G	DW				1	1	
3/19/21	455	RM 121 CS		G	DW				1	1	
3/19/21	456	RM 118 CS		G	DW				1	1	
3/19/21	453	RM 119 CS		G	DW				1	1	
3/19/21	457	RM 116 CS		G	DW				1	1	
3/19/21	458	RM 117 CS		G	DW				1	1	
3/19/21	458	RM 115 CS		G	DW				1	1	
3/19/21	459	RM 111 CS		G	DW				1	1	
3/19/21	500	RM 113 CS		G	DW				1	1	
3/19/21	501	RM 109 CS		G	DW				1	1	

Container Code: P=Plastic, A=Amber, V=Vial, G=Glass, B=Bacteria, C=Cube, O=Other, T=Terracore, D=BOD Bottle		Manufacturer/Lot #:		Date:	Time:	Sample # (s):	Container Type
Preservation Added Upon Receipt:		Date/Time:		Date:	Date/Time:	Date/Time:	Date/Time:
Relinquished by: <i>[Signature]</i>		Date/Time: 3/24/21 10:41		Company: OUBOCES	Received by: <i>[Signature]</i>	Date/Time: 3/24/21 10:45	Company: <i>[Signature]</i>
Relinquished by:		Date/Time:		Company:	Received by:	Date/Time:	Company:
Relinquished by:		Date/Time:		Company:	Received by:	Date/Time:	Company:
ICE Present: <i>[Initials]</i>	Custody Seal No.:	Custody Seals Intact: Δ	Cooler Temperature(s) °C/IR GUN # 17.8° L				

Chain of Custody Record

Client Information Client Contact: Kevin Flynn	Sampler: J. Russo Phone: 845-781-4887	Lab PM: E-Mail: joseph.russo@ouboces.org Halina.redner@ouboces.org Maureen.doherty@ouboces.org	Deliverable Type: Level I, Level II, NYS ASP Cat B EDD (Specify):	JOB #: 193732 Safe
---	--	--	--	------------------------------

Company: Orange-Ulster BOCES	Address: 53 Gibson Road City: Goshen State, Zip: NY, 10924 Phone: 845-781-4887 Email: joseph.russo@ouboces.org Halina.redner@ouboces.org Maureen.doherty@ouboces.org	Due Date Requested: Standard Turn-Around TAT Requested (days): PO #: PWS #: Project Name: Newburgh ECSD Site: Vails Gate	Project #: Additional Contacts:	Analysis Requested	Page: Page 1 of 1
---------------------------------	---	--	--	---------------------------	----------------------

- Preservation Codes:**
- | | | |
|------------------------|---------------------|---|
| A - HCL | L - EDA | M |
| B - NaOH | - Sodium Sulfite | |
| C - Zn Acetate | N - None | |
| D - Nitric Acid | O - MCAA | |
| E - H2SO4 | P - Other (specify) | |
| F - MeOH | | |
| G - NH4CL | | |
| H - Ascorbic Acid | | |
| I - Ice | | |
| J - DI Water | | |
| K - Sodium Thiosulfate | | |
- Other:
D-Nitric Acid
Upon Receipt Preservation verified:
Y / N

Sample Date	Sample Time	Sample Identification	Client ID (Lab ID)	Sample Type (C=comp, G=grab)	Matrix (DW=drinking water, W=water, S=solid, O=waste/oil)	Field Filtered Sample (Yes or No)	Perform MS/MSD (Yes or No)	Chlorine Present (Yes or No)	Lead	Total Number of Containers	Special Instructions/Note:
3/19/21	501	O/S 109 BF #1		G	DW				1	1	
3/19/21	502	O/S 109 BF #2		G	DW				1	1	
3/19/21	502	O/S 109 BOYS BS #1		G	DW				1	1	
3/19/21	503	O/S 109 BOYS BS #2		G	DW				1	1	
3/19/21	503	O/S 109 GIRLS BS #1		G	DW				1	1	
3/19/21	504	O/S 109 GIRLS BS #2		G	DW				1	1	
3/19/21	504	RM 107 CS		G	DW				1	1	
3/19/21	505	RM 108 CS		G	DW				1	1	
3/19/21	505	RM 105 CS		G	DW				1	1	
3/19/21	506	RM 106 CS		G	DW				1	1	
3/19/21	506	RM 104 CS		G	DW				1	1	
3/19/21	507	RM 102 CS		G	DW				1	1	
3/19/21	508	GIRLS LOCKER ROOM BS		G	DW				1	1	
3/19/21	509	BOYS LOCKER ROOM BS		G	DW				1	1	
3/19/21	511	OFFICE KS		G	DW				1	1	

Container Code: P=Plastic, A=Amber, V=Vial, G=Glass, B=Bacteria, C=Cube, O=Other, T=Terracore, D=BOD Bottle		Manufacturer/I of #:		Date:	Time:	Sample # (s):	Container Type
Relinquished by:	Date/Time:	Company:	Received by:	Date/Time:	Company:		
	3/24/21 10:45	OUBOCES		3/24/21 10:45	PTL		
Relinquished by:	Date/Time:	Company:	Received by:	Date/Time:	Company:		
ICE Present:	Custody Seal No.:	Custody Seals Intact:	Δ	Cooler Temperature(s) °C/IR GUN #:	17.8°C		

EnviroTest Laboratories, LLC

315 Fullerton Avenue
 Newburgh, NY 12550
 Phone (845) 562-0890 Fax (845) 562-0841

Chain of Custody Record



Client Information		Sampler: J. Russo	Lab PM:	Deliverable Type: Level I, Level II, NYS ASP Cat B EDD (Specify):	JOB #: 193732 686
Client Contact: Kevin Flynn		Phone: 845-781-4887	E-Mail: joseph.russo@ouboces.org Halina.redner@ouboces.org Maureen.doherty@ouboces.org		
Company: Orange-Ulster BOCES			Page: Page 1 of 1		

Address: 53 Gibson Road		Due Date Requested: Standard Turn-Around	Analysis Requested				Total Number of Containers	Preservation Codes: A - HCL B - NaOH C - Zn Acetate D - Nitric Acid E - H2SO4 F - MeOH G - NH4CL H - Ascorbic Acid I - Ice J - DI Water K - Sodium Thiosulfate L - EDA M - Sodium Sulfite N - None O - MCAA P - Other (specify)
City: Goshen		TAT Requested (days):						
State, Zip: NY, 10924		PO #:						
Phone: 845-781-4887		PWS #:						
Email: joseph.russo@ouboces.org Halina.redner@ouboces.org Maureen.doherty@ouboces.org		Project #:					Other: D-Nitric Acid	
Project Name: Newburgh ECSD		Additional Contacts:					Upon Receipt Preservation verified: Y / N	
Site: Vails Gate								

Sample Date	Sample Time	Sample Identification	Client ID (Lab ID)	Sample Type (C=comp, G=grab)	Matrix (DW=drinking water, W=water, S=solid, O=waste/oil)	Field Filtered Sample (Yes or No)	Perform MS/MSD (Yes or No)	Chlorine Present (Yes or No)	Lead	Total Number of Containers	Special Instructions/Note:
3/19/21	511	O/S SAFE BS		G	DW				1	1	
3/19/21	512	AP BATH BS		G	DW				1	1	
3/19/21	513	WORK ROOM KS		G	DW				1	1	
3/19/21	513	PRINCIPAL BS		G	DW				1	1	
3/19/21				G	DW				1	1	
3/19/21				G	DW				1	1	
3/19/21				G	DW				1	1	
3/19/21				G	DW				1	1	
3/19/21				G	DW				1	1	
3/19/21				G	DW				1	1	
3/19/21				G	DW				1	1	
3/19/21				G	DW				1	1	
3/19/21				G	DW				1	1	
3/19/21				G	DW				1	1	
3/19/21				G	DW				1	1	
3/19/21				G	DW				1	1	
3/19/21				G	DW				1	1	

Container Code: P=Plastic, A=Amber, V=Vial, G=Glass, B=Bacteria, C=Cube, O=Other, T=Terracore, D=BOD Bottle		Manufacturer/Lot #:		Date:	Time:	Sample # (s):	Container Type
Preservation Added Upon Receipt:		Date/Time:		Date:	Time:	Date/Time:	Date/Time:
Relinquished by: <i>[Signature]</i>		Date/Time: 3/24/21 10:21		Company: OUBOCES	Received by: <i>[Signature]</i>	Date/Time: 3/24/21 10:15	Company: <i>[Signature]</i>
Relinquished by:		Date/Time:		Company:	Received by:	Date/Time:	Company:
Relinquished by:		Date/Time:		Company:	Received by:	Date/Time:	Company:
ICE Present: <i>[Signature]</i> Custody Seal No.:		Custody Seals Intact: Δ		Cooler Temperature(s) °C/IR GUN #: 17.8°C			

LOGIN SAMPLE RECEIPT CHECK LIST

Client: Orange-Ulster BOCES

Job Number: 420-193732-1

SDG Number: Valls Gate

Login Number: 193732

Question	T/F/NA	Comment
Samples were collected by ETL employee as per SOP-SAM-1	NA	
The cooler's custody seal, if present, is intact.	NA	
The cooler or samples do not appear to have been compromised or tampered with.	True	
Samples were received on ice.	False	
Cooler Temperature is recorded.	True	17.8 C
Cooler Temp. is within method specified range.(0-6 C PW, 0-8 C NPW, or BAC <10 C	False	
If false, was sample received on ice within 6 hours of collection.	False	
Based on above criteria cooler temperature is acceptable.	True	Method does not require cooling
COC is present.	True	
COC is filled out in ink and legible.	True	
COC is filled out with all pertinent information.	True	
There are no discrepancies between the sample IDs on the containers and the COC.	True	
Samples are received within Holding Time.	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
Appropriate sample containers are used.	True	
Sample bottles are completely filled.	True	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
VOA sample vials do not have headspace or bubble is <6mm (1/4") in diameter.	NA	
If necessary, staff have been informed of any short hold time or quick TAT needs	True	
Multiphasic samples are not present.	True	
Samples do not require splitting or compositing.	True	