

## ANALYTICAL REPORT

Job Number: 420-194203-1

SDG Number: Newburgh ECSD- NFA Main

Job Description: Orange-Ulster BOCES

For:

Orange-Ulster BOCES

53 Gibson Road

Goshen, NY 10924

Attention: Jack DeGraw

*Meredith Ruthven*

---

Meredith W Ruthven

Customer Service Manager

mruthven@envirotestlaboratories.com

05/13/2021

Revision: 1

NYSDOH ELAP does not certify for all parameters. EnviroTest Laboratories does hold certification for all analytes where certification is offered by ELAP unless otherwise specified in the Certification Information section of this report. Pursuant to NELAP, this report may not be reproduced, except in full, without written approval of the laboratory. EnviroTest Laboratories LLC certifies that the analytical results contained herein apply only to the samples tested as received by our laboratory. All questions regarding this report should be directed to the EnviroTest Customer Service Representative. All services performed by EnviroTest Laboratories LLC are subject to our Terms and Conditions available at [envirotestlabs/terms.com](http://envirotestlabs/terms.com). As of 12/23/19, EnviroTest Laboratories LLC acquired substantially all of the lab and testing assets of EnviroTest Laboratories Inc, including its name.

EnviroTest Laboratories, LLC. Certifications and Approvals: NYSDOH 10142, NJDEP NY015, CTDOPH PH-0554

**Envirotest Laboratories**

315 Fullerton Avenue, Newburgh, NY 12550

Tel (845) 562-0890 Fax (845) 562-0841 [www.envirotestlaboratories.com](http://www.envirotestlaboratories.com)

## METHOD SUMMARY

Client: Orange-Ulster BOCES

Job Number: 420-194203-1  
SDG Number: Newburgh ECSD- NFA Main

<b>Description</b>	<b>Lab Location</b>	<b>Method</b>	<b>Preparation Method</b>
<b>Matrix: Water</b>			
ICPMS Metals by 200.8	EnvTest	EPA 200.8 Rev.5.4	
200 Series Drinking Water Prep Determination Step	EnvTest		EPA 200.7/200.8

### Lab References:

EnvTest = EnviroTest

### Method References:

EPA = US Environmental Protection Agency

## METHOD / ANALYST SUMMARY

Client: Orange-Ulster BOCES

Job Number: 420-194203-1  
SDG Number: Newburgh ECSD- NFA Main

<b>Method</b>	<b>Analyst</b>	<b>Analyst ID</b>
EPA 200.8 Rev.5.4	Luis, Carlos	CL

## SAMPLE SUMMARY

Client: Orange-Ulster BOCES

Job Number: 420-194203-1  
SDG Number: Newburgh ECSD- NFA Main

Lab Sample ID	Client Sample ID	Client Matrix	Date/Time Sampled	Date/Time Received
420-194203-1	O/S 220 BF	Drinking Water	03/27/2021 0507	04/01/2021 1120
420-194203-2	O/S 220 Girls BS 1	Drinking Water	03/27/2021 0510	04/01/2021 1120
420-194203-3	O/S 220 Girls BS 2	Drinking Water	03/27/2021 0510	04/01/2021 1120
420-194203-4	O/S 220 Girls BS 3	Drinking Water	03/27/2021 0511	04/01/2021 1120
420-194203-5	O/S 220 Girls BS 4	Drinking Water	03/27/2021 0511	04/01/2021 1120
420-194203-6	210 CS 1	Drinking Water	03/27/2021 0512	04/01/2021 1120
420-194203-7	210 CS 2	Drinking Water	03/27/2021 0512	04/01/2021 1120
420-194203-8	206 CS	Drinking Water	03/27/2021 0514	04/01/2021 1120
420-194203-9	203 CS	Drinking Water	03/27/2021 0515	04/01/2021 1120
420-194203-10	200 A CS 1	Drinking Water	03/27/2021 0516	04/01/2021 1120
420-194203-11	O/S 200 C CS	Drinking Water	03/27/2021 0516	04/01/2021 1120
420-194203-12	218 Office CS	Drinking Water	03/27/2021 0521	04/01/2021 1120
420-194203-13	Trainers Office SS	Drinking Water	03/27/2021 0524	04/01/2021 1120
420-194203-14	Trainers Office BS	Drinking Water	03/27/2021 0524	04/01/2021 1120
420-194203-15	Pool Boys Locker Rm BS	Drinking Water	03/27/2021 0527	04/01/2021 1120
420-194203-16	Pool Boys Locker Rm BF	Drinking Water	03/27/2021 0526	04/01/2021 1120
420-194203-17	Pool BS 1	Drinking Water	03/27/2021 0530	04/01/2021 1120
420-194203-18	Pool BS 2	Drinking Water	03/27/2021 0530	04/01/2021 1120
420-194203-19	Pool Girls Locker Rm BF	Drinking Water	03/27/2021 0529	04/01/2021 1120
420-194203-20	Swim Instructor BF	Drinking Water	03/27/2021 0531	04/01/2021 1120
420-194203-21	Swim Coachs Office BS	Drinking Water	03/27/2021 0532	04/01/2021 1120
420-194203-22	Ticket Booth Mens BS 1	Drinking Water	03/27/2021 0534	04/01/2021 1120
420-194203-23	Ticket Booth Mens BS 2	Drinking Water	03/27/2021 0534	04/01/2021 1120
420-194203-24	Ticket Booth Mens BF	Drinking Water	03/27/2021 0535	04/01/2021 1120
420-194203-25	Ticket Booth Girls BS 1	Drinking Water	03/27/2021 0536	04/01/2021 1120
420-194203-26	Ticket Booth Girls BS 2	Drinking Water	03/27/2021 0537	04/01/2021 1120
420-194203-27	Ticket Booth Girls BS 3	Drinking Water	03/27/2021 0537	04/01/2021 1120
420-194203-28	Coachs Office BS	Drinking Water	03/27/2021 0538	04/01/2021 1120
420-194203-29	223 KS	Drinking Water	03/27/2021 0542	04/01/2021 1120
420-194203-30	223 Mens BS	Drinking Water	03/27/2021 0543	04/01/2021 1120
420-194203-31	223 Womens BS	Drinking Water	03/27/2021 0543	04/01/2021 1120
420-194203-32	O/S 224 BF	Drinking Water	03/27/2021 0545	04/01/2021 1120
420-194203-33	O/S 224 BS 1	Drinking Water	03/27/2021 0545	04/01/2021 1120
420-194203-34	O/S 224 BS 2	Drinking Water	03/27/2021 0545	04/01/2021 1120
420-194203-35	O/S 224 BS 3	Drinking Water	03/27/2021 0546	04/01/2021 1120
420-194203-36	O/S 224 BS 4	Drinking Water	03/27/2021 0546	04/01/2021 1120
420-194203-37	258 BS	Drinking Water	03/27/2021 0548	04/01/2021 1120
420-194203-38	Stage Bathroom BS	Drinking Water	03/27/2021 0547	04/01/2021 1120
420-194203-39	O/S 232 BS	Drinking Water	03/27/2021 0551	04/01/2021 1120
420-194203-40	232 CS 1	Drinking Water	03/27/2021 0552	04/01/2021 1120
420-194203-41	232 CS 2	Drinking Water	03/27/2021 0552	04/01/2021 1120
420-194203-42	232 CS 3	Drinking Water	03/27/2021 0553	04/01/2021 1120
420-194203-43	234 CS 1	Drinking Water	03/27/2021 0554	04/01/2021 1120
420-194203-44	234 CS 2	Drinking Water	03/27/2021 0555	04/01/2021 1120
420-194203-45	Health Office BS 1	Drinking Water	03/27/2021 0557	04/01/2021 1120
420-194203-46	Health Office BS 2	Drinking Water	03/27/2021 0559	04/01/2021 1120

## SAMPLE SUMMARY

Client: Orange-Ulster BOCES

Job Number: 420-194203-1  
SDG Number: Newburgh ECSD- NFA Main

Lab Sample ID	Client Sample ID	Client Matrix	Date/Time Sampled	Date/Time Received
420-194203-47	Health Office BS 3	Drinking Water	03/27/2021 0600	04/01/2021 1120
420-194203-48	Health Office BS 4	Drinking Water	03/27/2021 0600	04/01/2021 1120
420-194203-49	Health Office O/S Ice Machine	Drinking Water	03/27/2021 0601	04/01/2021 1120
420-194203-50	O/S 243 BF	Drinking Water	03/27/2021 0603	04/01/2021 1120
420-194203-51	O/S 243 Boys BS 1	Drinking Water	03/27/2021 0604	04/01/2021 1120
420-194203-52	O/S 243 Boys BS 2	Drinking Water	03/27/2021 0604	04/01/2021 1120
420-194203-53	O/S 243 Boys BS 3	Drinking Water	03/27/2021 0605	04/01/2021 1120
420-194203-54	O/S 243 Boys BS 4	Drinking Water	03/27/2021 0605	04/01/2021 1120
420-194203-55	O/S 243 Boys BS 5	Drinking Water	03/27/2021 0606	04/01/2021 1120
420-194203-56	O/S 243 Girls BS 1	Drinking Water	03/27/2021 0607	04/01/2021 1120
420-194203-57	O/S 243 Girls BS 2	Drinking Water	03/27/2021 0607	04/01/2021 1120
420-194203-58	O/S 243 Girls BS 3	Drinking Water	03/27/2021 0608	04/01/2021 1120
420-194203-59	O/S 243 Girls BS 4	Drinking Water	03/27/2021 0608	04/01/2021 1120
420-194203-60	O/S 243 Girls BS 5	Drinking Water	03/27/2021 0608	04/01/2021 1120
420-194203-61	248 KS	Drinking Water	03/27/2021 0610	04/01/2021 1120
420-194203-62	252 KS	Drinking Water	03/27/2021 0611	04/01/2021 1120
420-194203-63	O/S 257 BF	Drinking Water	03/27/2021 0612	04/01/2021 1120
420-194203-64	254 KS 1	Drinking Water	03/27/2021 0613	04/01/2021 1120
420-194203-65	254 KS 3	Drinking Water	03/27/2021 0614	04/01/2021 1120
420-194203-66	O/S 254 Mens BS	Drinking Water	03/27/2021 0616	04/01/2021 1120
420-194203-67	O/S 254 Womens BS	Drinking Water	03/27/2021 0617	04/01/2021 1120
420-194203-68	O/S 275 BF	Drinking Water	03/27/2021 0617	04/01/2021 1120
420-194203-69	270 KS	Drinking Water	03/27/2021 0619	04/01/2021 1120
420-194203-70	268 KS	Drinking Water	03/27/2021 0620	04/01/2021 1120
420-194203-71	246 KS 1	Drinking Water	03/27/2021 0621	04/01/2021 1120
420-194203-72	246 KS 3	Drinking Water	03/27/2021 0622	04/01/2021 1120
420-194203-73	O/S 265 BF	Drinking Water	03/27/2021 0623	04/01/2021 1120
420-194203-74	264 KS	Drinking Water	03/27/2021 0624	04/01/2021 1120
420-194203-75	263 KS	Drinking Water	03/27/2021 0625	04/01/2021 1120
420-194203-76	O/S 239 BF	Drinking Water	03/27/2021 0626	04/01/2021 1120
420-194203-77	237 CS	Drinking Water	03/27/2021 0627	04/01/2021 1120
420-194203-78	239 KS	Drinking Water	03/27/2021 0628	04/01/2021 1120
420-194203-79	239 BF	Drinking Water	03/27/2021 0629	04/01/2021 1120
420-194203-80	O/S 238 BF	Drinking Water	03/27/2021 0629	04/01/2021 1120
420-194203-81	240 B BS	Drinking Water	03/27/2021 0630	04/01/2021 1120
420-194203-82	Boys Locker East BS 1	Drinking Water	03/27/2021 0634	04/01/2021 1120
420-194203-83	Boys Locker East BS 2	Drinking Water	03/27/2021 0634	04/01/2021 1120
420-194203-84	Boys Locker Coachs BS	Drinking Water	03/27/2021 0635	04/01/2021 1120
420-194203-85	Boys Locker Coaches Locker BS	Drinking Water	03/27/2021 0635	04/01/2021 1120
420-194203-86	New Locker Room BS 1	Drinking Water	03/27/2021 0639	04/01/2021 1120
420-194203-87	New Locker Room BS 2	Drinking Water	03/27/2021 0639	04/01/2021 1120
420-194203-88	New Locker Room BS 3	Drinking Water	03/27/2021 0640	04/01/2021 1120
420-194203-89	O/S 345 Womens BS	Drinking Water	03/27/2021 0645	04/01/2021 1120
420-194203-90	O/S 345 Mens BS	Drinking Water	03/27/2021 0646	04/01/2021 1120

## SAMPLE SUMMARY

Client: Orange-Ulster BOCES

Job Number: 420-194203-1  
SDG Number: Newburgh ECSD- NFA Main

Lab Sample ID	Client Sample ID	Client Matrix	Date/Time Sampled	Date/Time Received
420-194203-91	O/S 346 BF	Drinking Water	03/27/2021 0646	04/01/2021 1120
420-194203-92	O/S 346 Girls BS 1	Drinking Water	03/27/2021 0646	04/01/2021 1120
420-194203-93	O/S 346 Girls BS 2	Drinking Water	03/27/2021 0646	04/01/2021 1120
420-194203-94	O/S 346 Girls BS 3	Drinking Water	03/27/2021 0647	04/01/2021 1120
420-194203-95	336 Office KS	Drinking Water	03/27/2021 0649	04/01/2021 1120
420-194203-96	O/S 346 Boys BS 1	Drinking Water	03/27/2021 0647	04/01/2021 1120
420-194203-97	O/S 346 Boys BS 2	Drinking Water	03/27/2021 0647	04/01/2021 1120
420-194203-98	O/S 346 Boys BS 3	Drinking Water	03/27/2021 0648	04/01/2021 1120
420-194203-99	278 KS	Drinking Water	03/27/2021 0653	04/01/2021 1120
420-194203-100	O/S 286 Womens BS	Drinking Water	03/27/2021 0652	04/01/2021 1120
420-194203-101	O/S 286 Mens BS	Drinking Water	03/27/2021 0653	04/01/2021 1120
420-194203-102	O/S 288 BF	Drinking Water	03/27/2021 0654	04/01/2021 1120
420-194203-103	O/S 288 Girls BS 1	Drinking Water	03/27/2021 0654	04/01/2021 1120
420-194203-104	O/S 288 Girls BS 2	Drinking Water	03/27/2021 0654	04/01/2021 1120
420-194203-105	O/S 288 Girls BS 3	Drinking Water	03/27/2021 0655	04/01/2021 1120
420-194203-106	O/S 288 Boys BS 1	Drinking Water	03/27/2021 0656	04/01/2021 1120
420-194203-107	O/S 288 Boys BS 2	Drinking Water	03/27/2021 0656	04/01/2021 1120
420-194203-108	O/S 288 Boys BS 3	Drinking Water	03/27/2021 0657	04/01/2021 1120
420-194203-109	O/S 145 Womens BS	Drinking Water	03/27/2021 0659	04/01/2021 1120
420-194203-110	O/S 145 Mens BS	Drinking Water	03/27/2021 0659	04/01/2021 1120
420-194203-111	O/S 147 BF	Drinking Water	03/27/2021 0700	04/01/2021 1120
420-194203-112	O/S 147 Womens BS 1	Drinking Water	03/27/2021 0701	04/01/2021 1120
420-194203-113	O/S 147 Womens BS 2	Drinking Water	03/27/2021 0702	04/01/2021 1120
420-194203-114	O/S 147 Womens BS 3	Drinking Water	03/27/2021 0702	04/01/2021 1120
420-194203-115	O/S 147 Mens BS 1	Drinking Water	03/27/2021 0704	04/01/2021 1120
420-194203-116	O/S 147 Mens BS 2	Drinking Water	03/27/2021 0704	04/01/2021 1120
420-194203-117	O/S 147 Mens BS 3	Drinking Water	03/27/2021 0705	04/01/2021 1120
420-194203-118	139 CS	Drinking Water	03/27/2021 0706	04/01/2021 1120
420-194203-119	110 Dressing BS	Drinking Water	03/27/2021 0708	04/01/2021 1120
420-194203-120	110 BS	Drinking Water	03/27/2021 0709	04/01/2021 1120
420-194203-121	108 Dressing BS	Drinking Water	03/27/2021 0711	04/01/2021 1120
420-194203-122	108 BS	Drinking Water	03/27/2021 0712	04/01/2021 1120
420-194203-123	109 BS 1	Drinking Water	03/27/2021 0712	04/01/2021 1120
420-194203-124	109 BS 2	Drinking Water	03/27/2021 0712	04/01/2021 1120
420-194203-125	109 BS 3	Drinking Water	03/27/2021 0712	04/01/2021 1120
420-194203-126	109 BS 4	Drinking Water	03/27/2021 0713	04/01/2021 1120
420-194203-127	109 BS 5	Drinking Water	03/27/2021 0713	04/01/2021 1120
420-194203-128	109 BS 6	Drinking Water	03/27/2021 0713	04/01/2021 1120
420-194203-129	O/S 105 BF	Drinking Water	03/27/2021 0716	04/01/2021 1120
420-194203-130	107 A KS	Drinking Water	03/27/2021 0716	04/01/2021 1120
420-194203-131	O/S 106 BS	Drinking Water	03/27/2021 0718	04/01/2021 1120
420-194203-132	104 CS	Drinking Water	03/27/2021 0719	04/01/2021 1120
420-194203-133	103 CS	Drinking Water	03/27/2021 0719	04/01/2021 1120
420-194203-134	Cafe A Boys BS	Drinking Water	03/27/2021 0720	04/01/2021 1120
420-194203-135	Cafe A Girls BS	Drinking Water	03/27/2021 0721	04/01/2021 1120
420-194203-136	Cafe A Kitchen BS	Drinking Water	03/27/2021 0722	04/01/2021 1120

## SAMPLE SUMMARY

Client: Orange-Ulster BOCES

Job Number: 420-194203-1  
SDG Number: Newburgh ECSD- NFA Main

Lab Sample ID	Client Sample ID	Client Matrix	Date/Time Sampled	Date/Time Received
420-194203-137	Cafe A KS 1	Drinking Water	03/27/2021 0723	04/01/2021 1120
420-194203-138	Cafe A KS 2	Drinking Water	03/27/2021 0724	04/01/2021 1120
420-194203-139	Cafe A KS 3	Drinking Water	03/27/2021 0724	04/01/2021 1120
420-194203-140	Cafe A KS 4	Drinking Water	03/27/2021 0724	04/01/2021 1120
420-194203-141	Cafe A KS 5	Drinking Water	03/27/2021 0725	04/01/2021 1120
420-194203-142	Cafe A BF	Drinking Water	03/27/2021 0726	04/01/2021 1120
420-194203-143	O/S Cafe C BS	Drinking Water	03/27/2021 0729	04/01/2021 1120
420-194203-144	O/S Cafe C Boys BS 1	Drinking Water	03/27/2021 0731	04/01/2021 1120
420-194203-145	O/S Cafe C Boys BS 2	Drinking Water	03/27/2021 0733	04/01/2021 1120
420-194203-146	O/S Cafe C Boys BS 3	Drinking Water	03/27/2021 0734	04/01/2021 1120
420-194203-147	O/S Cafe C Boys BS 4	Drinking Water	03/27/2021 0734	04/01/2021 1120
420-194203-148	O/S Cafe C Boys BS 5	Drinking Water	03/27/2021 0735	04/01/2021 1120
420-194203-149	O/S Cafe C Boys BS 6	Drinking Water	03/27/2021 0735	04/01/2021 1120
420-194203-150	O/S Cafe C Womens BS	Drinking Water	03/27/2021 0735	04/01/2021 1120
420-194203-151	O/S Cafe C Mens BS	Drinking Water	03/27/2021 0736	04/01/2021 1120
420-194203-152	O/S Cafe C Girls BS 1	Drinking Water	03/27/2021 0737	04/01/2021 1120
420-194203-153	O/S Cafe C Girls BS 2	Drinking Water	03/27/2021 0737	04/01/2021 1120
420-194203-154	O/S Cafe C Girls BS 3	Drinking Water	03/27/2021 0737	04/01/2021 1120
420-194203-155	O/S Cafe C Girls BS 4	Drinking Water	03/27/2021 0738	04/01/2021 1120
420-194203-156	O/S Cafe C Girls BS 5	Drinking Water	03/27/2021 0738	04/01/2021 1120
420-194203-157	113 KS	Drinking Water	03/27/2021 0740	04/01/2021 1120
420-194203-158	120 KS	Drinking Water	03/27/2021 0741	04/01/2021 1120
420-194203-159	O/S 120 BF	Drinking Water	03/27/2021 0742	04/01/2021 1120
420-194203-160	Cafe B BF	Drinking Water	03/27/2021 0742	04/01/2021 1120
420-194203-161	Main Dish Room KS 1	Drinking Water	03/27/2021 0745	04/01/2021 1120
420-194203-162	Main Dish Room KS 2	Drinking Water	03/27/2021 0745	04/01/2021 1120
420-194203-163	Main Dish Room KS 3	Drinking Water	03/27/2021 0746	04/01/2021 1120
420-194203-164	Cafe B Serving Line KS	Drinking Water	03/27/2021 0747	04/01/2021 1120
420-194203-165	Main Kitchen Prep Sink	Drinking Water	03/27/2021 0747	04/01/2021 1120
420-194203-166	O/S 113 KS 1	Drinking Water	03/27/2021 0749	04/01/2021 1120
420-194203-167	O/S 113 KS 2	Drinking Water	03/27/2021 0750	04/01/2021 1120
420-194203-168	O/S 113 KS 3	Drinking Water	03/27/2021 0750	04/01/2021 1120
420-194203-169	Cafe C Serving Line KS 1	Drinking Water	03/27/2021 0751	04/01/2021 1120
420-194203-170	Cafe C Serving Line KS 2	Drinking Water	03/27/2021 0752	04/01/2021 1120
420-194203-171	Cafe C Serving Line KS 3	Drinking Water	03/27/2021 0752	04/01/2021 1120
420-194203-172	Main Kitchen KF	Drinking Water	03/27/2021 0753	04/01/2021 1120
420-194203-173	O/S 133 BF	Drinking Water	03/27/2021 0755	04/01/2021 1120
420-194203-174	131 KS	Drinking Water	03/27/2021 0756	04/01/2021 1120
420-194203-175	129 KS	Drinking Water	03/27/2021 0756	04/01/2021 1120
420-194203-176	128 KS	Drinking Water	03/27/2021 0757	04/01/2021 1120
420-194203-177	127 KS	Drinking Water	03/27/2021 0758	04/01/2021 1120
420-194203-178	O/S 126 BF	Drinking Water	03/27/2021 0759	04/01/2021 1120
420-194203-179	O/S Stairs 7 BS 1	Drinking Water	03/27/2021 0803	04/01/2021 1120
420-194203-180	O/S Stairs 7 BS 2	Drinking Water	03/27/2021 0803	04/01/2021 1120
420-194203-181	O/S 324 BF	Drinking Water	03/27/2021 0805	04/01/2021 1120
420-194203-182	O/S 323 Boys BS 1	Drinking Water	03/27/2021 0806	04/01/2021 1120

## SAMPLE SUMMARY

Client: Orange-Ulster BOCES

Job Number: 420-194203-1  
SDG Number: Newburgh ECSD- NFA Main

Lab Sample ID	Client Sample ID	Client Matrix	Date/Time Sampled	Date/Time Received
420-194203-183	O/S 323 Boys BS 2	Drinking Water	03/27/2021 0806	04/01/2021 1120
420-194203-184	O/S 323 Boys BS 3	Drinking Water	03/27/2021 0807	04/01/2021 1120
420-194203-185	O/S 323 Boys BS 4	Drinking Water	03/27/2021 0807	04/01/2021 1120
420-194203-186	O/S 319 BF	Drinking Water	03/27/2021 0809	04/01/2021 1120
420-194203-187	O/S 317 Girls BS 1	Drinking Water	03/27/2021 0809	04/01/2021 1120
420-194203-188	O/S 317 Girls BS 2	Drinking Water	03/27/2021 0810	04/01/2021 1120
420-194203-189	O/S 317 Girls BS 3	Drinking Water	03/27/2021 0810	04/01/2021 1120
420-194203-190	O/S 317 Girls BS 4	Drinking Water	03/27/2021 0810	04/01/2021 1120
420-194203-191	311 KS Prep	Drinking Water	03/27/2021 0812	04/01/2021 1120
420-194203-192	309 A CS	Drinking Water	03/27/2021 0813	04/01/2021 1120
420-194203-193	O/S 300 BS	Drinking Water	03/27/2021 0816	04/01/2021 1120
420-194203-194	300 BF	Drinking Water	03/27/2021 0816	04/01/2021 1120
420-194203-195	300 BS	Drinking Water	03/27/2021 0817	04/01/2021 1120
420-194203-196	Girls Locker Room BS 1	Drinking Water	03/27/2021 0819	04/01/2021 1120
420-194203-197	Girls Locker Room BS 2	Drinking Water	03/27/2021 0819	04/01/2021 1120
420-194203-198	Girls Coach BS	Drinking Water	03/27/2021 0820	04/01/2021 1120
420-194203-199	Girls Gym BF	Drinking Water	03/27/2021 0821	04/01/2021 1120
420-194203-200	Welding Shop BS	Drinking Water	03/27/2021 0834	04/01/2021 1120
420-194203-201	Welding Shop BF	Drinking Water	03/27/2021 0835	04/01/2021 1120
420-194203-202	Welding Shop Boys BS	Drinking Water	03/27/2021 0837	04/01/2021 1120
420-194203-203	Welding Shop Girls BS	Drinking Water	03/27/2021 0837	04/01/2021 1120
420-194203-204	AD Office BS	Drinking Water	03/27/2021 0841	04/01/2021 1120
420-194203-205	Wood Shop Boys BS 1	Drinking Water	03/27/2021 0848	04/01/2021 1120
420-194203-206	Wood Shop Boys BS 2	Drinking Water	03/27/2021 0848	04/01/2021 1120
420-194203-207	Wood Shop Boys BS 3	Drinking Water	03/27/2021 0849	04/01/2021 1120
420-194203-208	Wood Shop CS O/S BF	Drinking Water	03/27/2021 0849	04/01/2021 1120
420-194203-209	Wood Shop BF	Drinking Water	03/27/2021 0850	04/01/2021 1120
420-194203-210	Wood Shop Girls BS 1	Drinking Water	03/27/2021 0852	04/01/2021 1120
420-194203-211	Wood Shop Girls BS 2	Drinking Water	03/27/2021 0853	04/01/2021 1120
420-194203-212	Wood Shop CS 1	Drinking Water	03/27/2021 0856	04/01/2021 1120
420-194203-213	Wood Shop CS 2	Drinking Water	03/27/2021 0857	04/01/2021 1120
420-194203-214	Trainers Office Ice Machine	Drinking Water	03/27/2021 0523	04/01/2021 1120
420-194203-215	234 Ice Machine	Drinking Water	03/27/2021 0556	04/01/2021 1120
420-194203-216	Health Office Ice Machine	Drinking Water	03/27/2021 0600	04/01/2021 1120
420-194203-217	AD Office Ice Machine	Drinking Water	03/27/2021 0642	04/01/2021 1120



Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** O/S 220 BF  
**Lab Sample ID:** 420-194203-1

Date Sampled: 03/27/2021 0507  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/29/2021 1817		
Prep Method: 200.7/200.8			Date Prepared: 04/26/2021 1300		
Lead	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** O/S 220 Girls BS 1  
**Lab Sample ID:** 420-194203-2

Date Sampled: 03/27/2021 0510  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/29/2021 1825	
Prep Method: 200.7/200.8			Date Prepared:	04/26/2021 1300	
Lead	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** O/S 220 Girls BS 2  
**Lab Sample ID:** 420-194203-3

Date Sampled: 03/27/2021 0510  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/29/2021 1828	
Prep Method: 200.7/200.8			Date Prepared:	04/26/2021 1300	
Lead	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** O/S 220 Girls BS 3  
**Lab Sample ID:** 420-194203-4

Date Sampled: 03/27/2021 0511  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/29/2021 1830	
Prep Method: 200.7/200.8			Date Prepared:	04/26/2021 1300	
Lead	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** O/S 220 Girls BS 4  
**Lab Sample ID:** 420-194203-5

Date Sampled: 03/27/2021 0511  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/29/2021 1836	
Prep Method: 200.7/200.8			Date Prepared:	04/26/2021 1300	
Lead	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** 210 CS 1  
**Lab Sample ID:** 420-194203-6

Date Sampled: 03/27/2021 0512  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/29/2021 1838	
Prep Method: 200.7/200.8			Date Prepared:	04/26/2021 1300	
Lead	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** 210 CS 2  
**Lab Sample ID:** 420-194203-7

Date Sampled: 03/27/2021 0512  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/29/2021 1841	
Prep Method: 200.7/200.8			Date Prepared:	04/26/2021 1300	
Lead	3.51	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** 206 CS  
**Lab Sample ID:** 420-194203-8

Date Sampled: 03/27/2021 0514  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/29/2021 1843	
Prep Method: 200.7/200.8			Date Prepared:	04/26/2021 1300	
Lead	9.21	ug/L	1.00	1.00	1.0



Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** 203 CS  
**Lab Sample ID:** 420-194203-9

Date Sampled: 03/27/2021 0515  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/29/2021 1845	
Prep Method: 200.7/200.8			Date Prepared:	04/26/2021 1300	
Lead	8.25	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** 200 A CS 1  
**Lab Sample ID:** 420-194203-10

Date Sampled: 03/27/2021 0516  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/29/2021 1847	
Prep Method: 200.7/200.8			Date Prepared:	04/26/2021 1300	
Lead	3.52	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** O/S 200 C CS  
**Lab Sample ID:** 420-194203-11

Date Sampled: 03/27/2021 0516  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/29/2021 1852	
Prep Method: 200.7/200.8			Date Prepared:	04/26/2021 1300	
Lead	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** 218 Office CS  
**Lab Sample ID:** 420-194203-12

Date Sampled: 03/27/2021 0521  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/29/2021 1854	
Prep Method: 200.7/200.8			Date Prepared:	04/26/2021 1300	
Lead	6.61	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** Trainers Office SS  
**Lab Sample ID:** 420-194203-13

Date Sampled: 03/27/2021 0524  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/29/2021 1856	
Prep Method: 200.7/200.8			Date Prepared:	04/26/2021 1300	
Lead	8.22	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** Trainers Office BS  
**Lab Sample ID:** 420-194203-14

Date Sampled: 03/27/2021 0524  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/29/2021 1903	
Prep Method: 200.7/200.8			Date Prepared:	04/26/2021 1300	
Lead	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** Pool Boys Locker Rm BS  
**Lab Sample ID:** 420-194203-15

Date Sampled: 03/27/2021 0527  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/29/2021 1905	
Prep Method: 200.7/200.8			Date Prepared:	04/26/2021 1300	
Lead	5.01	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** Pool Boys Locker Rm BF  
**Lab Sample ID:** 420-194203-16

Date Sampled: 03/27/2021 0526  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/29/2021	1907	
Prep Method: 200.7/200.8			Date Prepared: 04/26/2021	1300	
Lead	1.00 U	ug/L	1.00	1.00	1.0



Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** Pool BS 1  
**Lab Sample ID:** 420-194203-17

Date Sampled: 03/27/2021 0530  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/29/2021 1909	
Prep Method: 200.7/200.8			Date Prepared:	04/26/2021 1300	
Lead	2.65	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** Pool BS 2  
**Lab Sample ID:** 420-194203-18

Date Sampled: 03/27/2021 0530  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/29/2021 1911	
Prep Method: 200.7/200.8			Date Prepared:	04/26/2021 1300	
Lead	3.86	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** Pool Girls Locker Rm BF  
**Lab Sample ID:** 420-194203-19

Date Sampled: 03/27/2021 0529  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/29/2021 1913		
Prep Method: 200.7/200.8			Date Prepared: 04/26/2021 1300		
Lead	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** Swim Instructor BF  
**Lab Sample ID:** 420-194203-20

Date Sampled: 03/27/2021 0531  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/29/2021 1916	
Prep Method: 200.7/200.8			Date Prepared:	04/26/2021 1300	
Lead	3.42	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** Swim Coachs Office BS  
**Lab Sample ID:** 420-194203-21

Date Sampled: 03/27/2021 0532  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/29/2021 1929	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0845	
Lead	11.5	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** Ticket Booth Mens BS 1  
**Lab Sample ID:** 420-194203-22

Date Sampled: 03/27/2021 0534  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/29/2021 1931	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0845	
Lead	2.73	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** Ticket Booth Mens BS 2  
**Lab Sample ID:** 420-194203-23

Date Sampled: 03/27/2021 0534  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/29/2021 1933	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0845	
Lead	8.74	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** Ticket Booth Mens BF  
**Lab Sample ID:** 420-194203-24

Date Sampled: 03/27/2021 0535  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/29/2021 1935	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0845	
Lead	1.00 U	ug/L	1.00	1.00	1.0



Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** Ticket Booth Girls BS 1  
**Lab Sample ID:** 420-194203-25

Date Sampled: 03/27/2021 0536  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/29/2021 1938	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0845	
Lead	18.7 g	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** Ticket Booth Girls BS 2  
**Lab Sample ID:** 420-194203-26

Date Sampled: 03/27/2021 0537  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution	
Method: 200.8 Rev.5.4			Date Analyzed:	04/29/2021 1940		
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0845		
Lead	28.8	g	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** Ticket Booth Girls BS 3  
**Lab Sample ID:** 420-194203-27

Date Sampled: 03/27/2021 0537  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4 Lead	221 g	ug/L	10.0	10.0	10

Date Analyzed: 04/30/2021 1703

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** Coachs Office BS  
**Lab Sample ID:** 420-194203-28

Date Sampled: 03/27/2021 0538  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/29/2021 1944	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0845	
Lead	1.59	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** 223 KS  
**Lab Sample ID:** 420-194203-29

Date Sampled: 03/27/2021 0542  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/29/2021 1946	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0845	
Lead	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** 223 Mens BS  
**Lab Sample ID:** 420-194203-30

Date Sampled: 03/27/2021 0543  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/29/2021 1948	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0845	
Lead	2.18	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** 223 Womens BS  
**Lab Sample ID:** 420-194203-31

Date Sampled: 03/27/2021 0543  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/29/2021 1957	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0845	
Lead	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** O/S 224 BF  
**Lab Sample ID:** 420-194203-32

Date Sampled: 03/27/2021 0545  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/29/2021 1959	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0845	
Lead	1.00 U	ug/L	1.00	1.00	1.0



Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** O/S 224 BS 1  
**Lab Sample ID:** 420-194203-33

Date Sampled: 03/27/2021 0545  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/29/2021 2002	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0845	
Lead	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** O/S 224 BS 2  
**Lab Sample ID:** 420-194203-34

Date Sampled: 03/27/2021 0545  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/29/2021 2004	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0845	
Lead	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** O/S 224 BS 3  
**Lab Sample ID:** 420-194203-35

Date Sampled: 03/27/2021 0546  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/29/2021 2006	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0845	
Lead	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** O/S 224 BS 4  
**Lab Sample ID:** 420-194203-36

Date Sampled: 03/27/2021 0546  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/29/2021 2008	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0845	
Lead	1.05	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** 258 BS  
**Lab Sample ID:** 420-194203-37

Date Sampled: 03/27/2021 0548  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/29/2021 2010	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0845	
Lead	10.8	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** Stage Bathroom BS  
**Lab Sample ID:** 420-194203-38

Date Sampled: 03/27/2021 0547  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/29/2021 2012	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0845	
Lead	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** O/S 232 BS  
**Lab Sample ID:** 420-194203-39

Date Sampled: 03/27/2021 0551  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/29/2021 2015	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0845	
Lead	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** 232 CS 1  
**Lab Sample ID:** 420-194203-40

Date Sampled: 03/27/2021 0552  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/29/2021	2021
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021	0845
Lead	2.30	ug/L	1.00	1.00	1.0



Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** 232 CS 2  
**Lab Sample ID:** 420-194203-41

Date Sampled: 03/27/2021 0552  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/29/2021 2030	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0845	
Lead	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** 232 CS 3  
**Lab Sample ID:** 420-194203-42

Date Sampled: 03/27/2021 0553  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/29/2021 2032	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0845	
Lead	5.07	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** 234 CS 1  
**Lab Sample ID:** 420-194203-43

Date Sampled: 03/27/2021 0554  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/29/2021 2034	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0845	
Lead	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** 234 CS 2  
**Lab Sample ID:** 420-194203-44

Date Sampled: 03/27/2021 0555  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/29/2021 2037	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0845	
Lead	2.05	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** Health Office BS 1  
**Lab Sample ID:** 420-194203-45

Date Sampled: 03/27/2021 0557  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/29/2021 2039	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0845	
Lead	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** Health Office BS 2  
**Lab Sample ID:** 420-194203-46

Date Sampled: 03/27/2021 0559  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/29/2021 2041	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0845	
Lead	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** Health Office BS 3  
**Lab Sample ID:** 420-194203-47

Date Sampled: 03/27/2021 0600  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/29/2021	2047	
Prep Method: 200.7/200.8			Date Prepared: 04/27/2021	0845	
Lead	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** Health Office BS 4  
**Lab Sample ID:** 420-194203-48

Date Sampled: 03/27/2021 0600  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4 Lead	11.4	ug/L	1.00	1.00	1.0

Date Analyzed: 05/06/2021 1414



Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** Health Office O/S Ice Machine  
**Lab Sample ID:** 420-194203-49

Date Sampled: 03/27/2021 0601  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/29/2021 2050	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0845	
Lead	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** O/S 243 BF  
**Lab Sample ID:** 420-194203-50

Date Sampled: 03/27/2021 0603  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/29/2021 2052	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0845	
Lead	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** O/S 243 Boys BS 1  
**Lab Sample ID:** 420-194203-51

Date Sampled: 03/27/2021 0604  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/29/2021 2056	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0845	
Lead	5.33	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** O/S 243 Boys BS 2  
**Lab Sample ID:** 420-194203-52

Date Sampled: 03/27/2021 0604  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/29/2021 2058	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0845	
Lead	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** O/S 243 Boys BS 3  
**Lab Sample ID:** 420-194203-53

Date Sampled: 03/27/2021 0605  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/29/2021	2101	
Prep Method: 200.7/200.8			Date Prepared: 04/27/2021	0845	
Lead	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** O/S 243 Boys BS 4  
**Lab Sample ID:** 420-194203-54

Date Sampled: 03/27/2021 0605  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/29/2021 2103	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0845	
Lead	7.23	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** O/S 243 Boys BS 5  
**Lab Sample ID:** 420-194203-55

Date Sampled: 03/27/2021 0606  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/29/2021 2105	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0845	
Lead	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** O/S 243 Girls BS 1  
**Lab Sample ID:** 420-194203-56

Date Sampled: 03/27/2021 0607  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/29/2021 2107	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0845	
Lead	1.00 U	ug/L	1.00	1.00	1.0



Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** O/S 243 Girls BS 2  
**Lab Sample ID:** 420-194203-57

Date Sampled: 03/27/2021 0607  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/29/2021 2114	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0845	
Lead	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** O/S 243 Girls BS 3  
**Lab Sample ID:** 420-194203-58

Date Sampled: 03/27/2021 0608  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/29/2021 2116	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0845	
Lead	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** O/S 243 Girls BS 4  
**Lab Sample ID:** 420-194203-59

Date Sampled: 03/27/2021 0608  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/29/2021 2118	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0845	
Lead	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** O/S 243 Girls BS 5  
**Lab Sample ID:** 420-194203-60

Date Sampled: 03/27/2021 0608  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/29/2021 2120	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0845	
Lead	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** 248 KS  
**Lab Sample ID:** 420-194203-61

Date Sampled: 03/27/2021 0610  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/29/2021 2129	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0845	
Lead	9.34	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** 252 KS  
**Lab Sample ID:** 420-194203-62

Date Sampled: 03/27/2021 0611  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/29/2021 2131	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0845	
Lead	4.42	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** O/S 257 BF  
**Lab Sample ID:** 420-194203-63

Date Sampled: 03/27/2021 0612  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/29/2021 2133	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0845	
Lead	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** 254 KS 1  
**Lab Sample ID:** 420-194203-64

Date Sampled: 03/27/2021 0613  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/29/2021 2140	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0845	
Lead	9.27	ug/L	1.00	1.00	1.0



Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** 254 KS 3  
**Lab Sample ID:** 420-194203-65

Date Sampled: 03/27/2021 0614  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/29/2021 2142	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0845	
Lead	22.9 g	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** O/S 254 Mens BS  
**Lab Sample ID:** 420-194203-66

Date Sampled: 03/27/2021 0616  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/29/2021	2144	
Prep Method: 200.7/200.8			Date Prepared: 04/27/2021	0845	
Lead	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** O/S 254 Womens BS  
**Lab Sample ID:** 420-194203-67

Date Sampled: 03/27/2021 0617  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/29/2021 2146	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0845	
Lead	1.93	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** O/S 275 BF  
**Lab Sample ID:** 420-194203-68

Date Sampled: 03/27/2021 0617  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/29/2021 2148	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0845	
Lead	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** 270 KS  
**Lab Sample ID:** 420-194203-69

Date Sampled: 03/27/2021 0619  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4 Lead	219 g	ug/L	10.0	10.0	10

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** 268 KS  
**Lab Sample ID:** 420-194203-70

Date Sampled: 03/27/2021 0620  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/29/2021 2153	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0845	
Lead	18.2 g	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** 246 KS 1  
**Lab Sample ID:** 420-194203-71

Date Sampled: 03/27/2021 0621  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/29/2021 2157	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0845	
Lead	7.53	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** 246 KS 3  
**Lab Sample ID:** 420-194203-72

Date Sampled: 03/27/2021 0622  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/29/2021 2159	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0845	
Lead	3.12	ug/L	1.00	1.00	1.0



Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** O/S 265 BF  
**Lab Sample ID:** 420-194203-73

Date Sampled: 03/27/2021 0623  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/29/2021 2206	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0845	
Lead	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** 264 KS  
**Lab Sample ID:** 420-194203-74

Date Sampled: 03/27/2021 0624  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/29/2021 2208	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0845	
Lead	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** 263 KS  
**Lab Sample ID:** 420-194203-75

Date Sampled: 03/27/2021 0625  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/29/2021 2210	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0845	
Lead	2.18	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** O/S 239 BF  
**Lab Sample ID:** 420-194203-76

Date Sampled: 03/27/2021 0626  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/29/2021 2212	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0845	
Lead	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** 237 CS  
**Lab Sample ID:** 420-194203-77

Date Sampled: 03/27/2021 0627  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/29/2021 2215	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0845	
Lead	1.83	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** 239 KS  
**Lab Sample ID:** 420-194203-78

Date Sampled: 03/27/2021 0628  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/29/2021 2217		
Prep Method: 200.7/200.8			Date Prepared: 04/27/2021 0845		
Lead	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** 239 BF  
**Lab Sample ID:** 420-194203-79

Date Sampled: 03/27/2021 0629  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/29/2021 2219		
Prep Method: 200.7/200.8			Date Prepared: 04/27/2021 0845		
Lead	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** O/S 238 BF  
**Lab Sample ID:** 420-194203-80

Date Sampled: 03/27/2021 0629  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/29/2021 2221	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0845	
Lead	1.00 U	ug/L	1.00	1.00	1.0



Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** 240 B BS  
**Lab Sample ID:** 420-194203-81

Date Sampled: 03/27/2021 0630  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/29/2021 2234		
Prep Method: 200.7/200.8			Date Prepared: 04/27/2021 0845		
Lead	23.6 g	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** Boys Locker East BS 1  
**Lab Sample ID:** 420-194203-82

Date Sampled: 03/27/2021 0634  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/29/2021 2236	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0845	
Lead	4.06	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** Boys Locker East BS 2  
**Lab Sample ID:** 420-194203-83

Date Sampled: 03/27/2021 0634  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/29/2021 2239	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0845	
Lead	1.89	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** Boys Locker Coachs BS  
**Lab Sample ID:** 420-194203-84

Date Sampled: 03/27/2021 0635  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/29/2021 2241	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0845	
Lead	9.86	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** Boys Locker Coaches Locker BS  
**Lab Sample ID:** 420-194203-85

Date Sampled: 03/27/2021 0635  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/29/2021 2243	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0845	
Lead	2.58	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** New Locker Room BS 1  
**Lab Sample ID:** 420-194203-86

Date Sampled: 03/27/2021 0639  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/29/2021 2245		
Prep Method: 200.7/200.8			Date Prepared: 04/27/2021 0845		
Lead	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** New Locker Room BS 2  
**Lab Sample ID:** 420-194203-87

Date Sampled: 03/27/2021 0639  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/29/2021 2247	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0845	
Lead	1.36	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** New Locker Room BS 3  
**Lab Sample ID:** 420-194203-88

Date Sampled: 03/27/2021 0640  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/29/2021 2249		
Prep Method: 200.7/200.8			Date Prepared: 04/27/2021 0845		
Lead	1.00 U	ug/L	1.00	1.00	1.0



Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** O/S 345 Womens BS  
**Lab Sample ID:** 420-194203-89

Date Sampled: 03/27/2021 0645  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/29/2021 2252	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0845	
Lead	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** O/S 345 Mens BS  
**Lab Sample ID:** 420-194203-90

Date Sampled: 03/27/2021 0646  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/29/2021 2258	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0845	
Lead	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** O/S 346 BF  
**Lab Sample ID:** 420-194203-91

Date Sampled: 03/27/2021 0646  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/29/2021	2303	
Prep Method: 200.7/200.8			Date Prepared: 04/27/2021	0845	
Lead	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** O/S 346 Girls BS 1  
**Lab Sample ID:** 420-194203-92

Date Sampled: 03/27/2021 0646  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/29/2021 2305	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0845	
Lead	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** O/S 346 Girls BS 2  
**Lab Sample ID:** 420-194203-93

Date Sampled: 03/27/2021 0646  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/29/2021 2307	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0845	
Lead	6.00	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** O/S 346 Girls BS 3  
**Lab Sample ID:** 420-194203-94

Date Sampled: 03/27/2021 0647  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/29/2021 2309	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0845	
Lead	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** 336 Office KS  
**Lab Sample ID:** 420-194203-95

Date Sampled: 03/27/2021 0649  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/29/2021	2311	
Prep Method: 200.7/200.8			Date Prepared: 04/27/2021	0845	
Lead	9.89	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** O/S 346 Boys BS 1  
**Lab Sample ID:** 420-194203-96

Date Sampled: 03/27/2021 0647  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/29/2021 2313	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0845	
Lead	1.19	ug/L	1.00	1.00	1.0



Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** O/S 346 Boys BS 2  
**Lab Sample ID:** 420-194203-97

Date Sampled: 03/27/2021 0647  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4 Lead	1.17	ug/L	1.00	1.00	1.0

Date Analyzed: 04/29/2021 2316

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** O/S 346 Boys BS 3  
**Lab Sample ID:** 420-194203-98

Date Sampled: 03/27/2021 0648  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4 Lead	1.00 U	ug/L	1.00	04/29/2021 2318 1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** 278 KS  
**Lab Sample ID:** 420-194203-99

Date Sampled: 03/27/2021 0653  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/01/2021 1335	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0900	
Lead	10.6	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** O/S 286 Womens BS  
**Lab Sample ID:** 420-194203-100

Date Sampled: 03/27/2021 0652  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/01/2021 1337	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0900	
Lead	1.05	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** O/S 286 Mens BS  
**Lab Sample ID:** 420-194203-101

Date Sampled: 03/27/2021 0653  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/01/2021 1346	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0900	
Lead	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** O/S 288 BF  
**Lab Sample ID:** 420-194203-102

Date Sampled: 03/27/2021 0654  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/01/2021 1348	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0900	
Lead	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** O/S 288 Girls BS 1  
**Lab Sample ID:** 420-194203-103

Date Sampled: 03/27/2021 0654  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/01/2021 1350	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0900	
Lead	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** O/S 288 Girls BS 2  
**Lab Sample ID:** 420-194203-104

Date Sampled: 03/27/2021 0654  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/01/2021 1357	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0900	
Lead	3.43	ug/L	1.00	1.00	1.0



Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** O/S 288 Girls BS 3  
**Lab Sample ID:** 420-194203-105

Date Sampled: 03/27/2021 0655  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/01/2021 1359	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0900	
Lead	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** O/S 288 Boys BS 1  
**Lab Sample ID:** 420-194203-106

Date Sampled: 03/27/2021 0656  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/01/2021 1401	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0900	
Lead	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** O/S 288 Boys BS 2  
**Lab Sample ID:** 420-194203-107

Date Sampled: 03/27/2021 0656  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/01/2021 1403	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0900	
Lead	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** O/S 288 Boys BS 3  
**Lab Sample ID:** 420-194203-108

Date Sampled: 03/27/2021 0657  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/01/2021 1406	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0900	
Lead	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** O/S 145 Womens BS  
**Lab Sample ID:** 420-194203-109

Date Sampled: 03/27/2021 0659  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/01/2021 1408	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0900	
Lead	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** O/S 145 Mens BS  
**Lab Sample ID:** 420-194203-110

Date Sampled: 03/27/2021 0659  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/01/2021 1410	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0900	
Lead	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** O/S 147 BF  
**Lab Sample ID:** 420-194203-111

Date Sampled: 03/27/2021 0700  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/01/2021 1414	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0900	
Lead	1.16	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** O/S 147 Womens BS 1  
**Lab Sample ID:** 420-194203-112

Date Sampled: 03/27/2021 0701  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/01/2021 1417	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0900	
Lead	1.00 U	ug/L	1.00	1.00	1.0



Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** O/S 147 Womens BS 2  
**Lab Sample ID:** 420-194203-113

Date Sampled: 03/27/2021 0702  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/01/2021 1423	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0900	
Lead	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** O/S 147 Womens BS 3  
**Lab Sample ID:** 420-194203-114

Date Sampled: 03/27/2021 0702  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/01/2021 1425	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0900	
Lead	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** O/S 147 Mens BS 1  
**Lab Sample ID:** 420-194203-115

Date Sampled: 03/27/2021 0704  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/01/2021 1427	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0900	
Lead	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** O/S 147 Mens BS 2  
**Lab Sample ID:** 420-194203-116

Date Sampled: 03/27/2021 0704  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/01/2021 1430	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0900	
Lead	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** O/S 147 Mens BS 3  
**Lab Sample ID:** 420-194203-117

Date Sampled: 03/27/2021 0705  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/01/2021 1432	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0900	
Lead	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** 139 CS  
**Lab Sample ID:** 420-194203-118

Date Sampled: 03/27/2021 0706  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/01/2021 1434	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0900	
Lead	2.30	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** 110 Dressing BS  
**Lab Sample ID:** 420-194203-119

Date Sampled: 03/27/2021 0708  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/01/2021 1436	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0900	
Lead	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** 110 BS  
**Lab Sample ID:** 420-194203-120

Date Sampled: 03/27/2021 0709  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/01/2021 1438	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0900	
Lead	4.12	ug/L	1.00	1.00	1.0



Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** 108 Dressing BS  
**Lab Sample ID:** 420-194203-121

Date Sampled: 03/27/2021 0711  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/01/2021 1451	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0900	
Lead	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** 108 BS  
**Lab Sample ID:** 420-194203-122

Date Sampled: 03/27/2021 0712  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/01/2021 1454	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0900	
Lead	7.57	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** 109 BS 1  
**Lab Sample ID:** 420-194203-123

Date Sampled: 03/27/2021 0712  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 05/01/2021 1456		
Prep Method: 200.7/200.8			Date Prepared: 04/27/2021 0900		
Lead	1.27	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** 109 BS 2  
**Lab Sample ID:** 420-194203-124

Date Sampled: 03/27/2021 0712  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/01/2021 1458	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0900	
Lead	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** 109 BS 3  
**Lab Sample ID:** 420-194203-125

Date Sampled: 03/27/2021 0712  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/01/2021 1500	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0900	
Lead	4.76	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** 109 BS 4  
**Lab Sample ID:** 420-194203-126

Date Sampled: 03/27/2021 0713  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/01/2021 1502	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0900	
Lead	8.66	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** 109 BS 5  
**Lab Sample ID:** 420-194203-127

Date Sampled: 03/27/2021 0713  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/01/2021 1505	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0900	
Lead	1.30	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** 109 BS 6  
**Lab Sample ID:** 420-194203-128

Date Sampled: 03/27/2021 0713  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/01/2021 1507	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0900	
Lead	1.10	ug/L	1.00	1.00	1.0



Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** O/S 105 BF  
**Lab Sample ID:** 420-194203-129

Date Sampled: 03/27/2021 0716  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/01/2021 1509	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0900	
Lead	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** 107 A KS  
**Lab Sample ID:** 420-194203-130

Date Sampled: 03/27/2021 0716  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/04/2021 1251	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0900	
Lead	10.1	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** O/S 106 BS  
**Lab Sample ID:** 420-194203-131

Date Sampled: 03/27/2021 0718  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/04/2021 1258	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0900	
Lead	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** 104 CS  
**Lab Sample ID:** 420-194203-132

Date Sampled: 03/27/2021 0719  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/04/2021 1301	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0900	
Lead	4.91	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** 103 CS  
**Lab Sample ID:** 420-194203-133

Date Sampled: 03/27/2021 0719  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/04/2021 1304	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0900	
Lead	1.79	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID: Cafe A Boys BS**  
**Lab Sample ID: 420-194203-134**

Date Sampled: 03/27/2021 0720  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 05/04/2021 1308		
Prep Method: 200.7/200.8			Date Prepared: 04/27/2021 0900		
Lead	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** Cafe A Girls BS  
**Lab Sample ID:** 420-194203-135

Date Sampled: 03/27/2021 0721  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/04/2021 1311	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0900	
Lead	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** Cafe A Kitchen BS  
**Lab Sample ID:** 420-194203-136

Date Sampled: 03/27/2021 0722  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/04/2021 1314	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0900	
Lead	128 g	ug/L	1.00	1.00	1.0



Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** Cafe A KS 1  
**Lab Sample ID:** 420-194203-137

Date Sampled: 03/27/2021 0723  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/04/2021 1317	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0900	
Lead	15.3 g	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** Cafe A KS 2  
**Lab Sample ID:** 420-194203-138

Date Sampled: 03/27/2021 0724  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/04/2021 1327	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0900	
Lead	4.65	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** Cafe A KS 3  
**Lab Sample ID:** 420-194203-139

Date Sampled: 03/27/2021 0724  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/04/2021 1330	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0900	
Lead	43.3 g	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** Cafe A KS 4  
**Lab Sample ID:** 420-194203-140

Date Sampled: 03/27/2021 0724  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/04/2021 1333	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0900	
Lead	4.57	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** Cafe A KS 5  
**Lab Sample ID:** 420-194203-141

Date Sampled: 03/27/2021 0725  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/04/2021 1346	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0900	
Lead	6.36	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** Cafe A BF  
**Lab Sample ID:** 420-194203-142

Date Sampled: 03/27/2021 0726  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/04/2021 1349	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0900	
Lead	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** O/S Cafe C BS  
**Lab Sample ID:** 420-194203-143

Date Sampled: 03/27/2021 0729  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/04/2021 1352	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0900	
Lead	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** O/S Cafe C Boys BS 1  
**Lab Sample ID:** 420-194203-144

Date Sampled: 03/27/2021 0731  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/04/2021 1356	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0900	
Lead	1.00 U	ug/L	1.00	1.00	1.0



Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** O/S Cafe C Boys BS 2  
**Lab Sample ID:** 420-194203-145

Date Sampled: 03/27/2021 0733  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/04/2021 1405	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0900	
Lead	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** O/S Cafe C Boys BS 3  
**Lab Sample ID:** 420-194203-146

Date Sampled: 03/27/2021 0734  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/01/2021 1608	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0900	
Lead	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** O/S Cafe C Boys BS 4  
**Lab Sample ID:** 420-194203-147

Date Sampled: 03/27/2021 0734  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/01/2021 1610	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0900	
Lead	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** O/S Cafe C Boys BS 5  
**Lab Sample ID:** 420-194203-148

Date Sampled: 03/27/2021 0735  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/01/2021 1612	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0900	
Lead	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** O/S Cafe C Boys BS 6  
**Lab Sample ID:** 420-194203-149

Date Sampled: 03/27/2021 0735  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/01/2021 1614	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0900	
Lead	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** O/S Cafe C Womens BS  
**Lab Sample ID:** 420-194203-150

Date Sampled: 03/27/2021 0735  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/01/2021 1617	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0900	
Lead	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** O/S Cafe C Mens BS  
**Lab Sample ID:** 420-194203-151

Date Sampled: 03/27/2021 0736  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/01/2021 1621	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0900	
Lead	1.55	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** O/S Cafe C Girls BS 1  
**Lab Sample ID:** 420-194203-152

Date Sampled: 03/27/2021 0737  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/01/2021 1623	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0900	
Lead	1.00 U	ug/L	1.00	1.00	1.0



Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** O/S Cafe C Girls BS 2  
**Lab Sample ID:** 420-194203-153

Date Sampled: 03/27/2021 0737  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/01/2021 1625	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0900	
Lead	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** O/S Cafe C Girls BS 3  
**Lab Sample ID:** 420-194203-154

Date Sampled: 03/27/2021 0737  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/01/2021 1627	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0900	
Lead	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** O/S Cafe C Girls BS 4  
**Lab Sample ID:** 420-194203-155

Date Sampled: 03/27/2021 0738  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/01/2021 1634	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0900	
Lead	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** O/S Cafe C Girls BS 5  
**Lab Sample ID:** 420-194203-156

Date Sampled: 03/27/2021 0738  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/01/2021 1636	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0900	
Lead	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** 113 KS  
**Lab Sample ID:** 420-194203-157

Date Sampled: 03/27/2021 0740  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/01/2021 1638	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0900	
Lead	3.76	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** 120 KS  
**Lab Sample ID:** 420-194203-158

Date Sampled: 03/27/2021 0741  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/01/2021 1641	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0900	
Lead	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** O/S 120 BF  
**Lab Sample ID:** 420-194203-159

Date Sampled: 03/27/2021 0742  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 05/01/2021 1643		
Prep Method: 200.7/200.8			Date Prepared: 04/27/2021 0900		
Lead	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** Cafe B BF  
**Lab Sample ID:** 420-194203-160

Date Sampled: 03/27/2021 0742  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/01/2021 1645	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0900	
Lead	1.00 U	ug/L	1.00	1.00	1.0



Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** Main Dish Room KS 1  
**Lab Sample ID:** 420-194203-161

Date Sampled: 03/27/2021 0745  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 05/01/2021 1654		
Prep Method: 200.7/200.8			Date Prepared: 04/27/2021 0900		
Lead	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** Main Dish Room KS 2  
**Lab Sample ID:** 420-194203-162

Date Sampled: 03/27/2021 0745  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/01/2021 1700	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0900	
Lead	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** Main Dish Room KS 3  
**Lab Sample ID:** 420-194203-163

Date Sampled: 03/27/2021 0746  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/01/2021 1702	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0900	
Lead	84.5 g	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** Cafe B Serving Line KS  
**Lab Sample ID:** 420-194203-164

Date Sampled: 03/27/2021 0747  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/01/2021 1705	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0900	
Lead	3.80	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** Main Kitchen Prep Sink  
**Lab Sample ID:** 420-194203-165

Date Sampled: 03/27/2021 0747  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/01/2021 1707	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0900	
Lead	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** O/S 113 KS 1  
**Lab Sample ID:** 420-194203-166

Date Sampled: 03/27/2021 0749  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/01/2021 1709	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0900	
Lead	12.2	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** O/S 113 KS 2  
**Lab Sample ID:** 420-194203-167

Date Sampled: 03/27/2021 0750  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/01/2021 1711	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0900	
Lead	19.1 g	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** O/S 113 KS 3  
**Lab Sample ID:** 420-194203-168

Date Sampled: 03/27/2021 0750  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/01/2021 1713	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0900	
Lead	2.63	ug/L	1.00	1.00	1.0



Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** Cafe C Serving Line KS 1  
**Lab Sample ID:** 420-194203-169

Date Sampled: 03/27/2021 0751  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/01/2021 1715	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0900	
Lead	5.84	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** Cafe C Serving Line KS 2  
**Lab Sample ID:** 420-194203-170

Date Sampled: 03/27/2021 0752  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/01/2021 1718	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0900	
Lead	3.36	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** Cafe C Serving Line KS 3  
**Lab Sample ID:** 420-194203-171

Date Sampled: 03/27/2021 0752  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/01/2021 1726	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0900	
Lead	6.02	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** Main Kitchen KF  
**Lab Sample ID:** 420-194203-172

Date Sampled: 03/27/2021 0753  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/01/2021 1729	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0900	
Lead	1.52	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** O/S 133 BF  
**Lab Sample ID:** 420-194203-173

Date Sampled: 03/27/2021 0755  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/01/2021 1731	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0900	
Lead	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** 131 KS  
**Lab Sample ID:** 420-194203-174

Date Sampled: 03/27/2021 0756  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/01/2021 1733	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0900	
Lead	11.6	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** 129 KS  
**Lab Sample ID:** 420-194203-175

Date Sampled: 03/27/2021 0756  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/01/2021 1735	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0900	
Lead	1.58	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** 128 KS  
**Lab Sample ID:** 420-194203-176

Date Sampled: 03/27/2021 0757  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/01/2021 1737	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0900	
Lead	4.18	ug/L	1.00	1.00	1.0



Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** 127 KS  
**Lab Sample ID:** 420-194203-177

Date Sampled: 03/27/2021 0758  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/01/2021 1739	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0900	
Lead	21.7 g	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** O/S 126 BF  
**Lab Sample ID:** 420-194203-178

Date Sampled: 03/27/2021 0759  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 05/01/2021 1742		
Prep Method: 200.7/200.8			Date Prepared: 04/27/2021 0900		
Lead	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** O/S Stairs 7 BS 1  
**Lab Sample ID:** 420-194203-179

Date Sampled: 03/27/2021 0803  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/01/2021 1744	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0900	
Lead	2.28	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** O/S Stairs 7 BS 2  
**Lab Sample ID:** 420-194203-180

Date Sampled: 03/27/2021 0803  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/01/2021 1746	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0900	
Lead	3.79	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** O/S 324 BF  
**Lab Sample ID:** 420-194203-181

Date Sampled: 03/27/2021 0805  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/01/2021 1759	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0900	
Lead	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** O/S 323 Boys BS 1  
**Lab Sample ID:** 420-194203-182

Date Sampled: 03/27/2021 0806  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/01/2021 1801	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0900	
Lead	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** O/S 323 Boys BS 2  
**Lab Sample ID:** 420-194203-183

Date Sampled: 03/27/2021 0806  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/01/2021 1803	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0900	
Lead	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** O/S 323 Boys BS 3  
**Lab Sample ID:** 420-194203-184

Date Sampled: 03/27/2021 0807  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/01/2021 1806	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0900	
Lead	1.00 U	ug/L	1.00	1.00	1.0



Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** O/S 323 Boys BS 4  
**Lab Sample ID:** 420-194203-185

Date Sampled: 03/27/2021 0807  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/01/2021 1808	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0900	
Lead	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** O/S 319 BF  
**Lab Sample ID:** 420-194203-186

Date Sampled: 03/27/2021 0809  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/01/2021 1810	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0900	
Lead	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** O/S 317 Girls BS 1  
**Lab Sample ID:** 420-194203-187

Date Sampled: 03/27/2021 0809  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/01/2021 1812	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0900	
Lead	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** O/S 317 Girls BS 2  
**Lab Sample ID:** 420-194203-188

Date Sampled: 03/27/2021 0810  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/01/2021 1819	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0900	
Lead	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** O/S 317 Girls BS 3  
**Lab Sample ID:** 420-194203-189

Date Sampled: 03/27/2021 0810  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/01/2021 1821	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0900	
Lead	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** O/S 317 Girls BS 4  
**Lab Sample ID:** 420-194203-190

Date Sampled: 03/27/2021 0810  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/01/2021 1823	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0900	
Lead	1.05	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** 311 KS Prep  
**Lab Sample ID:** 420-194203-191

Date Sampled: 03/27/2021 0812  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/01/2021 1827	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0900	
Lead	5.08	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** 309 A CS  
**Lab Sample ID:** 420-194203-192

Date Sampled: 03/27/2021 0813  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/01/2021 1830	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0900	
Lead	1.20	ug/L	1.00	1.00	1.0



Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** O/S 300 BS  
**Lab Sample ID:** 420-194203-193

Date Sampled: 03/27/2021 0816  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/01/2021 1832	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0900	
Lead	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** 300 BF  
**Lab Sample ID:** 420-194203-194

Date Sampled: 03/27/2021 0816  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/01/2021 1834	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0900	
Lead	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** 300 BS  
**Lab Sample ID:** 420-194203-195

Date Sampled: 03/27/2021 0817  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/01/2021 1836	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0900	
Lead	2.14	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** Girls Locker Room BS 1  
**Lab Sample ID:** 420-194203-196

Date Sampled: 03/27/2021 0819  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/02/2021 1326	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0900	
Lead	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** Girls Locker Room BS 2  
**Lab Sample ID:** 420-194203-197

Date Sampled: 03/27/2021 0819  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/02/2021 1328	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0900	
Lead	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** Girls Coach BS  
**Lab Sample ID:** 420-194203-198

Date Sampled: 03/27/2021 0820  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/02/2021 1330	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0900	
Lead	4.57	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** Girls Gym BF  
**Lab Sample ID:** 420-194203-199

Date Sampled: 03/27/2021 0821  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/02/2021 1332	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0900	
Lead	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID: Welding Shop BS**  
**Lab Sample ID: 420-194203-200**

Date Sampled: 03/27/2021 0834  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/02/2021 1334	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0900	
Lead	1.00 U	ug/L	1.00	1.00	1.0



Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** Welding Shop BF  
**Lab Sample ID:** 420-194203-201

Date Sampled: 03/27/2021 0835  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/02/2021 1343	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0900	
Lead	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** Welding Shop Boys BS  
**Lab Sample ID:** 420-194203-202

Date Sampled: 03/27/2021 0837  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/02/2021 1350	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0900	
Lead	1.39	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** Welding Shop Girls BS  
**Lab Sample ID:** 420-194203-203

Date Sampled: 03/27/2021 0837  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/02/2021 1352	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0900	
Lead	26.8 g	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** AD Office BS  
**Lab Sample ID:** 420-194203-204

Date Sampled: 03/27/2021 0841  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/02/2021 1354	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0900	
Lead	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** Wood Shop Boys BS 1  
**Lab Sample ID:** 420-194203-205

Date Sampled: 03/27/2021 0848  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/02/2021 1356	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0900	
Lead	3.17	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** Wood Shop Boys BS 2  
**Lab Sample ID:** 420-194203-206

Date Sampled: 03/27/2021 0848  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/02/2021 1358	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0900	
Lead	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** Wood Shop Boys BS 3  
**Lab Sample ID:** 420-194203-207

Date Sampled: 03/27/2021 0849  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/02/2021 1401	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0900	
Lead	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** Wood Shop CS O/S BF  
**Lab Sample ID:** 420-194203-208

Date Sampled: 03/27/2021 0849  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/02/2021 1403	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0900	
Lead	1.00 U	ug/L	1.00	1.00	1.0



Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** Wood Shop BF  
**Lab Sample ID:** 420-194203-209

Date Sampled: 03/27/2021 0850  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/02/2021 1405	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0900	
Lead	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** Wood Shop Girls BS 1  
**Lab Sample ID:** 420-194203-210

Date Sampled: 03/27/2021 0852  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/02/2021 1407	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0900	
Lead	2.13	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** Wood Shop Girls BS 2  
**Lab Sample ID:** 420-194203-211

Date Sampled: 03/27/2021 0853  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/02/2021 1416	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0900	
Lead	2.63	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** Wood Shop CS 1  
**Lab Sample ID:** 420-194203-212

Date Sampled: 03/27/2021 0856  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/02/2021 1418	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0900	
Lead	1.74	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** Wood Shop CS 2  
**Lab Sample ID:** 420-194203-213

Date Sampled: 03/27/2021 0857  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/02/2021 1420	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0900	
Lead	11.1	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** Trainers Office Ice Machine  
**Lab Sample ID:** 420-194203-214

Date Sampled: 03/27/2021 0523  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/02/2021 1423	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0900	
Lead	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** 234 Ice Machine  
**Lab Sample ID:** 420-194203-215

Date Sampled: 03/27/2021 0556  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/02/2021 1425	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0900	
Lead	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** Health Office Ice Machine  
**Lab Sample ID:** 420-194203-216

Date Sampled: 03/27/2021 0600  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/02/2021 1427	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0900	
Lead	1.07	ug/L	1.00	1.00	1.0



Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-194203-1  
Sdg Number: Newburgh ECSD- NFA Main

**Client Sample ID:** AD Office Ice Machine  
**Lab Sample ID:** 420-194203-217

Date Sampled: 03/27/2021 0642  
Date Received: 04/01/2021 1120  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/02/2021 1429	
Prep Method: 200.7/200.8			Date Prepared:	04/27/2021 0900	
Lead	1.00 U	ug/L	1.00	1.00	1.0

## DATA REPORTING QUALIFIERS

Client: Orange-Ulster BOCES

Job Number:  
Sdg Number: Newburgh ECSD- NFA Main

<b>Lab Section</b>	<b>Qualifier</b>	<b>Description</b>
Metals	g	Result fails applicable NYS drinking water standards
	U	The analyte was analyzed for but not detected at or above the lowest stated limit.

## Certification Information

Client: Orange-Ulster BOCES

Job Number:

Sdg Number: Newburgh ECSD- NFA Main

---

### **The following analytes are Not Part of the ELAP scope of accreditation:**

Sulfur, Tungsten, Bicarbonate Alkalinity, 7 Day BOD 5210C, 28 Day BOD, Soluble BOD, Carbon Dioxide, Carbonate Alkalinity, CBOD Soluble, Chlorine, Cyanide (WAD), Ferrous Iron, Ferric Iron, Total Nitrogen, Total Organic Nitrogen, Dissolved Oxygen, pH, Solids (Fixed), Solids (Percent), Solids (Percent Moisture), Solids (Percent Volatile), Solids (Volatile Suspended), Temperature, TKN (Soluble), COD (Soluble), Total Inorganic Carbon, 2-Aminopyridine, 3-Picoline, 1-Methyl-2-pyrrilidinone, Aziridine, Dimethyl sulfoxide, 1-Chlorohexane, 1,2,4,5-Tetramethylbenzene, 4-Ethyl toluene, p-Diethylbenzene, Iron Bacteria, Salmonella, Sulfur Reducing Bacteria, & UOD (Ultimate Oxygen Demand).

### **The following analytes are Not Part of ELAP Potable Water scope of accreditation:**

Ammonia (SM 4500NH3G), Biochemical Oxygen Demand (SM 5210B), Chemical Oxygen Demand (EPA 410.4), Dissolved Oxygen (SM 4500 O C), TKN (351.2), Phosphorus (365.3), Nitrate-Nitrite (353.2), Setttable Solids (SM 2540F), Total Suspended Solids (SM 2540 C), m-Xylene & p-Xylene (502.2, 524), o-Xylene (502.2, 524), Sulfide (SM4500SD), Acenaphthene (525.2), Acenaphthylene (525.2), Fluoranthene (525.2), Fluorene (525.2), Phenanthrene (525.2), Anthracene (525.2), Pyrene (525.2), Benzo[a]anthracene (525.2), Benzo[b]fluoranthene (525.2), Benzo[g,h,i]perylene (525.2), Benzo[k]fluoranthene (525.2), Indeno[1,2,3-cd]pyrene (525.2), & Dibenz(a,h)anthracene (525.2). Pyridine

### **The following analytes are Not Part of ELAP Solid and Hazardous Waste scope of accreditation:**

Ammonia (SM 4500NH3G), TKN (351.2), Phosphorus (365.3), 1,2-Dichloro-1,1,2-trifluoroethane (8260), & Chlorodifluoromethane (8260).

### **The following analytes are Not Part of ELAP Non Potable Water scope of accreditation:**

Dissolved Organic Carbon (5310C), Mecoprop (8151A), MCPA (8151A).

## Definitions and Glossary

Client: Orange-Ulster BOCES

Job Number:

Sdg Number: Newburgh ECSD- NFA Main

---

<u>Abbreviation</u>	<u>These commonly used abbreviations may or may not be present in this report.</u>
%R	Percent Recovery
DL, RA, RE	Indicates a Dilution, Reanalysis or Reextraction.
EPA	United States Environmental Protection Agency
MDL	Method Detection Limit - an estimate of the minimum amount of a substance that an analytical process can reliably detect. A MDL is analyte- and matrix-specific and may be laboratory-dependent.
ND	Not detected at the reporting limit (or MDL if shown).
QC	Quality Control
RL	Reporting Limit - the minimum levels, concentrations, or quantities of a target variable (e.g., target analyte) that can be reported with a specified degree of confidence.
RPD	Relative Percent Difference - a measure of the relative difference between two points

<b>Client Information</b>		<b>Analysis Requested</b>		<b>Deliverable Type:</b> Level I, Level II, NYS ASP Cat B EDD (Specify):					
Client Contact: Kevin Flynn Phone: 845-781-4887 Email: joseph.russo@oubooces.org Halina.redner@oubooces.org Maureen.doherty@oubooces.org		Lab PM: Joseph Russo E-Mail: joseph.russo@oubooces.org Halina.redner@oubooces.org Maureen.doherty@oubooces.org		JOB #: 194203 1 & 15					
Company: Orange-Ulster BOCES Address: 53 Gibson Road City: Goshen State, Zip: NY, 10924 Phone: 845-781-4887 Email: joseph.russo@oubooces.org Halina.redner@oubooces.org Maureen.doherty@oubooces.org		Due Date Requested: Standard Turn-Around TAT Requested (days): PO #: 420-194203-B-1 PWS #: O/S 220 BF Project #: 420-1656401 Date Sampled: 3/27/2021		Preservation Codes: A - HCL B - NaOH C - Zn Acetate D - Nitric Acid E - H2SO4 F - NiOH G - NH4CL H - Ascorbic Acid I - Ice J - DI Water K - Sodium Phosphate L - EDTA M - Sodium Sulfite N - None O - MCAA P - Other (specify)					
Project Name: Newburgh ECSD NFA Main		Additional Contacts:		Other: <b>D-Nitric Acid</b> Upon Receipt Preservation verified: Y / N					
Sample Date	Sample Time	Sample Identification Client ID (Lab ID)	Matrix (DW=drinking water, W=water, S=solid, G=grab, O=wastewat)	Field Filtered Sample (Yes or No)	Perform MS/MSD (Yes or No)	Chlorine Present (Yes)	Lead	Total Number of Containers	Special Instructions/Note:
3/27/21	5:07	O/S 220 BF	G DW	X	X	X	1	1	
3/27/21	5:10	O/S 220 Girls BS 1	G DW	X	X	X	1	1	
3/27/21	5:10	O/S 220 Girls BS 2	G DW	X	X	X	1	1	
3/27/21	5:11	O/S 220 Girls BS 3	G DW	X	X	X	1	1	
3/27/21	5:11	O/S 220 Girls BS 4	G DW	X	X	X	1	1	
3/27/21	5:12	210 CS 1	G DW	X	X	X	1	1	
3/27/21	5:12	210 CS 2	G DW	X	X	X	1	1	
3/27/21	5:14	206 CS	G DW	X	X	X	1	1	
3/27/21	5:15	203 CS	G DW	X	X	X	1	1	
3/27/21	5:16	200 A CS 1	G DW	X	X	X	1	1	
3/27/21	5:16	O/S 200 C CS	G DW	X	X	X	1	1	
3/27/21	5:21	218 Office CS	G DW	X	X	X	1	1	
3/27/21	5:24	Trainers Office SS	G DW	X	X	X	1	1	
3/27/21	5:24	Trainers Office BS	G DW	X	X	X	1	1	
3/27/21	5:27	Pool Boys Locker Rm BS	G DW	X	X	X	1	1	
		Container Code: P=Plastic, A=Amber, V=Vial, G=Glass, B=Bacteria, C=Cube, O=Other, T=Terracore, D=BDD Bottle Preservation Added Upon Receipt:		Received by: <i>LL</i> Date/Time: 4/1/21 11:20 Company: OUBOCES					
		Relinquished by: <i>Maureen Doherty</i> Date/Time: 3/27/21 11:30 Company: OUBOCES		Received by: <i>LL</i> Date/Time: 4/1/21 11:20 Company: OUBOCES					
		Relinquished by:		Received by:					
		ICE Present: <i>NO</i> Custody Seal No.:		Cooler Temperature(s) °C/°F: <i>19.6°C</i>					

Chain of Custody Record

<b>Client Information</b> Company: Orange-Utster BOCES Address: 53 Gibson Road City: Goshen State/Zip: NY, 10924 Phone: 845-781-4887 Email: joseph.russo@ouboces.org Project Name: Newburgh ECSD NFA Main		Lab P/N: E-Mail: joseph.russo@ouboces.org Halima.rednet@ouboces.org Maureen.doherty@ouboces.org		Deliverable Type: Level I, Level II, NYS ASP Cat B EDD (Specify):		JOB #: 194203 2 of 15	
Due Date Requested: Standard Turn-Around TAT Requested (days):		PO #: PWS #: Project #: Additional Contacts:		Analysis Requested		Page: 1 of 1	
Sample Identification Client ID (Lab ID)		Matrix (DW= drinking water, W=water, S=solid, G=grab) Sample Type (C=comp, G=grab) Preservation Code:		Field Filtered Sample (Yes or No)		Perform MS/MSD (Yes or No)	
Chlorine Present (Yes or No)		Lead		Total Number of Containers		Special Instructions/Note:	
Sample Date Time		Sample Identification Client ID (Lab ID)		Matrix (DW= drinking water, W=water, S=solid, G=grab) Sample Type (C=comp, G=grab) Preservation Code:		Field Filtered Sample (Yes or No)	
Chlorine Present (Yes or No)		Lead		Total Number of Containers		Special Instructions/Note:	
3/27/21	5:26	Pool Boys Locker Rm BF	G	DW	1	1	
3/27/21	5:30	Pool BS 1	G	DW	1	1	
3/27/21	5:30	Pool BS 2	G	DW	1	1	
3/27/21	5:29	Pool Girls Locker Rm BF	G	DW	1	1	
3/27/21	5:31	Swim Instructor BF	G	DW	1	1	
3/27/21	5:32	Swim Coaches Office BS	G	DW	1	1	
3/27/21	5:34	Ticket Booth Mens BS 1	G	DW	1	1	
3/27/21	5:34	Ticket Booth Mens BS 2	G	DW	1	1	
3/27/21	5:35	Ticket Booth Mens BF	G	DW	1	1	
3/27/21	5:36	Ticket Booth Girls BS 1	G	DW	1	1	
3/27/21	5:37	Ticket Booth Girls BS 2	G	DW	1	1	
3/27/21	5:37	Ticket Booth Girls BS 3	G	DW	1	1	
3/27/21	5:38	Coaches Office BS	G	DW	1	1	
3/27/21	5:42	223 KS	G	DW	1	1	
3/27/21	5:43	223 Mens BS	G	DW	1	1	
Container Code: P=Plastic, A=Amber, V=Val, G=Glass, B=Bacteria, C=Cube, O=Other, T=Terrace, D=BOD Bottle Relinquished by: <i>[Signature]</i> Relinquished by:		Date/Time: 3/11/21 11:20 Date/Time:		Date/Time: 4/11/21 11:20 Date/Time:		Date/Time: <i>[Signature]</i> Date/Time:	
ICE Present: <input checked="" type="checkbox"/> Custody Seal No.:		Custody Seals Intact:		Cooler Temperature(s) °C/IR GUN #: 19.6-C		Company:	

**Chain of Custody Record**

<b>Client Information</b>		Sampler: J DeGraw Phone: 845-781-4887 E-Mail: joseph.russo@ouboces.org Halima.redner@ouboces.org Maureen.doherty@ouboces.org		Deliverable Type: Level I, Level II, NYS ASP Cat B EDD (Specify):		JOB #: 194203 3 of 15					
Company: Orange-Utster BOCES Address: 53 Gibson Road City: Goshen State/Zip: NY, 10924 Phone: 845-781-4887 PWS #: PO #: Email: joseph.russo@ouboces.org Halima.redner@ouboces.org Maureen.doherty@ouboces.org Project Name: Newburgh ECSD Additional Contacts: NFA Main		Due Date Requested: Standard Turn-Around TAT Requested (days): Matrix (DW= drinking water, W=water, S=solid, G=grab) Preservation Code: Sample Type (C=comp, G=grab) Field Filtered Sample (Yes or No) Perform MS/MSD (Yes or No) Chlorine Present (Yes or No) Lead		Analysis Requested		Preservation Codes: A - HCL B - NaOH C - Zn Acetate D - Nitric Acid E - H2SO4 F - MeOH G - NH4CL H - Ascorbic Acid I - Ice J - DI Water K - Sodium Thiosulfate Other: D-Nitric Acid Upon Receipt Preservation verified: Y / N					
Sample Date	Sample Time	Sample Identification	Client ID (Lab ID)	Matrix	Preservation Code	Field Filtered Sample (Yes or No)	Perform MS/MSD (Yes or No)	Chlorine Present (Yes or No)	Lead	Total Number of Containers	Special Instructions/Note
3/27/21	5:43	223 Womens BS		G	DW					1	
3/27/21	5:45	O/S 224 BF		G	DW					1	
3/27/21	5:45	O/S 224 BS 1		G	DW					1	
3/27/21	5:45	O/S 224 BS 2		G	DW					1	
3/27/21	5:46	O/S 224 BS 3		G	DW					1	
3/27/21	5:46	O/S 224 BS 4		G	DW					1	
3/27/21	5:48	258 BS		G	DW					1	
3/27/21	5:47	Slage Bathroom BS		G	DW					1	
3/27/21	5:51	O/S 232 BS		G	DW					1	
3/27/21	5:52	232 CS 1		G	DW					1	
3/27/21	5:52	232 CS 2		G	DW					1	
3/27/21	5:53	232 CS 3		G	DW					1	
3/27/21	5:54	234 CS 1		G	DW					1	
3/27/21	5:55	234 CS 2		G	DW					1	
3/27/21	5:57	Health Office BS 1		G	DW					1	
Container Code: P=Plastic, A=Amber, V=Vial, G=Glass, B=Bacteria, C=Cube, O=Other, T=Terracore, D=BOD Bottle Preservation Code: A=Amber, V=Vial, G=Glass, B=Bacteria, C=Cube, O=Other, T=Terracore, D=BOD Bottle Relinquished by: <i>[Signature]</i> Date: 3/11/21 11:20 Relinquished by: Date: 3/11/21 11:20 Relinquished by: Date: 3/11/21 11:20 ICE Present: <input checked="" type="checkbox"/> Custody Seal No.: <input checked="" type="checkbox"/> Custody Seals Intact: <input checked="" type="checkbox"/> Cooler Temperature(s) °C/IR GUN #: 19.6 °C Received by: <i>[Signature]</i> Date/Time: 3/11/21 11:20 Company: OUBOCES Received by: Date/Time: Company: Received by: Date/Time: Company:											

**Chain of Custody Record**

<b>Client Information</b> Client Contact: Kevin Flynn Phone: 845-761-4887		Lab PIV: E-Mail: joseph.russo@oubooces.org Halina.redner@oubooces.org Maureen.doherty@oubooces.org		Deliverable Type: Level I, Level II, NYS ASP Cat B EDD (Specify):		JOB #: 194203 4 & 15			
Company: Orange-Ulster BOCES Address: 53 Gibson Road City: Goshen State, Zip: NY, 10924 Phone: 845-761-4887		Due Date Requested: Standard Turn-Around TAT Requested (days):		Analysis Requested		Preservation Codes: A - HCL B - NaOH C - Zn Acetate D - Nitric Acid E - H2SO4 F - MeOH G - NH4CL H - Ascorbic Acid I - Ice J - DI Water K - Sodium Thiosulfate L - EDA M - Sodium Sulfite N - None O - MCAA P - Other (specify)			
PO #: 845-761-4887 PWS #: Halina.redner@oubooces.org Project #: Maureen.doherty@oubooces.org Additional Contacts: Newburgh ECSD NFA Main		Matrix (DW= drinking water, W=water, G=grab) Preservation Code:		Field Filtered Sample (Yes or No)		Perform M/MSD (Yes or No)			
Sample Identification Client ID (Lab ID)		Sample Type (C=comp, G=grab)		Chlorine Present (Yes or No)		Total Number of Containers			
Sample Date	Sample Time	Sample Identification	Sample Type	Chlorine Present	Perform M/MSD	Field Filtered Sample	Matrix	Preservation Code	Special Instructions/Note
3/27/21	5:59	Health Office BS 2	G	1	1	1	DW	G	
3/27/21	6:00	Health Office BS 3	G	1	1	1	DW	G	
3/27/21	6:00	Health Office BS 4	G	1	1	1	DW	G	
3/27/21	6:01	Health Office O/S Ice Machine	G	1	1	1	DW	G	
3/27/21	6:03	O/S 243 BF	G	1	1	1	DW	G	
3/27/21	6:04	O/S 243 Boys BS 1	G	1	1	1	DW	G	
3/27/21	6:04	O/S 243 Boys BS 2	G	1	1	1	DW	G	
3/27/21	6:05	O/S 243 Boys BS 3	G	1	1	1	DW	G	
3/27/21	6:05	O/S 243 Boys BS 4	G	1	1	1	DW	G	
3/27/21	6:06	O/S 243 Boys BS 5	G	1	1	1	DW	G	
3/27/21	6:07	O/S 243 Girls BS 1	G	1	1	1	DW	G	
3/27/21	6:07	O/S 243 Girls BS 2	G	1	1	1	DW	G	
3/27/21	6:08	O/S 243 Girls BS 3	G	1	1	1	DW	G	
3/27/21	6:08	O/S 243 Girls BS 4	G	1	1	1	DW	G	
3/27/21	6:08	O/S 243 Girls BS 5	G	1	1	1	DW	G	
Container Code: P=Plastic, A=Amber, V=Vial, G=Glass, B=Bacteria, C=Cube, O=Other, T=Terracore, D=BOD Bottle Preservation Added Upon Receipt:		Date/Time: 3/11/21 11:20 Date/Time:		Date/Time: 4/11/21 11:20 Date/Time:		Date/Time: Date/Time:		Container Type	
Relinquished by: [Signature]		Relinquished by:		Relinquished by:		Relinquished by:		Relinquished by:	
ICE Present: <input checked="" type="checkbox"/>		Custody Seal No.:		Custody Seals Intact: <input checked="" type="checkbox"/>		Cooler Temperature(s) °C/IR GUN #: 19.6 °C		Company: OUBOCES Company: ETC	



**Chain of Custody Record**

<b>Client Information</b>		<b>Sampler:</b> J DeGraw <b>Phone:</b> 845-781-4887		<b>Deliverable Type:</b> Level I, Level II, NYS ASP Cat B EDD (Specify):		<b>JOB #:</b>  1947035615	
<b>Client Contact:</b> Kevin Flynn		<b>E-Mail:</b> joseph.russo@oubooces.org Halima.redner@oubooces.org Maureen.doherty@oubooces.org					
<b>Company:</b> Orange-Utster BOCES		<b>Due Date Requested:</b> Standard Turn-Around		<b>Analysis Requested</b>		<b>Preservation Codes:</b>	
<b>Address:</b> 53 Gibson Road <b>City:</b> Goshen <b>State, Zip:</b> NY, 10924 <b>Phone:</b> 845-781-4887 <b>Email:</b> joseph.russo@oubooces.org Halima.redner@oubooces.org Maureen.doherty@oubooces.org		<b>TAT Requested (days):</b>					
<b>Project Name:</b> Newburgh ECSD NFA Main		<b>Project #:</b>		<b>Field Filtered Sample (Yes or No)</b>		<b>Chlorine Present (Yes or No)</b>	
<b>Additional Contacts:</b>		<b>Additional Contacts:</b>					
				<b>Form MS/MSD (Yes or No)</b>		<b>Lead</b>	
				<b>Matrix (DW= drinking water, W=water, S=solid, O=waste/oil, G=grab)</b>		<b>Sample Type (C=comp, G=grab)</b>	
				<b>Preservation Code</b>		<b>Special Instructions/Note:</b>	
				<b>Sample Identification Client ID (Lab ID)</b>		<b>Total Number of Containers</b>	
Sample Date	Sample Time			G	DW	1	
3/27/21	6:10	248 KS					
3/27/21	6:11	252 KS					
3/27/21	6:12	O/S 257 BF					
3/27/21	6:13	254 KS 1					
3/27/21	6:14	254 KS 3					
3/27/21	6:16	O/S 254 Mens BS					
3/27/21	6:17	O/S 254 Womens BS					
3/27/21	6:17	O/S 275 BF					
3/27/21	6:19	270 KS					
3/27/21	6:20	288 KS					
3/27/21	6:21	246 KS 1					
3/27/21	6:22	246 KS 3					
3/27/21	6:23	O/S 265 BF					
3/27/21	6:24	264 KS					
3/27/21	6:25	263 KS					
				P			<b>Container Type</b>
						<b>Upon Receipt Preservation verified:</b> Y / N	
						<b>Other:</b> D-Nitric Acid	
						<b>Preservation Codes:</b> A - HCL B - NaOH C - Zn Acetate D - Nitric Acid E - H2SO4 F - MeOH G - NH4CL H - Ascorbic Acid I - Ice J - DI Water K - Sodium Thioculfate L - EDA M - Sodium Sulfite N - None O - MCAA P - Other (specify)	
						<b>Page:</b> Page 1 of 1	
						<b>Received by:</b> Date/Time: 4/11/21 11:20 Company: OUBOCES	
						<b>Received by:</b> Date/Time: 4/11/21 11:20 Company: OUBOCES	
						<b>Received by:</b> Date/Time: 4/11/21 11:20 Company: OUBOCES	
						<b>ICE Present:</b> <input checked="" type="checkbox"/> <b>Custody Seal No.:</b> 19467	

Chain of Custody Record

<b>Client Information</b> Client Contact: Kevin Flynn Phone: 845-781-4887 E-Mail: Joseph.russo@ouboces.org Halima.redner@ouboces.org Maureen.doherty@ouboces.org		Deliverable Type: Level I, Level II, NYS ASP, Cat B EDD (Specify):	
Company: Orange-Utster BOCES Address: 53 Gibson Road City: Goshen State, Zip: NY, 10924 Phone: 845-781-4887 Email: Joseph.russo@ouboces.org Halima.redner@ouboces.org Maureen.doherty@ouboces.org Project Name: Newburgh ECSD NFA Main		Lab PIV: J DeGraw Phone: 845-781-4887 E-Mail: Joseph.russo@ouboces.org Halima.redner@ouboces.org Maureen.doherty@ouboces.org	
Due Date Requested: Standard Turn-Around TAT Requested (days):		Analysis Requested	
PO #: 845-781-4887 PWS #: Halima.redner@ouboces.org Project #: Maureen.doherty@ouboces.org Additional Contacts:		Chlorine Present (Yes or No) <input checked="" type="checkbox"/> No Perform MS/MSD (Yes or No) <input checked="" type="checkbox"/> No Field Filtered Sample (Yes or No) <input checked="" type="checkbox"/> No Lead <input checked="" type="checkbox"/> No	
Sample Identification Client ID (Lab ID)		Total Number of Containers	
Sample Date 3/27/21	Sample Time 6:26	Matrix (DW=drinking water, W=water, G=grab, O=waste/soil, Preservation Code: G)	O/S 239 BF
3/27/21	6:27	G	237 CS
3/27/21	6:28	G	239 KS
3/27/21	6:29	G	239 BF
3/27/21	6:29	G	O/S 238 BF
3/27/21	6:30	G	240 B BS
3/27/21	6:34	G	Boys Locker East BS 1
3/27/21	6:34	G	Boys Locker East BS 2
3/27/21	6:35	G	Boys Locker Coaches BS
3/27/21	6:35	G	Boys Lockere Coaches Locker BS
3/27/21	6:39	G	New Locker Room BS 1
3/27/21	6:39	G	New Locker Room BS 2
3/27/21	6:40	G	New Locker Room BS 3
3/27/21	6:45	G	O/S 345 Womens BS
3/27/21	6:46	G	O/S 345 Mens BS
Container Code: P=Plastic, A=Amber, V=Vial, G=Glass, B=Bacteria, C=Cube, O=Other, T=Terracore, D=BOD Bottle Preservation Added Upon Receipt:		Container Type	
Relinquished by: <i>Kevin Flynn</i> Date/Time: 3/27/21 11:20		Received by: <i>Kevin Flynn</i> Date/Time: 3/27/21 11:00	
Relinquished by:		Received by:	
ICF Present: <input checked="" type="checkbox"/> Yes		Cooler Temperature(s) °C/IR GUN #:	

JOB #:  
194203 6815

Page: Page 1 of 1

- Preservation Codes:
- A - HCL
  - B - NaOH
  - C - Zn Acetate
  - D - Nitric Acid
  - E - H2SO4
  - F - MeOH
  - G - NH4CL
  - H - Ascorbic Acid
  - I - Ice
  - J - DI Water
  - K - Sodium Thiosulfate
  - Other: D-Nitric Acid
- Upon Receipt Preservation verified: Y / N

Chain of Custody Record



Client Information		Lab PVI:		Deliverable Type:							
Company: Orange-Ulster BOCES Address: 53 Gibson Road City: Goshen State, Zip: NY, 10924 Phone: 845-781-4887 Email: joseph.russo@oubooces.org Project Name: Newburgh ECSD NFA Main		Sampler: J DeGraw Phone: 845-781-4887 E-Mail: joseph.russo@oubooces.org Halina.redner@oubooces.org Maureen.doherty@oubooces.org		Level I, Level II, NYS ASP Cat B EDD (Specify):							
Due Date Requested: Standard Turn-Around TAT Requested (days):		Analysis Requested		Page: 1 of 1 JOB #: 194203 7 of 15							
Sample Date	Sample Time	Sample Identification	Client ID (Lab ID)	Matrix (DW= drinking water, W=water, G=grab)	Preservation Code	Field Filtered Sample (Yes or No)	Perform MS/MSD (Yes or No)	Chlorine Present (Yes or No)	Lead	Total Number of Containers	Special Instructions/Note:
3/27/21	6:46	O/S 346 BF		G	DW				D	1	D-Nitric Acid Upon Receipt Preservation verified: Y / N
3/27/21	6:46	O/S 346 Girls BS 1		G	DW					1	
3/27/21	6:46	O/S 346 Girls BS 2		G	DW					1	
3/27/21	6:47	O/S 346 Girls BS 3		G	DW					1	
3/27/21	6:49	336 Office KS		G	DW					1	
3/27/21	6:47	O/S 346 Boys BS 1		G	DW					1	
3/27/21	6:47	O/S 346 Boys BS 2		G	DW					1	
3/27/21	6:48	O/S 346 Boys BS 3		G	DW					1	
3/27/21	6:53	278 KS		G	DW					1	
3/27/21	6:52	O/S 286 Womens BS		G	DW					1	
3/27/21	6:53	O/S 286 Mens BS		G	DW					1	
3/27/21	6:54	O/S 288 BF		G	DW					1	
3/27/21	6:54	O/S 288 Girls BS 1		G	DW					1	
3/27/21	6:54	O/S 288 Girls BS 2		G	DW					1	
3/27/21	6:55	O/S 288 Girls BS 3		G	DW					1	

Chain of Custody Record



<b>Client Information</b> Company: Orange-Ulster BOCES Address: 53 Gibson Road City: Goshen State, Zip: NY, 10924 Phone: 845-781-4887 Email: Joseph.russo@oubooces.org Project Name: Newburgh ECSD Additional Contacts: NFA Main		Due Date Requested: Standard Turn-Around TAT Requested (days):		Deliverable Type: Level I, Level II, NYS ASP Cat B EDD (Specify):						
Client Contact: Kevin Flynn		Sampler: J DeGraw Phone: 845-781-4887		Lab PM: E-Mail: Joseph.russo@oubooces.org Halina.reidner@oubooces.org Maureen.doherty@oubooces.org						
Job #: 194703 8 & 15		Page: Page 1 of 1								
Analysis Requested										
Preservation Codes: A - HCL B - NaOH C - Zn Acetate D - Nitric Acid E - H2SO4 F - MeOH G - NH4CL H - Ascorbic Acid I - Ice J - DI Water K - Sodium Thiosulfate L - EDA M - Sodium Sulfite N - None O - MCAA P - Other (Specify)										
Other: D-Nitric Acid Upon Receipt Preservation verified: Y / N										
Total Number of containers										
Sample Date	Sample Time	Sample Identification	Client ID (Lab ID)	Matrix (DW=drinking water, W=water, S=solid, O=waste/oil)	Sample Type (C=comp, G=grab)	Field Filtered Sample (Yes or No)	Perform MS/MSD (Yes or No)	Chlorine Present (Yes or No)	Lead	Special Instructions/Note:
3/27/21	6:56	O/S 288 Boys BS 1		DW	G					
3/27/21	6:56	O/S 288 Boys BS 2		DW	G					
3/27/21	6:57	O/S 288 Boys BS 3		DW	G					
3/27/21	6:59	O/S 145 Womens BS		DW	G					
3/27/21	6:59	O/S 145 Mens BS		DW	G					
3/27/21	7:00	O/S 147 BF		DW	G					
3/27/21	7:01	O/S 147 Womens BS 1		DW	G					
3/27/21	7:02	O/S 147 Womens BS 2		DW	G					
3/27/21	7:02	O/S 147 Womens BS 3		DW	G					
3/27/21	7:04	O/S 147 Mens BS 1		DW	G					
3/27/21	7:04	O/S 147 Mens BS 2		DW	G					
3/27/21	7:05	O/S 147 Mens BS 3		DW	G					
3/27/21	7:06	139 CS		DW	G					
3/27/21	7:08	110 Dressing BS		DW	G					
3/27/21	7:09	110 BS		DW	G					
Container Code: P=Plastic, A=Amber, V=Vial, G=Glass, B=Bacteria, C=Cube, O=Other, T=Terracore, D=BOD Bottle Preservation: Addled Linnon Recalnt										
Relinquished by: <i>[Signature]</i> Date: 3/1/21 11:20										
Relinquished by: <i>[Signature]</i> Date: 3/1/21 11:20										
Relinquished by: <i>[Signature]</i> Date: 3/1/21 11:20										
ICE Present: <input checked="" type="checkbox"/> Custody Seal No.: 1111										

**Chain of Custody Record**

JOB #:  
**194703**  
**9 of 15**

Deliverable Type:  
 Level I, Level II,  
 NYS ASP Cat B  
 EDD (Specify):

Lab PM:  
 E-Mail:  
 joseph.russo@oubooces.org  
 Halina.redner@oubooces.org  
 Maureen.doherty@oubooces.org

Client Information  
 Client Contact:  
 Kevin Flynn  
 Phone: 845-781-4887

Company:  
 Orange-Ulster BOCES  
 Address:  
 53 Gibson Road  
 City:  
 Goshen  
 State, Zip:  
 NY, 10924  
 Phone:  
 845-781-4887  
 PWS #:  
 Project #:  
 Additional Contacts:

Sample Date	Sample Time	Sample Identification	Client ID (Lab ID)	Matrix (DW= drinking water, W=water, S=solid, G=grab)	Sample Type (C=Comp, G=grab)	Field Filtered Sample (Yes or No)	Perform MS/MSD (Yes or No)	Chlorine Present (Yes or No)	Lead	Total Number of Containers	Special Instructions/Note:
3/27/21	7:11	108 Dressing BS		DW	G					1	
3/27/21	7:12	108 BS		DW	G					1	
3/27/21	7:12	109 BS 1		DW	G					1	
3/27/21	7:12	109 BS 2		DW	G					1	
3/27/21	7:12	109 BS 3		DW	G					1	
3/27/21	7:13	109 BS 4		DW	G					1	
3/27/21	7:13	109 BS 5		DW	G					1	
3/27/21	7:13	109 BS 6		DW	G					1	
3/27/21	7:16	O/S 105 BF		DW	G					1	
3/27/21	7:16	107 A KS		DW	G					1	
3/27/21	7:18	O/S 106 BS		DW	G					1	
3/27/21	7:19	104 CS		DW	G					1	
3/27/21	7:19	103 CS		DW	G					1	
3/27/21	7:20	Café A Boys BS		DW	G					1	
3/27/21	7:21	Café A Girls BS		DW	G					1	

Page: Page 1 of 1

Preservation Codes:  
 A - HCL  
 B - NaOH  
 C - Zn Acetate  
 D - Nitric Acid  
 E - H2SO4  
 F - MeOH  
 G - NH4CL  
 H - Ascorbic Acid  
 I - Ice  
 J - DI Water  
 K - Sodium Thiosulfate  
 L - FDA  
 M - Sodium Sulfite  
 N - None  
 O - MCAA  
 P - Other (specify)

Other:  
**D-Nitric Acid**  
 Upon Receipt Preservation verified:  
 Y / N

Analysis Requested

Container Code: P=Plastic, A=Amber, V=Vial, G=Glass, B=Bacteria, C=Cube, O=Other, T=Terracore, D=BOD Bottle  
 Preservation Added Upon Receipt:

Relinquished by: *[Signature]*  
 Relinquished by:

Received by: *[Signature]*  
 Received by:

Received by: *[Signature]*  
 Received by:

Received by: *[Signature]*  
 Received by:

ICE Present:  Custody Seal No.: *1716*

Manufacturer of #1 Date: *3/17/21 11:20*

Manufacturer of #2 Date: *4/1/21 11:20*

Manufacturer of #3 Date: *4/1/21 11:20*

Company: OUBOCES  
 Company: OUBOCES  
 Company: OUBOCES

Container Type

<b>Client Information</b> Client Contact: Kevin Flynn Phone: 845-781-4887 E-Mail: joseph.russo@oubooces.org Halina.redner@oubooces.org Maureen.doherty@oubooces.org		Deliverable Type: Level I, Level II, NYS ASP Cat B EDD (Specify):		JOB #: 194203 10 & 15					
Company: Orange-Ulster BOCES Address: 53 Gibson Road City: Goshen State, Zip: NY, 10924 Phone: 845-781-4887 PWS #: _____ Project #: _____ Additional Contacts: _____		Due Date Requested: Standard Turn-Around TAT Requested (days): _____ PO #: _____ PWS #: _____ Project #: _____ Additional Contacts: _____		Lab P.M.: _____ E-Mail: joseph.russo@oubooces.org Halina.redner@oubooces.org Maureen.doherty@oubooces.org					
Sample Identification Client ID (Lab ID)		Matrix (DW= drinking water, W=water, S=solid, O=wastewater, G=grab)		Preservation Code:					
Sample Date	Sample Time	Sample Type (G=grab)	Field Filled Sample (Yes or No)	Perform MS/MSD (Yes or No)	Chlorine Present (Yes or No)	Lead	Total Number of Containers	Special Instructions/Note:	
3/27/21	7:22	Café A Kitchen BS	X	X	X	D	1		
3/27/21	7:23	Café A KS 1	X	X	X	1	1		
3/27/21	7:24	Café A KS 2	X	X	X	1	1		
3/27/21	7:24	Café A KS 3	X	X	X	1	1		
3/27/21	7:24	Café A KS 4	X	X	X	1	1		
3/27/21	7:25	Café A KS 5	X	X	X	1	1		
3/27/21	7:26	Café A BF	X	X	X	1	1		
3/27/21	7:29	O/S Café C BF	X	X	X	1	1		
3/27/21	7:31	O/S Café C Boys BS 1	X	X	X	1	1		
3/27/21	7:33	O/S Café C Boys BS 2	X	X	X	1	1		
3/27/21	7:34	O/S Café C Boys BS 3	X	X	X	1	1		
3/27/21	7:34	O/S Café C Boys BS 4	X	X	X	1	1		
3/27/21	7:35	O/S Café C Boys BS 5	X	X	X	1	1		
3/27/21	7:35	O/S Café C Boys BS 6	X	X	X	1	1		
3/27/21	7:35	O/S Café C Womens BS	X	X	X	1	1		
Container Code: P=Plastic, A=Amber, V=Vial, G=Glass, B=Bacteria, C=Cups, O=Other, T=Terracore, D=BOD Bottle Preservation Added Upon Receipt:		Date/Time: 3/11/21 11:20 Date/Time:		Date/Time: 4/11/21 11:20 Date/Time:		Date/Time:		Date/Time:	
Relinquished by: <i>[Signature]</i>		Relinquished by:		Relinquished by:		Relinquished by:		Relinquished by:	
ICE Present: YU		Custody Seal No.:		Custody Seals Intact:		Cooler Temperature(s) °C/IR GUN #:		Container Type:	

**Chain of Custody Record**

Sample Date	Sample Time	Sample Identification	Client ID (Lab ID)	Matrix (DW= drinking water, W=water, S=solid, O=waste/oil)	Sample Type (C=Comp, G=grab)	Preservation Code	Field Filtered Sample (Yes or No)	Perform MS/MSD (Yes or No)	Chlorine Present (Yes or No)	Lead	Analysis Requested	Deliverable Type: Level I, Level II, NYS ASP Cat B EDD (Specify):	Lab Pk:	Sampler: J DeGraw Phone: 845-781-4887	Due Date Requested: Standard Turn-Around TAT Requested (days):	Company: Orange-Ulster BOCES Address: 53 Gibson Road City: Goshen State, Zip: NY, 10924 Phone: 845-781-4887 Email: joseph.russo@oubooces.org Maureen.doherty@oubooces.org Project Name: Newburgh ECSD NFA Main	Job #:
3/27/21	7:36	O/S Café C Mens BS		G	DW		X	X	X	D		Level I, Level II, NYS ASP Cat B EDD (Specify):	194203 1A of 15				
3/27/21	7:37	O/S Café C Girls BS 1		G	DW		X	X	X	D							
3/27/21	7:37	O/S Café C Girls BS 2		G	DW		X	X	X	D							
3/27/21	7:37	O/S Café C Girls BS 3		G	DW		X	X	X	D							
3/27/21	7:38	O/S Café C Girls BS 4		G	DW		X	X	X	D							
3/27/21	7:38	O/S Café C Girls BS 5		G	DW		X	X	X	D							
3/27/21	7:40	113 KS		G	DW		X	X	X	D							
3/27/21	7:41	120 KS		G	DW		X	X	X	D							
3/27/21	7:42	O/S 120 BF		G	DW		X	X	X	D							
3/27/21	7:42	Café B BF		G	DW		X	X	X	D							
3/27/21	7:45	Main Dish Room KS 1		G	DW		X	X	X	D							
3/27/21	7:45	Main Dish Room KS 2		G	DW		X	X	X	D							
3/27/21	7:46	Main Dish Room KS 3		G	DW		X	X	X	D							
3/27/21	7:47	Café B Serving Line KS		G	DW		X	X	X	D							
3/27/21	7:47	Main Kitchen Kitcher Prep Sink		G	DW		X	X	X	D							

  

Container Code: P=Plastic, A=Amber, V=Vial, G=Glass, B=Bacteria, C=Cube, O=Other, T=Terracore, D=BOD Bottle	Manufacturer #:	Date:
Preservation Added: Linon Baccant:	54124	11:20
Relinquished by: <i>[Signature]</i>	Date/Time:	Received by: <i>[Signature]</i>
Relinquished by:	Date/Time:	Received by:
Relinquished by:	Date/Time:	Received by:

  

ICE Present: <input checked="" type="checkbox"/>	Custody Seal No.:	1910
--	-------------------	------

Chain of Custody Record



Sample Date	Sample Time	Sample Identification Client ID (Lab ID)	Matrix (DW= drinking water, W=water, S=solid, O=waste/oil)	Sample Type (C=Comp, G=Grab)	Preservation Code	Field Filtered Sample (Yes or No)	Perform MS/MSD (Yes or No)	Chlorine Present (Yes or No)	Lead	Total Number of Containers	Special Instructions/Note:
3/27/21	7:49	O/S 113 KS 1	DW	G	DW					1	
3/27/21	7:50	O/S 113 KS 2	DW	G	DW					1	
3/27/21	7:50	O/S 113 KS 3	DW	G	DW					1	
3/27/21	7:51	Café C Serving Line KS 1	DW	G	DW					1	
3/27/21	7:52	Café C Serving Line KS 2	DW	G	DW					1	
3/27/21	7:52	Café C Serving Line KS 3	DW	G	DW					1	
3/27/21	7:53	Main Kitchen KF	DW	G	DW					1	
3/27/21	7:55	O/S 133 BF	DW	G	DW					1	
3/27/21	7:56	131 KS	DW	G	DW					1	
3/27/21	7:56	129 KS	DW	G	DW					1	
3/27/21	7:57	128 KS	DW	G	DW					1	
3/27/21	7:58	127KS	DW	G	DW					1	
3/27/21	7:59	O/S 126 BF	DW	G	DW					1	
3/27/21	8:03	O/S Stairs 7 BS 1	DW	G	DW					1	
3/27/21	8:03	O/S Stairs 7 BS 2	DW	G	DW					1	
<p>Container Code: P=Plastic, A=Amber, V=Vial, G=Glass, B=Bacteria, C=Cube, O=Other, T=Terrace, D=BOD Bottle                      Relinquished by: <u>Maureen Doherty</u> Date: <u>3/11/21 11:20</u>                      Relinquished by: <u>KA</u> Date: <u>3/11/21 11:20</u>                      Relinquished by: _____ Date: _____                      Relinquished by: _____ Date: _____</p>											
<p>ICE Present: <input checked="" type="checkbox"/> Custody Seal No.: _____ Custody Seals Intact: <input checked="" type="checkbox"/> Cooler Temperature(s) °C/IR SUN#: <u>1100</u></p>											

JOB #: 144203  
12 & 15

Deliverable Type: Level I, Level II, NYS ASP Cal B EDD (Specify):  
 Lab P/N:  
 E-Mail: joseph.russo@oubooces.org  
 Halina.redner@oubooces.org  
 Maureen.doherty@oubooces.org

Page: Page 1 of 1

Analysis Requested

- Preservation Codes:
- A - HCL
  - B - NaOH
  - C - Zn Acetate
  - D - Nitric Acid
  - E - H2SO4
  - F - MeOH
  - G - NH4CL
  - H - Ascorbic Acid
  - I - Ice
  - J - DI Water
  - K - Sodium Thiosulfate
  - L - EDA
  - M - Sodium Sulfite
  - N - None
  - O - MCAA
  - P - Other (specify)

Other: D-Nitric Acid  
 Upon Receipt Preservation verified: Y / N

Company: Orange-Ulster BOCES  
 Address: 53 Gibson Road  
 City: Goshen  
 State, Zip: NY, 10924  
 Phone: 845-781-4887  
 Email: joseph.russo@oubooces.org  
 Halina.redner@oubooces.org  
 Maureen.doherty@oubooces.org  
 Project Name: Newburgh ECSD  
 NFA Main

Due Date Requested:  
 Standard Turn-Around TAT Requested (days):  
 PO #:  
 PWS #:  
 Project #:  
 Additional Contacts:



**Chain of Custody Record**



<b>Client Information</b> Client Contact: Kevin Flynn Phone: 845-781-4887 E-Mail: joseph.russo@oubores.org Halina.redner@oubores.org Maureen.doherty@oubores.org		Deliverable Type: Level I, Level II, NYS ASP Cat B EDD (Specify):		JOB #: 14240 194703 13 & 15					
Company: Orange-Ulster BOCES Address: 53 Gibson Road City: Goshen State, Zip: NY, 10924 Phone: 845-781-4887 Email: joseph.russo@oubores.org Halina.redner@oubores.org Maureen.doherty@oubores.org		Lab PIN: J DeGraw E-Mail: joseph.russo@oubores.org Halina.redner@oubores.org Maureen.doherty@oubores.org		Page: 1 of 1					
Due Date Requested: Standard Turn-Around TAT Requested (days):		Analysis Requested							
PO #: PWS #: Project #: Additional Contacts:		Preservation Codes: A - HCL B - NaOH C - Zn Acetate D - Nitric Acid E - H2SO4 F - NaOH G - NH4CL H - Acetic Acid I - Ice J - DI Water K - Sodium Thiostulfate L - EDA M - Sodium Sulfite N - None O - NCA P - Other (specify)							
Sample Identification Client ID (Lab ID)		Other: D-Nitric Acid Upon Receipt Preservation verified: Y / N							
Sample Date 3/27/21	Sample Time 8:05	Matrix (DW=drinking water, W=water, S=solid, O=wastewater) Sample Type (C=comp, G=grab) G DW	Field Filtered Sample (Yes or No)	Perform MS/MSD (Yes or No)	Chlorine Present (Yes or No)	Lead	Total Number of Containers	Special Instructions/Note:	
3/27/21	8:05	O/S 324 BF					1		
3/27/21	8:06	O/S 323 Boys BS 1					1		
3/27/21	8:06	O/S 323 Boys BS 2					1		
3/27/21	8:07	O/S 323 Boys BS 3					1		
3/27/21	8:07	O/S 323 Boys BS 4					1		
3/27/21	8:09	O/S 319 BF					1		
3/27/21	8:09	O/S 317 Girls BS 1					1		
3/27/21	8:10	O/S 317 Girls BS 2					1		
3/27/21	8:10	O/S 317 Girls BS 3					1		
3/27/21	8:10	O/S 317 Girls BS 4					1		
3/27/21	8:12	311 KS Prep					1		
3/27/21	8:13	309 A CS					1		
3/27/21	8:16	O/S 300 BS					1		
3/27/21	8:16	300 BF					1		
3/27/21	8:17	300 BS					1		
Container Code: P=Plastic, A=Amber, V=Vial, G=Glass, B=Bacteria, C=Cube, O=Other, T=Terracore, D=BOD Bottle		Preservation Added Linn Receipt:			Date/Time: 3/27/21 11:20			Date/Time: 3/27/21 11:20	
Relinquished by: <i>[Signature]</i>		Relinquished by:			Date/Time:			Date/Time:	
Relinquished by:		Relinquished by:			Date/Time:			Date/Time:	
ICE Present: <input checked="" type="checkbox"/>		Custody Seal Intact: <input checked="" type="checkbox"/>			Cooler Temperature (°C) / °F: 19.1 / 66.4			Company: ETC	

Chain of Custody Record

Client Information		Lab FMI:		Deliverable Type:								
Company: Orange-Ulster BOCES Address: 53 Gibson Road City: Goshen State, Zip: NY, 10924 Phone: 845-781-4887 Email: joseph.russo@oubooces.org Halina.redner@oubooces.org Maureen.doherty@oubooces.org Project Name: Newburgh ECSD Additional Contacts: NFA Main		Sampler: J DeGraw Phone: 845-781-4887 E-Mail: joseph.russo@oubooces.org Halina.redner@oubooces.org Maureen.doherty@oubooces.org		Level I, Level II, NYS ASP Cat B EDD (Specify):								
Sample Date	Sample Time	Sample Identification	Client ID (Lab ID)	Matrix (DW=drinking water, W=water, S=solid, O=waste/soil)	Sample Type (C=Comp, G=grab)	Field Filled Sample (Yes or No)	Perform MS/MSD (Yes or No)	Chlorine Present (Yes or No)	Lead	Analysis Requested	Preservation Codes:	Page: 1 of 1
3/27/21	8:19	Girls Locker Room BS 1			G	DW					A - HCL B - NaOH C - Zn Acetate D - Nitric Acid E - H2SO4 F - NaOH G - NH4CL H - Ascorbic Acid I - Ice J - DI Water K - Sodium Thiosulfate Other: <b>D-Nitric Acid</b> Upon Receipt Preservation verified: Y / N	
3/27/21	8:19	Girls Locker Room BS 2			G	DW					L - EDA M - Sodium Sulfite N - None O - MCAA P - Other (specify)	
3/27/21	8:20	Girls Coach BS			G	DW						
3/27/21	8:21	Girls Gym BF			G	DW						
3/27/21	8:34	Welding Shop BS			G	DW						
3/27/21	8:35	Welding Shop BF			G	DW						
3/27/21	8:37	Welding Shop Boys BS			G	DW						
3/27/21	8:37	Welding Shop Girls BS			G	DW						
3/27/21	8:41	AD Office BS			G	DW						
3/27/21	8:48	Wood Shop Boys BS 1			G	DW						
3/27/21	8:48	Wood Shop Boys BS 2			G	DW						
3/27/21	8:49	Wood Shop Boys BS 3			G	DW						
3/27/21	8:49	Wood Shop CS O/S BF			G	DW						
3/27/21	8:50	Wood Shop BF			G	DW						
3/27/21	8:52	Wood Shop Girls BS 1			G	DW						
Container Code: P=Plastic, A=Amber, V=Vial, G=Glass, B=Bacteria, C=Cube, O=Other, T=Terracore, D=BOD Bottle Preservation Added Upon Receipt Relinquished by: <i>[Signature]</i> Relinquished by:												
Sample # (S)		Date/Time	Company	Received by:		Date/Time	Company	Sample # (S)		Date/Time	Company	
1170		4/1/21 11:20	OUBOCES	[Signature]		4/1/21 11:20	OUBOCES	1170		4/1/21 11:20	OUBOCES	
1170		4/1/21 11:20	OUBOCES	[Signature]		4/1/21 11:20	OUBOCES	1170		4/1/21 11:20	OUBOCES	
1170		4/1/21 11:20	OUBOCES	[Signature]		4/1/21 11:20	OUBOCES	1170		4/1/21 11:20	OUBOCES	
ICE Present <input checked="" type="checkbox"/>		Custody Seal No.:	Custody Seals Intact: <input checked="" type="checkbox"/>		Cooler Temperature (°C) / IR GUN #: 14.6							



## LOGIN SAMPLE RECEIPT CHECK LIST

Client: Orange-Ulster BOCES

Job Number: 420-194203-1  
SDG Number: Newburgh ECSD- NFA Main

**Login Number: 194203**

Question	T/F/NA	Comment
Samples were collected by ETL employee as per SOP-SAM-1	NA	
The cooler's custody seal, if present, is intact.	NA	
The cooler or samples do not appear to have been compromised or tampered with.	True	
Samples were received on ice.	False	
Cooler Temperature is recorded.	True	19.6 C
Cooler Temp. is within method specified range.(0-6 C PW, 0-8 C NPW, or BAC <10 C	False	
If false, was sample received on ice within 6 hours of collection.	False	
Based on above criteria cooler temperature is acceptable.	True	Method does not require cooling
COC is present.	True	
COC is filled out in ink and legible.	True	
COC is filled out with all pertinent information.	True	
There are no discrepancies between the sample IDs on the containers and the COC.	True	
Samples are received within Holding Time.	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
Appropriate sample containers are used.	True	
Sample bottles are completely filled.	True	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
VOA sample vials do not have headspace or bubble is <6mm (1/4") in diameter.	NA	
If necessary, staff have been informed of any short hold time or quick TAT needs	True	
Multiphasic samples are not present.	True	
Samples do not require splitting or compositing.	True	