

## ANALYTICAL REPORT

Job Number: 420-195784-1

SDG Number: Newburgh ECSD NFA North

Job Description: Orange-Ulster BOCES

For:  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Attention: Jack DeGraw



---

Designee for  
Meredith W Ruthven  
Customer Service Manager  
mruthven@envirotestlaboratories.com  
06/27/2021

NYSDOH ELAP does not certify for all parameters. EnviroTest Laboratories does hold certification for all analytes where certification is offered by ELAP unless otherwise specified in the Certification Information section of this report. Pursuant to NELAP, this report may not be reproduced, except in full, without written approval of the laboratory. EnviroTest Laboratories LLC certifies that the analytical results contained herein apply only to the samples tested as received by our laboratory. All questions regarding this report should be directed to the EnviroTest Customer Service Representative. All services performed by EnviroTest Laboratories LLC are subject to our Terms and Conditions available at [Envirotestlabs/terms.com](http://Envirotestlabs/terms.com). As of 12/23/19, EnviroTest Laboratories LLC acquired substantially all of the lab and testing assets of EnviroTest Laboratories Inc, including its name.

EnviroTest Laboratories, LLC. Certifications and Approvals: NYSDOH 10142, NJDEP NY015, CTDOH PH-0554

## METHOD SUMMARY

Client: Orange-Ulster BOCES

Job Number: 420-195784-1  
SDG Number: Newburgh ECSD NFA North

<b>Description</b>	<b>Lab Location</b>	<b>Method</b>	<b>Preparation Method</b>
<b>Matrix: Water</b>			
ICPMS Metals by 200.8	EnvTest	EPA 200.8 Rev.5.4	
200 Series Drinking Water Prep Determination Step	EnvTest		EPA 200.7/200.8

### Lab References:

EnvTest = EnviroTest

### Method References:

EPA = US Environmental Protection Agency

## METHOD / ANALYST SUMMARY

Client: Orange-Ulster BOCES

Job Number: 420-195784-1  
SDG Number: Newburgh ECSD NFA North

<b>Method</b>	<b>Analyst</b>	<b>Analyst ID</b>
EPA 200.8 Rev.5.4	Luis, Carlos	CL

## SAMPLE SUMMARY

Client: Orange-Ulster BOCES

Job Number: 420-195784-1  
SDG Number: Newburgh ECSD NFA North

Lab Sample ID	Client Sample ID	Client Matrix	Date/Time Sampled	Date/Time Received
420-195784-1	North Cafe BF	Drinking Water	04/20/2021 0407	04/22/2021 0911
420-195784-2	Kitchen HS	Drinking Water	04/20/2021 0408	04/22/2021 0911
420-195784-3	Kitchen KS #1	Drinking Water	04/20/2021 0410	04/22/2021 0911
420-195784-4	Kitchen KS #2	Drinking Water	04/20/2021 0411	04/22/2021 0911
420-195784-5	Kitchen KS #3	Drinking Water	04/20/2021 0412	04/22/2021 0911
420-195784-6	Kitchen KS #4	Drinking Water	04/20/2021 0412	04/22/2021 0911
420-195784-7	Kitchen KS #5	Drinking Water	04/20/2021 0412	04/22/2021 0911
420-195784-8	Kitchen KS #6	Drinking Water	04/20/2021 0413	04/22/2021 0911
420-195784-9	Kitchen KS #7	Drinking Water	04/20/2021 0413	04/22/2021 0911
420-195784-10	Kitchen KF	Drinking Water	04/20/2021 0415	04/22/2021 0911
420-195784-11	South Cafe BF	Drinking Water	04/20/2021 0420	04/22/2021 0911
420-195784-12	South Cafe Boys BS #1	Drinking Water	04/20/2021 0421	04/22/2021 0911
420-195784-13	South Cafe Boys BS #2	Drinking Water	04/20/2021 0421	04/22/2021 0911
420-195784-14	South Cafe Girls BS #1	Drinking Water	04/20/2021 0422	04/22/2021 0911
420-195784-15	South Cafe Girls BS #2	Drinking Water	04/20/2021 0422	04/22/2021 0911
420-195784-16	Locker Room Boys BS	Drinking Water	04/20/2021 0424	04/22/2021 0911
420-195784-17	Locker Room Boys BS #1	Drinking Water	04/20/2021 0425	04/22/2021 0911
420-195784-18	Locker Room Boys BS #2	Drinking Water	04/20/2021 0425	04/22/2021 0911
420-195784-19	Locker Room Girls BS	Drinking Water	04/20/2021 0428	04/22/2021 0911
420-195784-20	Locker Room Girls BS #1	Drinking Water	04/20/2021 0429	04/22/2021 0911
420-195784-21	Locker Room Girls BS #2	Drinking Water	04/20/2021 0429	04/22/2021 0911
420-195784-22	Coaches BS	Drinking Water	04/20/2021 0430	04/22/2021 0911
420-195784-23	Locker Room BF	Drinking Water	04/20/2021 0430	04/22/2021 0911
420-195784-24	Gym BF	Drinking Water	04/20/2021 0433	04/22/2021 0911
420-195784-25	1st Floor Girls BS #1	Drinking Water	04/20/2021 0435	04/22/2021 0911
420-195784-26	1st Floor Girls BS #2	Drinking Water	04/20/2021 0436	04/22/2021 0911
420-195784-27	1st Floor Girls BS #3	Drinking Water	04/20/2021 0436	04/22/2021 0911
420-195784-28	1st Floor Boys BS #1	Drinking Water	04/20/2021 0437	04/22/2021 0911
420-195784-29	1st Floor Boys BS #2	Drinking Water	04/20/2021 0437	04/22/2021 0911
420-195784-30	1st Floor Staff BS #1	Drinking Water	04/20/2021 0439	04/22/2021 0911
420-195784-31	O/S 113 BF	Drinking Water	04/20/2021 0440	04/22/2021 0911
420-195784-32	103 CS	Drinking Water	04/20/2021 0442	04/22/2021 0911
420-195784-33	Wood Shop SS	Drinking Water	04/20/2021 0443	04/22/2021 0911
420-195784-34	125 BS	Drinking Water	04/20/2021 0444	04/22/2021 0911
420-195784-35	100 BS	Drinking Water	04/20/2021 0445	04/22/2021 0911
420-195784-36	100 CS #1	Drinking Water	04/20/2021 0446	04/22/2021 0911
420-195784-37	100 CS #2	Drinking Water	04/20/2021 0446	04/22/2021 0911
420-195784-38	O/S P Tech BS #1	Drinking Water	04/20/2021 0448	04/22/2021 0911
420-195784-39	O/S P Tech BS #2	Drinking Water	04/20/2021 0448	04/22/2021 0911
420-195784-40	202 SS #1	Drinking Water	04/20/2021 0456	04/22/2021 0911
420-195784-41	202 SS #2	Drinking Water	04/20/2021 0456	04/22/2021 0911
420-195784-42	North Girls BS #1	Drinking Water	04/20/2021 0457	04/22/2021 0911
420-195784-43	North Girls BS #2	Drinking Water	04/20/2021 0458	04/22/2021 0911
420-195784-44	North Girls BS #3	Drinking Water	04/20/2021 0458	04/22/2021 0911
420-195784-45	210 B HS #1	Drinking Water	04/20/2021 0459	04/22/2021 0911
420-195784-46	210 B HS #2	Drinking Water	04/20/2021 0500	04/22/2021 0911

## SAMPLE SUMMARY

Client: Orange-Ulster BOCES

Job Number: 420-195784-1  
SDG Number: Newburgh ECSD NFA North

Lab Sample ID	Client Sample ID	Client Matrix	Date/Time Sampled	Date/Time Received
420-195784-47	201 A HS #1	Drinking Water	04/20/2021 0501	04/22/2021 0911
420-195784-48	201 A HS #2	Drinking Water	04/20/2021 0501	04/22/2021 0911
420-195784-49	201 A BS	Drinking Water	04/20/2021 0502	04/22/2021 0911
420-195784-50	O/S 210 BS #1	Drinking Water	04/20/2021 0504	04/22/2021 0911
420-195784-51	O/S 210 BS #2	Drinking Water	04/20/2021 0504	04/22/2021 0911
420-195784-52	O/S 210 BF	Drinking Water	04/20/2021 0505	04/22/2021 0911
420-195784-53	O/S Security BS #2	Drinking Water	04/20/2021 0506	04/22/2021 0911
420-195784-54	O/S Security BS #1	Drinking Water	04/20/2021 0506	04/22/2021 0911
420-195784-55	212 CS	Drinking Water	04/20/2021 0508	04/22/2021 0911
420-195784-56	216 BS	Drinking Water	04/20/2021 0509	04/22/2021 0911
420-195784-57	Library Office BS	Drinking Water	04/20/2021 0510	04/22/2021 0911
420-195784-58	O/S 219 BF	Drinking Water	04/20/2021 0512	04/22/2021 0911
420-195784-59	O/S 225 BS	Drinking Water	04/20/2021 0513	04/22/2021 0911
420-195784-60	225 CS #1	Drinking Water	04/20/2021 0514	04/22/2021 0911
420-195784-61	225 CS #2A	Drinking Water	04/20/2021 0514	04/22/2021 0911
420-195784-62	225 CS #3	Drinking Water	04/20/2021 0515	04/22/2021 0911
420-195784-63	225 CS #2	Drinking Water	04/20/2021 0516	04/22/2021 0911
420-195784-64	O/S 310 BF	Drinking Water	04/20/2021 0519	04/22/2021 0911
420-195784-65	O/S 310 BS	Drinking Water	04/20/2021 0520	04/22/2021 0911
420-195784-66	Nurse BS	Drinking Water	04/20/2021 0521	04/22/2021 0911
420-195784-67	Nurse HS	Drinking Water	04/20/2021 0522	04/22/2021 0911
420-195784-68	O/S Health BS	Drinking Water	04/20/2021 0524	04/22/2021 0911
420-195784-69	O/S Main Office BS	Drinking Water	04/20/2021 0526	04/22/2021 0911
420-195784-70	Main Office BS	Drinking Water	04/20/2021 0527	04/22/2021 0911
420-195784-71	O/S 303 BF	Drinking Water	04/20/2021 0529	04/22/2021 0911
420-195784-72	O/S 303 BS #1	Drinking Water	04/20/2021 0530	04/22/2021 0911
420-195784-73	O/S 303 BS #2	Drinking Water	04/20/2021 0530	04/22/2021 0911
420-195784-74	O/S 402 BF	Drinking Water	04/20/2021 0532	04/22/2021 0911
420-195784-75	O/S 405 BS #1	Drinking Water	04/20/2021 0532	04/22/2021 0911
420-195784-76	O/S 405 BS #2	Drinking Water	04/20/2021 0533	04/22/2021 0911
420-195784-77	O/S 411 BS #1	Drinking Water	04/20/2021 0534	04/22/2021 0911
420-195784-78	O/S 411 BS #2	Drinking Water	04/20/2021 0534	04/22/2021 0911
420-195784-79	O/S 411 BF	Drinking Water	04/20/2021 0535	04/22/2021 0911
420-195784-80	Kitchen Ice	Drinking Water	04/20/2021 0418	04/22/2021 0911

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195784-1  
Sdg Number: Newburgh ECSD NFA North

**Client Sample ID:** North Cafe BF  
**Lab Sample ID:** 420-195784-1

Date Sampled: 04/20/2021 0407  
Date Received: 04/22/2021 0911  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 06/23/2021 0447		
Prep Method: 200.7/200.8			Date Prepared: 06/21/2021 1700		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195784-1  
Sdg Number: Newburgh ECSD NFA North

**Client Sample ID:** Kitchen HS  
**Lab Sample ID:** 420-195784-2

Date Sampled: 04/20/2021 0408  
Date Received: 04/22/2021 0911  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/23/2021 0454	
Prep Method: 200.7/200.8			Date Prepared:	06/21/2021 1700	
Pb	11.0	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195784-1  
Sdg Number: Newburgh ECSD NFA North

**Client Sample ID:** Kitchen KS #1  
**Lab Sample ID:** 420-195784-3

Date Sampled: 04/20/2021 0410  
Date Received: 04/22/2021 0911  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/23/2021 0456	
Prep Method: 200.7/200.8			Date Prepared:	06/21/2021 1700	
Pb	11.5	ug/L	1.00	1.00	1.0



Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195784-1  
Sdg Number: Newburgh ECSD NFA North

**Client Sample ID:** Kitchen KS #2  
**Lab Sample ID:** 420-195784-4

Date Sampled: 04/20/2021 0411  
Date Received: 04/22/2021 0911  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/23/2021 0458	
Prep Method: 200.7/200.8			Date Prepared:	06/21/2021 1700	
Pb	8.56	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195784-1  
Sdg Number: Newburgh ECSD NFA North

**Client Sample ID:** Kitchen KS #3  
**Lab Sample ID:** 420-195784-5

Date Sampled: 04/20/2021 0412  
Date Received: 04/22/2021 0911  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/23/2021 0500	
Prep Method: 200.7/200.8			Date Prepared:	06/21/2021 1700	
Pb	13.8	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195784-1  
Sdg Number: Newburgh ECSD NFA North

**Client Sample ID:** Kitchen KS #4  
**Lab Sample ID:** 420-195784-6

Date Sampled: 04/20/2021 0412  
Date Received: 04/22/2021 0911  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/23/2021 0503	
Prep Method: 200.7/200.8			Date Prepared:	06/21/2021 1700	
Pb	12.1	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195784-1  
Sdg Number: Newburgh ECSD NFA North

**Client Sample ID:** Kitchen KS #5  
**Lab Sample ID:** 420-195784-7

Date Sampled: 04/20/2021 0412  
Date Received: 04/22/2021 0911  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/23/2021 0505	
Prep Method: 200.7/200.8			Date Prepared:	06/21/2021 1700	
Pb	11.0	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195784-1  
Sdg Number: Newburgh ECSD NFA North

**Client Sample ID:** Kitchen KS #6  
**Lab Sample ID:** 420-195784-8

Date Sampled: 04/20/2021 0413  
Date Received: 04/22/2021 0911  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/23/2021 0507	
Prep Method: 200.7/200.8			Date Prepared:	06/21/2021 1700	
Pb	4.34	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195784-1  
Sdg Number: Newburgh ECSD NFA North

**Client Sample ID:** Kitchen KS #7  
**Lab Sample ID:** 420-195784-9

Date Sampled: 04/20/2021 0413  
Date Received: 04/22/2021 0911  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/23/2021 0509	
Prep Method: 200.7/200.8			Date Prepared:	06/21/2021 1700	
Pb	3.88	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195784-1  
Sdg Number: Newburgh ECSD NFA North

**Client Sample ID:** Kitchen KF  
**Lab Sample ID:** 420-195784-10

Date Sampled: 04/20/2021 0415  
Date Received: 04/22/2021 0911  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/23/2021 0511	
Prep Method: 200.7/200.8			Date Prepared:	06/21/2021 1700	
Pb	11.7	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195784-1  
Sdg Number: Newburgh ECSD NFA North

**Client Sample ID:** South Cafe BF  
**Lab Sample ID:** 420-195784-11

Date Sampled: 04/20/2021 0420  
Date Received: 04/22/2021 0911  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 06/23/2021 0525		
Prep Method: 200.7/200.8			Date Prepared: 06/21/2021 1700		
Pb	1.00 U	ug/L	1.00	1.00	1.0



Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195784-1  
Sdg Number: Newburgh ECSD NFA North

**Client Sample ID:** South Cafe Boys BS #1  
**Lab Sample ID:** 420-195784-12

Date Sampled: 04/20/2021 0421  
Date Received: 04/22/2021 0911  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/23/2021 0527	
Prep Method: 200.7/200.8			Date Prepared:	06/21/2021 1700	
Pb	2.41	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195784-1  
Sdg Number: Newburgh ECSD NFA North

**Client Sample ID:** South Cafe Boys BS #2  
**Lab Sample ID:** 420-195784-13

Date Sampled: 04/20/2021 0421  
Date Received: 04/22/2021 0911  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/23/2021 0529	
Prep Method: 200.7/200.8			Date Prepared:	06/21/2021 1700	
Pb	1.60	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195784-1  
Sdg Number: Newburgh ECSD NFA North

**Client Sample ID:** South Cafe Girls BS #1  
**Lab Sample ID:** 420-195784-14

Date Sampled: 04/20/2021 0422  
Date Received: 04/22/2021 0911  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/23/2021 0531	
Prep Method: 200.7/200.8			Date Prepared:	06/21/2021 1700	
Pb	1.92	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195784-1  
Sdg Number: Newburgh ECSD NFA North

**Client Sample ID:** South Cafe Girls BS #2  
**Lab Sample ID:** 420-195784-15

Date Sampled: 04/20/2021 0422  
Date Received: 04/22/2021 0911  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/23/2021 0533	
Prep Method: 200.7/200.8			Date Prepared:	06/21/2021 1700	
Pb	6.02	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195784-1  
Sdg Number: Newburgh ECSD NFA North

**Client Sample ID:** Locker Room Boys BS  
**Lab Sample ID:** 420-195784-16

Date Sampled: 04/20/2021 0424  
Date Received: 04/22/2021 0911  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/23/2021 0535	
Prep Method: 200.7/200.8			Date Prepared:	06/21/2021 1700	
Pb	2.19	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195784-1  
Sdg Number: Newburgh ECSD NFA North

**Client Sample ID:** Locker Room Boys BS #1  
**Lab Sample ID:** 420-195784-17

Date Sampled: 04/20/2021 0425  
Date Received: 04/22/2021 0911  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/23/2021 0538	
Prep Method: 200.7/200.8			Date Prepared:	06/21/2021 1700	
Pb	14.8	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195784-1  
Sdg Number: Newburgh ECSD NFA North

**Client Sample ID:** Locker Room Boys BS #2  
**Lab Sample ID:** 420-195784-18

Date Sampled: 04/20/2021 0425  
Date Received: 04/22/2021 0911  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/23/2021 0540	
Prep Method: 200.7/200.8			Date Prepared:	06/21/2021 1700	
Pb	1.86	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195784-1  
Sdg Number: Newburgh ECSD NFA North

**Client Sample ID:** Locker Room Girls BS  
**Lab Sample ID:** 420-195784-19

Date Sampled: 04/20/2021 0428  
Date Received: 04/22/2021 0911  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/23/2021 0546	
Prep Method: 200.7/200.8			Date Prepared:	06/21/2021 1700	
Pb	1.36	ug/L	1.00	1.00	1.0



Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195784-1  
Sdg Number: Newburgh ECSD NFA North

**Client Sample ID:** Locker Room Girls BS #1  
**Lab Sample ID:** 420-195784-20

Date Sampled: 04/20/2021 0429  
Date Received: 04/22/2021 0911  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/23/2021 0549	
Prep Method: 200.7/200.8			Date Prepared:	06/21/2021 1700	
Pb	5.76	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195784-1  
Sdg Number: Newburgh ECSD NFA North

**Client Sample ID:** Locker Room Girls BS #2  
**Lab Sample ID:** 420-195784-21

Date Sampled: 04/20/2021 0429  
Date Received: 04/22/2021 0911  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/23/2021 0553	
Prep Method: 200.7/200.8			Date Prepared:	06/21/2021 1700	
Pb	22.2 g	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195784-1  
Sdg Number: Newburgh ECSD NFA North

**Client Sample ID:** Coaches BS  
**Lab Sample ID:** 420-195784-22

Date Sampled: 04/20/2021 0430  
Date Received: 04/22/2021 0911  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/23/2021 0555	
Prep Method: 200.7/200.8			Date Prepared:	06/21/2021 1700	
Pb	4.47	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195784-1  
Sdg Number: Newburgh ECSD NFA North

**Client Sample ID:** Locker Room BF  
**Lab Sample ID:** 420-195784-23

Date Sampled: 04/20/2021 0430  
Date Received: 04/22/2021 0911  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/23/2021 0557	
Prep Method: 200.7/200.8			Date Prepared:	06/21/2021 1700	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195784-1  
Sdg Number: Newburgh ECSD NFA North

**Client Sample ID:** Gym BF  
**Lab Sample ID:** 420-195784-24

Date Sampled: 04/20/2021 0433  
Date Received: 04/22/2021 0911  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/23/2021 0600	
Prep Method: 200.7/200.8			Date Prepared:	06/21/2021 1700	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195784-1  
Sdg Number: Newburgh ECSD NFA North

**Client Sample ID:** 1st Floor Girls BS #1  
**Lab Sample ID:** 420-195784-25

Date Sampled: 04/20/2021 0435  
Date Received: 04/22/2021 0911  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/23/2021 0602	
Prep Method: 200.7/200.8			Date Prepared:	06/21/2021 1700	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195784-1  
Sdg Number: Newburgh ECSD NFA North

**Client Sample ID:** 1st Floor Girls BS #2  
**Lab Sample ID:** 420-195784-26

Date Sampled: 04/20/2021 0436  
Date Received: 04/22/2021 0911  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/23/2021 0604	
Prep Method: 200.7/200.8			Date Prepared:	06/21/2021 1700	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195784-1  
Sdg Number: Newburgh ECSD NFA North

**Client Sample ID:** 1st Floor Girls BS #3  
**Lab Sample ID:** 420-195784-27

Date Sampled: 04/20/2021 0436  
Date Received: 04/22/2021 0911  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/23/2021 0606	
Prep Method: 200.7/200.8			Date Prepared:	06/21/2021 1700	
Pb	1.00 U	ug/L	1.00	1.00	1.0



Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195784-1  
Sdg Number: Newburgh ECSD NFA North

**Client Sample ID:** 1st Floor Boys BS #1  
**Lab Sample ID:** 420-195784-28

Date Sampled: 04/20/2021 0437  
Date Received: 04/22/2021 0911  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/23/2021 0613	
Prep Method: 200.7/200.8			Date Prepared:	06/21/2021 1700	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195784-1  
Sdg Number: Newburgh ECSD NFA North

**Client Sample ID:** 1st Floor Boys BS #2  
**Lab Sample ID:** 420-195784-29

Date Sampled: 04/20/2021 0437  
Date Received: 04/22/2021 0911  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/23/2021 0615	
Prep Method: 200.7/200.8			Date Prepared:	06/21/2021 1700	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195784-1  
Sdg Number: Newburgh ECSD NFA North

**Client Sample ID:** 1st Floor Staff BS #1  
**Lab Sample ID:** 420-195784-30

Date Sampled: 04/20/2021 0439  
Date Received: 04/22/2021 0911  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/23/2021 0617	
Prep Method: 200.7/200.8			Date Prepared:	06/21/2021 1700	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195784-1  
Sdg Number: Newburgh ECSD NFA North

**Client Sample ID:** O/S 113 BF  
**Lab Sample ID:** 420-195784-31

Date Sampled: 04/20/2021 0440  
Date Received: 04/22/2021 0911  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/23/2021 0626	
Prep Method: 200.7/200.8			Date Prepared:	06/21/2021 1700	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195784-1  
Sdg Number: Newburgh ECSD NFA North

**Client Sample ID:** 103 CS  
**Lab Sample ID:** 420-195784-32

Date Sampled: 04/20/2021 0442  
Date Received: 04/22/2021 0911  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/23/2021 0628	
Prep Method: 200.7/200.8			Date Prepared:	06/21/2021 1700	
Pb	3.64	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195784-1  
Sdg Number: Newburgh ECSD NFA North

**Client Sample ID: Wood Shop SS**  
**Lab Sample ID: 420-195784-33**

Date Sampled: 04/20/2021 0443  
Date Received: 04/22/2021 0911  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/23/2021 0630	
Prep Method: 200.7/200.8			Date Prepared:	06/21/2021 1700	
Pb	2.64	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195784-1  
Sdg Number: Newburgh ECSD NFA North

**Client Sample ID:** 125 BS  
**Lab Sample ID:** 420-195784-34

Date Sampled: 04/20/2021 0444  
Date Received: 04/22/2021 0911  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/23/2021 0632	
Prep Method: 200.7/200.8			Date Prepared:	06/21/2021 1700	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195784-1  
Sdg Number: Newburgh ECSD NFA North

**Client Sample ID:** 100 BS  
**Lab Sample ID:** 420-195784-35

Date Sampled: 04/20/2021 0445  
Date Received: 04/22/2021 0911  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/23/2021 0639	
Prep Method: 200.7/200.8			Date Prepared:	06/21/2021 1700	
Pb	1.00 U	ug/L	1.00	1.00	1.0



Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195784-1  
Sdg Number: Newburgh ECSD NFA North

**Client Sample ID:** 100 CS #1  
**Lab Sample ID:** 420-195784-36

Date Sampled: 04/20/2021 0446  
Date Received: 04/22/2021 0911  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/23/2021 0641	
Prep Method: 200.7/200.8			Date Prepared:	06/21/2021 1700	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195784-1  
Sdg Number: Newburgh ECSD NFA North

**Client Sample ID:** 100 CS #2  
**Lab Sample ID:** 420-195784-37

Date Sampled: 04/20/2021 0446  
Date Received: 04/22/2021 0911  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/23/2021 0643	
Prep Method: 200.7/200.8			Date Prepared:	06/21/2021 1700	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195784-1  
Sdg Number: Newburgh ECSD NFA North

**Client Sample ID:** O/S P Tech BS #1  
**Lab Sample ID:** 420-195784-38

Date Sampled: 04/20/2021 0448  
Date Received: 04/22/2021 0911  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/23/2021 0645	
Prep Method: 200.7/200.8			Date Prepared:	06/21/2021 1700	
Pb	4.95	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195784-1  
Sdg Number: Newburgh ECSD NFA North

**Client Sample ID:** O/S P Tech BS #2  
**Lab Sample ID:** 420-195784-39

Date Sampled: 04/20/2021 0448  
Date Received: 04/22/2021 0911  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/23/2021 0648	
Prep Method: 200.7/200.8			Date Prepared:	06/21/2021 1700	
Pb	4.97	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195784-1  
Sdg Number: Newburgh ECSD NFA North

**Client Sample ID:** 202 SS #1  
**Lab Sample ID:** 420-195784-40

Date Sampled: 04/20/2021 0456  
Date Received: 04/22/2021 0911  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/23/2021 0656	
Prep Method: 200.7/200.8			Date Prepared:	06/21/2021 1700	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195784-1  
Sdg Number: Newburgh ECSD NFA North

**Client Sample ID:** 202 SS #2  
**Lab Sample ID:** 420-195784-41

Date Sampled: 04/20/2021 0456  
Date Received: 04/22/2021 0911  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/23/2021 0659	
Prep Method: 200.7/200.8			Date Prepared:	06/21/2021 1700	
Pb	6.04	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195784-1  
Sdg Number: Newburgh ECSD NFA North

**Client Sample ID:** North Girls BS #1  
**Lab Sample ID:** 420-195784-42

Date Sampled: 04/20/2021 0457  
Date Received: 04/22/2021 0911  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/23/2021 0705	
Prep Method: 200.7/200.8			Date Prepared:	06/21/2021 1700	
Pb	35.4 g	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195784-1  
Sdg Number: Newburgh ECSD NFA North

**Client Sample ID:** North Girls BS #2  
**Lab Sample ID:** 420-195784-43

Date Sampled: 04/20/2021 0458  
Date Received: 04/22/2021 0911  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/23/2021 0707	
Prep Method: 200.7/200.8			Date Prepared:	06/21/2021 1700	
Pb	8.91	ug/L	1.00	1.00	1.0



Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195784-1  
Sdg Number: Newburgh ECSD NFA North

**Client Sample ID:** North Girls BS #3  
**Lab Sample ID:** 420-195784-44

Date Sampled: 04/20/2021 0458  
Date Received: 04/22/2021 0911  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/23/2021 0710	
Prep Method: 200.7/200.8			Date Prepared:	06/21/2021 1700	
Pb	32.8 g	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195784-1  
Sdg Number: Newburgh ECSD NFA North

**Client Sample ID:** 210 B HS #1  
**Lab Sample ID:** 420-195784-45

Date Sampled: 04/20/2021 0459  
Date Received: 04/22/2021 0911  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/23/2021 0712	
Prep Method: 200.7/200.8			Date Prepared:	06/21/2021 1700	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195784-1  
Sdg Number: Newburgh ECSD NFA North

**Client Sample ID:** 210 B HS #2  
**Lab Sample ID:** 420-195784-46

Date Sampled: 04/20/2021 0500  
Date Received: 04/22/2021 0911  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/23/2021 0714	
Prep Method: 200.7/200.8			Date Prepared:	06/21/2021 1700	
Pb	1.22	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195784-1  
Sdg Number: Newburgh ECSD NFA North

**Client Sample ID:** 201 A HS #1  
**Lab Sample ID:** 420-195784-47

Date Sampled: 04/20/2021 0501  
Date Received: 04/22/2021 0911  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/23/2021 0716	
Prep Method: 200.7/200.8			Date Prepared:	06/21/2021 1700	
Pb	7.32	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195784-1  
Sdg Number: Newburgh ECSD NFA North

**Client Sample ID:** 201 A HS #2  
**Lab Sample ID:** 420-195784-48

Date Sampled: 04/20/2021 0501  
Date Received: 04/22/2021 0911  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/23/2021 0718	
Prep Method: 200.7/200.8			Date Prepared:	06/21/2021 1700	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195784-1  
Sdg Number: Newburgh ECSD NFA North

**Client Sample ID:** 201 A BS  
**Lab Sample ID:** 420-195784-49

Date Sampled: 04/20/2021 0502  
Date Received: 04/22/2021 0911  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/23/2021 0720	
Prep Method: 200.7/200.8			Date Prepared:	06/21/2021 1700	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195784-1  
Sdg Number: Newburgh ECSD NFA North

**Client Sample ID:** O/S 210 BS #1  
**Lab Sample ID:** 420-195784-50

Date Sampled: 04/20/2021 0504  
Date Received: 04/22/2021 0911  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/23/2021 0725	
Prep Method: 200.7/200.8			Date Prepared:	06/21/2021 1700	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195784-1  
Sdg Number: Newburgh ECSD NFA North

**Client Sample ID:** O/S 210 BS #2  
**Lab Sample ID:** 420-195784-51

Date Sampled: 04/20/2021 0504  
Date Received: 04/22/2021 0911  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 06/23/2021 0731		
Prep Method: 200.7/200.8			Date Prepared: 06/21/2021 1700		
Pb	1.00 U	ug/L	1.00	1.00	1.0



Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195784-1  
Sdg Number: Newburgh ECSD NFA North

**Client Sample ID:** O/S 210 BF  
**Lab Sample ID:** 420-195784-52

Date Sampled: 04/20/2021 0505  
Date Received: 04/22/2021 0911  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/23/2021 0734	
Prep Method: 200.7/200.8			Date Prepared:	06/21/2021 1700	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195784-1  
Sdg Number: Newburgh ECSD NFA North

**Client Sample ID:** O/S Security BS #2  
**Lab Sample ID:** 420-195784-53

Date Sampled: 04/20/2021 0506  
Date Received: 04/22/2021 0911  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/23/2021 0736	
Prep Method: 200.7/200.8			Date Prepared:	06/21/2021 1700	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195784-1  
Sdg Number: Newburgh ECSD NFA North

**Client Sample ID:** O/S Security BS #1  
**Lab Sample ID:** 420-195784-54

Date Sampled: 04/20/2021 0506  
Date Received: 04/22/2021 0911  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 06/23/2021 0738		
Prep Method: 200.7/200.8			Date Prepared: 06/21/2021 1700		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195784-1  
Sdg Number: Newburgh ECSD NFA North

**Client Sample ID:** 212 CS  
**Lab Sample ID:** 420-195784-55

Date Sampled: 04/20/2021 0508  
Date Received: 04/22/2021 0911  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/23/2021 0740	
Prep Method: 200.7/200.8			Date Prepared:	06/21/2021 1700	
Pb	2.51	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195784-1  
Sdg Number: Newburgh ECSD NFA North

**Client Sample ID:** 216 BS  
**Lab Sample ID:** 420-195784-56

Date Sampled: 04/20/2021 0509  
Date Received: 04/22/2021 0911  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/23/2021 0742	
Prep Method: 200.7/200.8			Date Prepared:	06/21/2021 1700	
Pb	14.6	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195784-1  
Sdg Number: Newburgh ECSD NFA North

**Client Sample ID:** Library Office BS  
**Lab Sample ID:** 420-195784-57

Date Sampled: 04/20/2021 0510  
Date Received: 04/22/2021 0911  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/23/2021 0744	
Prep Method: 200.7/200.8			Date Prepared:	06/21/2021 1700	
Pb	2.05	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195784-1  
Sdg Number: Newburgh ECSD NFA North

**Client Sample ID:** O/S 219 BF  
**Lab Sample ID:** 420-195784-58

Date Sampled: 04/20/2021 0512  
Date Received: 04/22/2021 0911  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/23/2021 0747	
Prep Method: 200.7/200.8			Date Prepared:	06/21/2021 1700	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195784-1  
Sdg Number: Newburgh ECSD NFA North

**Client Sample ID:** O/S 225 BS  
**Lab Sample ID:** 420-195784-59

Date Sampled: 04/20/2021 0513  
Date Received: 04/22/2021 0911  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/23/2021 0749	
Prep Method: 200.7/200.8			Date Prepared:	06/21/2021 1700	
Pb	2.40	ug/L	1.00	1.00	1.0



Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195784-1  
Sdg Number: Newburgh ECSD NFA North

**Client Sample ID:** 225 CS #1  
**Lab Sample ID:** 420-195784-60

Date Sampled: 04/20/2021 0514  
Date Received: 04/22/2021 0911  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/23/2021 0802	
Prep Method: 200.7/200.8			Date Prepared:	06/21/2021 1700	
Pb	1.62	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195784-1  
Sdg Number: Newburgh ECSD NFA North

**Client Sample ID:** 225 CS #2A  
**Lab Sample ID:** 420-195784-61

Date Sampled: 04/20/2021 0514  
Date Received: 04/22/2021 0911  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/23/2021 0804	
Prep Method: 200.7/200.8			Date Prepared:	06/21/2021 1700	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195784-1  
Sdg Number: Newburgh ECSD NFA North

**Client Sample ID:** 225 CS #3  
**Lab Sample ID:** 420-195784-62

Date Sampled: 04/20/2021 0515  
Date Received: 04/22/2021 0911  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 06/23/2021 0806		
Prep Method: 200.7/200.8			Date Prepared: 06/21/2021 1700		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195784-1  
Sdg Number: Newburgh ECSD NFA North

**Client Sample ID:** 225 CS #2  
**Lab Sample ID:** 420-195784-63

Date Sampled: 04/20/2021 0516  
Date Received: 04/22/2021 0911  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/23/2021 0808	
Prep Method: 200.7/200.8			Date Prepared:	06/21/2021 1700	
Pb	1.03	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195784-1  
Sdg Number: Newburgh ECSD NFA North

**Client Sample ID:** O/S 310 BF  
**Lab Sample ID:** 420-195784-64

Date Sampled: 04/20/2021 0519  
Date Received: 04/22/2021 0911  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/23/2021 0811	
Prep Method: 200.7/200.8			Date Prepared:	06/21/2021 1700	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195784-1  
Sdg Number: Newburgh ECSD NFA North

**Client Sample ID:** O/S 310 BS  
**Lab Sample ID:** 420-195784-65

Date Sampled: 04/20/2021 0520  
Date Received: 04/22/2021 0911  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/23/2021 0813	
Prep Method: 200.7/200.8			Date Prepared:	06/21/2021 1700	
Pb	6.62	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195784-1  
Sdg Number: Newburgh ECSD NFA North

**Client Sample ID:** Nurse BS  
**Lab Sample ID:** 420-195784-66

Date Sampled: 04/20/2021 0521  
Date Received: 04/22/2021 0911  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/23/2021 0815	
Prep Method: 200.7/200.8			Date Prepared:	06/21/2021 1700	
Pb	3.73	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195784-1  
Sdg Number: Newburgh ECSD NFA North

**Client Sample ID:** Nurse HS  
**Lab Sample ID:** 420-195784-67

Date Sampled: 04/20/2021 0522  
Date Received: 04/22/2021 0911  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/23/2021 0817	
Prep Method: 200.7/200.8			Date Prepared:	06/21/2021 1700	
Pb	7.08	ug/L	1.00	1.00	1.0



Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195784-1  
Sdg Number: Newburgh ECSD NFA North

**Client Sample ID:** O/S Health BS  
**Lab Sample ID:** 420-195784-68

Date Sampled: 04/20/2021 0524  
Date Received: 04/22/2021 0911  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 06/23/2021 0824		
Prep Method: 200.7/200.8			Date Prepared: 06/21/2021 1700		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195784-1  
Sdg Number: Newburgh ECSD NFA North

**Client Sample ID:** O/S Main Office BS  
**Lab Sample ID:** 420-195784-69

Date Sampled: 04/20/2021 0526  
Date Received: 04/22/2021 0911  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 06/23/2021 0826		
Prep Method: 200.7/200.8			Date Prepared: 06/21/2021 1700		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195784-1  
Sdg Number: Newburgh ECSD NFA North

**Client Sample ID:** Main Office BS  
**Lab Sample ID:** 420-195784-70

Date Sampled: 04/20/2021 0527  
Date Received: 04/22/2021 0911  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/23/2021 0830	
Prep Method: 200.7/200.8			Date Prepared:	06/21/2021 1700	
Pb	6.94	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195784-1  
Sdg Number: Newburgh ECSD NFA North

**Client Sample ID:** O/S 303 BF  
**Lab Sample ID:** 420-195784-71

Date Sampled: 04/20/2021 0529  
Date Received: 04/22/2021 0911  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 06/23/2021 0832		
Prep Method: 200.7/200.8			Date Prepared: 06/21/2021 1700		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195784-1  
Sdg Number: Newburgh ECSD NFA North

**Client Sample ID:** O/S 303 BS #1  
**Lab Sample ID:** 420-195784-72

Date Sampled: 04/20/2021 0530  
Date Received: 04/22/2021 0911  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/23/2021 0835	
Prep Method: 200.7/200.8			Date Prepared:	06/21/2021 1700	
Pb	1.74	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195784-1  
Sdg Number: Newburgh ECSD NFA North

**Client Sample ID:** O/S 303 BS #2  
**Lab Sample ID:** 420-195784-73

Date Sampled: 04/20/2021 0530  
Date Received: 04/22/2021 0911  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/23/2021 0837	
Prep Method: 200.7/200.8			Date Prepared:	06/21/2021 1700	
Pb	56.1 g	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195784-1  
Sdg Number: Newburgh ECSD NFA North

**Client Sample ID:** O/S 402 BF  
**Lab Sample ID:** 420-195784-74

Date Sampled: 04/20/2021 0532  
Date Received: 04/22/2021 0911  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 06/23/2021 0839		
Prep Method: 200.7/200.8			Date Prepared: 06/21/2021 1700		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195784-1  
Sdg Number: Newburgh ECSD NFA North

**Client Sample ID:** O/S 405 BS #1  
**Lab Sample ID:** 420-195784-75

Date Sampled: 04/20/2021 0532  
Date Received: 04/22/2021 0911  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/23/2021 0841	
Prep Method: 200.7/200.8			Date Prepared:	06/21/2021 1700	
Pb	4.55	ug/L	1.00	1.00	1.0



Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195784-1  
Sdg Number: Newburgh ECSD NFA North

**Client Sample ID:** O/S 405 BS #2  
**Lab Sample ID:** 420-195784-76

Date Sampled: 04/20/2021 0533  
Date Received: 04/22/2021 0911  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/23/2021 0843	
Prep Method: 200.7/200.8			Date Prepared:	06/21/2021 1700	
Pb	6.41	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195784-1  
Sdg Number: Newburgh ECSD NFA North

**Client Sample ID:** O/S 411 BS #1  
**Lab Sample ID:** 420-195784-77

Date Sampled: 04/20/2021 0534  
Date Received: 04/22/2021 0911  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/23/2021 0850	
Prep Method: 200.7/200.8			Date Prepared:	06/21/2021 1700	
Pb	3.14	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195784-1  
Sdg Number: Newburgh ECSD NFA North

**Client Sample ID:** O/S 411 BS #2  
**Lab Sample ID:** 420-195784-78

Date Sampled: 04/20/2021 0534  
Date Received: 04/22/2021 0911  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/23/2021 0852	
Prep Method: 200.7/200.8			Date Prepared:	06/21/2021 1700	
Pb	2.19	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195784-1  
Sdg Number: Newburgh ECSD NFA North

**Client Sample ID:** O/S 411 BF  
**Lab Sample ID:** 420-195784-79

Date Sampled: 04/20/2021 0535  
Date Received: 04/22/2021 0911  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 06/23/2021 0854		
Prep Method: 200.7/200.8			Date Prepared: 06/21/2021 1700		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195784-1  
Sdg Number: Newburgh ECSD NFA North

**Client Sample ID:** Kitchen Ice  
**Lab Sample ID:** 420-195784-80

Date Sampled: 04/20/2021 0418  
Date Received: 04/22/2021 0911  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/23/2021 0903	
Prep Method: 200.7/200.8			Date Prepared:	06/21/2021 1700	
Pb	1.00 U	ug/L	1.00	1.00	1.0

## DATA REPORTING QUALIFIERS

Client: Orange-Ulster BOCES

Job Number:  
Sdg Number: Newburgh ECSD NFA North

<b>Lab Section</b>	<b>Qualifier</b>	<b>Description</b>
Metals		
	g	Result fails applicable NYS drinking water standards
	U	The analyte was analyzed for but not detected at or above the lowest stated limit.

## Certification Information

Client: Orange-Ulster BOCES

Job Number:

Sdg Number: Newburgh ECSD NFA North

---

### **The following analytes are Not Part of the ELAP scope of accreditation:**

Sulfur, Tungsten, Bicarbonate Alkalinity, 7 Day BOD 5210C, 28 Day BOD, Soluble BOD, Carbon Dioxide Carbonate Alkalinity, CBOD Soluble, Chlorine, Cyanide (WAD), Ferrous Iron, Ferric Iron, Total Nitrogen, Total Organic Nitrogen, Dissolved Oxygen, pH, Solids (Fixed), Solids (Percent), Solids (Percent Moisture), Solids (Percent Volatile), Solids (Volatile Suspended), Temperature, TKN (Soluble), COD (Soluble), Total Inorganic Carbon, 2-Aminopyridine, 3-Picoline, 1-Methyl-2-pyrrilidinone, Aziridine, Dimethyl sulfoxide, 1-Chlorohexane, 1,2,4,5-Tetramethylbenzene, 4-Ethyl toluene, p-Diethylbenzene, Iron Bacteria, Salmonella, Sulfur Reducing Bacteria, & UOD (Ultimate Oxygen Demand).

### **The following analytes are Not Part of ELAP Potable Water scope of accreditation:**

Ammonia (SM 4500NH3G), Biochemical Oxygen Demand (SM 5210B), Chemical Oxygen Demand (EPA 410.4), Dissolved Oxygen (SM 4500 O C), TKN (351.2), Phosphorus (365.3), Nitrate-Nitrite (353.2), Setttable Solids (SM 2540F), Total Suspended Solids (SM 2540 C), m-Xylene & p-Xylene (502.2, 524), o-Xylene (502.2, 524), Sulfide (SM4500SD), Acenaphthene (525.2), Acenaphthylene (525.2), Fluoranthene (525.2), Fluorene (525.2), Phenanthrene (525.2), Anthracene (525.2), Pyrene (525.2), Benzo[a]anthracene (525.2), Benzo[b]fluoranthene (525.2), Benzo[g,h,i]perylene (525.2), Benzo[k]fluoranthene (525.2), Indeno[1,2,3-cd]pyrene (525.2), & Dibenz(a,h)anthracene (525.2). Pyridine

### **The following analytes are Not Part of ELAP Solid and Hazardous Waste scope of accreditation:**

Ammonia (SM 4500NH3G), TKN (351.2), Phosphorus (365.3), 1,2-Dichloro-1,1,2-trifluoroethane (8260), & Chlorodifluoromethane (8260).

### **The following analytes are Not Part of ELAP Non Potable Water scope of accreditation:**

Dissolved Organic Carbon (5310C), Mecoprop (8151A), MCPA (8151A).

## Definitions and Glossary

Client: Orange-Ulster BOCES

Job Number:

Sdg Number: Newburgh ECSD NFA North

---

<u>Abbreviation</u>	<u>These commonly used abbreviations may or may not be present in this report.</u>
%R	Percent Recovery
DL, RA, RE	Indicates a Dilution, Reanalysis or Reextraction.
EPA	United States Environmental Protection Agency
MDL	Method Detection Limit - an estimate of the minimum amount of a substance that an analytical process can reliably detect. A MDL is analyte- and matrix-specific and may be laboratory-dependent.
ND	Not detected at the reporting limit (or MDL if shown).
QC	Quality Control
RL	Reporting Limit - the minimum levels, concentrations, or quantities of a target variable (e.g., target analyte) that can be reported with a specified degree of confidence.
RPD	Relative Percent Difference - a measure of the relative difference between two points.



**EnviroTest Laboratories, LLC**

315 Fullerton Avenue  
Newburgh, NY 12550  
Phone (845) 562-0890 Fax (845) 562-0841

**Chain of Custody Record**



<b>Client Information</b>		Sampler: J DeGraw	Lab PM:	Deliverable Type: Level I, Level II, NYS ASP Cat B EDD (Specify):	JOB #:  <b>195784</b> <i>1 of 6</i>
Client Contact: Kevin Flynn		Phone: 845-781-4887	E-Mail: joseph.russo@ouboces.org Halina.redner@ouboces.org Maureen.doherty@ouboces.org		

Company: Orange-Ulster BOCES		<b>Analysis Requested</b>			Page: Page 1 of 1
Address: 53 Gibson Road		Due Date Requested: Standard Turn-Around	<p><b>420-195784-B-1</b> North Cafe BF</p> <p>Date Sampled: 4/20/2021      420-1673747</p>		
City: Goshen		TAT Requested (days):			
State, Zip: NY, 10924		PO #:			
Phone: 845-781-4887		PWS #:			
Email: joseph.russo@ouboces.org      Halina.redner@ouboces.org Maureen.doherty@ouboces.org		Project #:	Project Name: Newburgh ECSD		
Site: NFA North		Additional Contacts:			Preservation Codes: A - HCL                      L - EDA                      M B - NaOH                      - Sodium Sulfite C - Zn Acetate                      N - None D - Nitric Acid                      O - MCAA E - H2SO4                      P - Other (specify) F - MeOH G - NH4CL H - Ascorbic Acid I - Ice J - DI Water K - Sodium Thiosulfate  Other: <b>D-Nitric Acid</b> Upon Receipt Preservation verified: Y / N

Sample Date	Sample Time	Sample Identification	Client ID (Lab ID)	Sample Type (C=Comp, G=grab)	Matrix (DW=drinking water, W=water, S=solid, O=waste/oil)	Field Filtered (Y/N)	MS/MSD (Y/N)	Chlorine Present (Y/N)	Lead	Total Number of Containers	Special Instructions/Note:
4/20/21	407	NORTH CAFÉ BF		G	DW				1	1	
4/20/21	408	KITCHEN HS		G	DW				1	1	
4/20/21	410	KITCHEN KS #1		G	DW				1	1	
4/20/21	411	KITCHEN KS #2		G	DW				1	1	
4/20/21	412	KITCHEN KS #3		G	DW				1	1	
4/20/21	412	KITCHEN KS #4		G	DW				1	1	
4/20/21	412	KITCHEN KS #5		G	DW				1	1	
4/20/21	413	KITCHEN KS #6		G	DW				1	1	
4/20/21	413	KITCHEN KS #7		G	DW				1	1	
4/20/21	415	KITCHEN KF		G	DW				1	1	
4/20/21	420	SOUTH CAFÉ BF		G	DW				1	1	
4/20/21	421	SOUTH CAFÉ BOYS BS #1		G	DW				1	1	
4/20/21	421	SOUTH CAFÉ BOYS BS #2		G	DW				1	1	
4/20/21	422	SOUTH CAFÉ GIRLS BS #1		G	DW				1	1	
4/20/21	422	SOUTH CAFÉ GIRLS BS #2		G	DW				1	1	

Container Code: P=Plastic, A=Amber, V=Vial, G=Glass, B=Bacteria, C=Cube, O=Other, T=Terracore, D=BOD Bottle

Preservation Added Upon Receipt: \_\_\_\_\_ Manufacturer/Lot #: \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_ Sample # (s): \_\_\_\_\_ Container Type: \_\_\_\_\_

Relinquished by: <i>[Signature]</i>	Date/Time: 4/22/21 0911	Company: OUBOCES	Received by: <i>[Signature]</i>	Date/Time: 4/20/21 911	Company: ETC
Relinquished by:	Date/Time:	Company:	Received by:	Date/Time:	Company:
Relinquished by:	Date/Time:	Company:	Received by:	Date/Time:	Company:

ICE Present:  Custody Seal No.: \_\_\_\_\_ Custody Seals Intact:  Cooler Temperature(s) °C/IR GUN #: 15.91C

**EnviroTest Laboratories, LLC**

315 Fullerton Avenue  
Newburgh, NY 12550  
Phone (845) 562-0890 Fax (845) 562-0841

**Chain of Custody Record**



<b>Client Information</b> Client Contact: Kevin Flynn	Sampler: J DeGraw Phone: 845-781-4887	Lab PM:  E-Mail: joseph.russo@ouboces.org Halina.redner@ouboces.org Maureen.doherty@ouboces.org	Deliverable Type: Level I, Level II, NYS ASP Cat B EDD (Specify):	JOB #:  195784 2 of 2
---	--	--	--	--------------------------------

Company: Orange-Ulster BOCES	Address: 53 Gibson Road City: Goshen State, Zip: NY, 10924 Phone: 845-781-4887 Email: joseph.russo@ouboces.org Halina.redner@ouboces.org Maureen.doherty@ouboces.org	Due Date Requested: Standard Turn-Around TAT Requested (days):  PO #:  PWS #:  Project #:  Additional Contacts:	<b>Analysis Requested</b>	Page: Page 1 of 1
---------------------------------	---	---	---------------------------	----------------------

Sample Date	Sample Time	Sample Identification	Client ID (Lab ID)	Sample Type (C=Comp, G=grab)	Matrix (DW=drinking water, W=water, S=solid, O=waste/oil)	Field Filtered Sample (Yes or No)	Perform MS/MSD (Yes or No)	Chlorine Present (Yes or No)	Lead	Total Number of Containers	Other: D-Nitric Acid Upon Receipt Preservation verified: Y / N
											Special Instructions/Note:
4/20/21	424	LOCKER ROOM BOYS BS		G	DW				1	1	
4/20/21	425	LOCKER ROOM BOYS BS #1		G	DW				1	1	
4/20/21	425	LOCKER ROOM BOYS BS #2		G	DW				1	1	
4/20/21	428	LOCKER ROOM GIRLS BS		G	DW				1	1	
4/20/21	429	LOCKER ROOM GIRLS BS #1		G	DW				1	1	
4/20/21	429	LOCKER ROOM GIRLS BS #2		G	DW				1	1	
4/20/21	430	COACHES BS		G	DW				1	1	
4/20/21	430	LOCKER ROOM BF		G	DW				1	1	
4/20/21	433	GYM BF		G	DW				1	1	
4/20/21	435	1ST FLOOR GIRLS BS #1		G	DW				1	1	
4/20/21	436	1ST FLOOR GIRLS BS #2		G	DW				1	1	
4/20/21	436	1ST FLOOR GIRLS BS #3		G	DW				1	1	
4/20/21	437	1ST FLOOR BOYS BS #1		G	DW				1	1	
4/20/21	437	1ST FLOOR BOYS BS #2		G	DW				1	1	
4/20/21	439	1ST FLOOR STAFF BS #1		G	DW				1	1	

Container Code: P=Plastic, A=Amber, V=Vial, G=Glass, B=Bacteria, C=Cube, O=Other, T=Terracore, D=BOD Bottle											
Preservation Added Upon Receipt: _____ Manufacturer/lot #: _____ Date: _____ Time: _____ Sample # (s): _____ Container Type											
Relinquished by: <i>[Signature]</i>	Date/Time: 4/22/21 0911	Company: OUBOCES	Received by: <i>[Signature]</i>	Date/Time: 4/20/21 911	Company: ETC						
Relinquished by:	Date/Time:	Company:	Received by:	Date/Time:	Company:						
Relinquished by:	Date/Time:	Company:	Received by:	Date/Time:	Company:						
ICE Present: <i>no</i> Custody Seal No.: _____ Custody Seals Intact: <input checked="" type="checkbox"/> Cooler Temperature(s) °C/IR GUN #: <i>15.9.C</i>											

**EnviroTest Laboratories, LLC**

315 Fullerton Avenue  
Newburgh, NY 12550  
Phone (845) 562-0890 Fax (845) 562-0841

**Chain of Custody Record**



<b>Client Information</b>		Sampler: J DeGraw	Lab PM:	Deliverable Type: Level I, Level II, NYS ASP Cat B EDD (Specify):	JOB #:  195784 3 of 6
Client Contact: Kevin Flynn		Phone: 845-781-4887	E-Mail: joseph.russo@ouboces.org Halina.redner@ouboces.org Maureen.doherty@ouboces.org		

Company: Orange-Ulster BOCES		<b>Analysis Requested</b>			Page: Page 1 of 1
Address: 53 Gibson Road City: Goshen State, Zip: NY, 10924		Due Date Requested: Standard Turn-Around TAT Requested (days):		Preservation Codes:  A - HCL B - NaOH C - Zn Acetate D - Nitric Acid E - H2SO4 F - MeOH G - NH4CL H - Ascorbic Acid I - Ice J - DI Water K - Sodium Thiosulfate  L - EDA - Sodium Sulfite N - None O - MCAA P - Other (specify)	Other: <b>D-Nitric Acid</b> <i>Upon Receipt Preservation verified: Y / N</i>
Phone: 845-781-4887		PO #:			
Email: joseph.russo@ouboces.org Halina.redner@ouboces.org Maureen.doherty@ouboces.org		PWS #:			
Project Name: Newburgh ECSD Site: NFA North		Project #:  Additional Contacts:			

Sample Date	Sample Time	Sample Identification	Client ID (Lab ID)	Sample Type (C=comp, G=grab)	Matrix (DW=drinking water, W=water, S=solid, O=waste/oil)	Field Filtered Sample (Yes or No)	Perform MS/MSD (Yes or No)	Chlorine Present (Yes or No)	Lead	Total Number of Containers	Special Instructions/Note:
4/20/21	440	O/S 113 BF		G	DW				1	1	
4/20/21	442	103 CS		G	DW				1	1	
4/20/21	443	WOOD SHOP SS		G	DW				1	1	
4/20/21	444	125 BS		G	DW				1	1	
4/20/21	445	100 BS		G	DW				1	1	
4/20/21	446	100 CS #1		G	DW				1	1	
4/20/21	446	100 CS #2		G	DW				1	1	
4/20/21	448	O/S P TECH BS #1		G	DW				1	1	
4/20/21	448	O/S P TECH BS #2		G	DW				1	1	
4/20/21	456	202 SS #1		G	DW				1	1	
4/20/21	456	202 SS #2		G	DW				1	1	
4/20/21	457	NORTH GIRLS BS #1		G	DW				1	1	
4/20/21	458	NORTH GIRL BS #2		G	DW				1	1	
4/20/21	458	NORTH GIRLS BS #3		G	DW				1	1	
4/20/21	459	210 B HS #1		G	DW				1	1	

Container Code: P=Plastic, A=Amber, V=Vial, G=Glass, B=Bacteria, C=Cube, O=Other, T=Terracore, D=BOD Bottle

Preservation Added Upon Receipt:	Manufacturer/lot #:	Date:	Time:	Sample # (s):	Container Type
Relinquished by: <i>[Signature]</i>	Date/Time: 4/22/21 0911	Company: OUBOCES	Received by: <i>[Signature]</i>	Date/Time: 4/22/21 911	Company: ETC
Relinquished by:	Date/Time:	Company:	Received by:	Date/Time:	Company:
Relinquished by:	Date/Time:	Company:	Received by:	Date/Time:	Company:

ICE Present: **NO** Custody Seal No.: Custody Seals Intact:  Cooler Temperature(s) °C/IR GUN #: **15.9°C**

**EnviroTest Laboratories, LLC**

315 Fullerton Avenue  
 Newburgh, NY 12550  
 Phone (845) 562-0890 Fax (845) 562-0841

**Chain of Custody Record**



<b>Client Information</b>	Sampler: J DeGraw	Lab PM:	Deliverable Type: Level I, Level II, NYS ASP Cat B EDD (Specify):	JOB #:  145784 4 of 6
Client Contact: Kevin Flynn	Phone: 845-781-4887	E-Mail: joseph.russo@oubooces.org Halina.redner@oubooces.org Maureen.doherty@oubooces.org		

Company: Orange-Ulster BOCES	Due Date Requested: Standard Turn-Around	<b>Analysis Requested</b>			Page: Page 1 of 1		
Address: 53 Gibson Road	TAT Requested (days):	Field Filtered Sample (Yes or No)	Perform MS/MSD (Yes or No)	Chlorine Present (Yes or No)	Lead	Total Number of Containers	Preservation Codes: A - HCL B - NaOH C - Zn Acetate D - Nitric Acid E - H2SO4 F - MeOH G - NH4CL H - Ascorbic Acid I - Ice J - DI Water K - Sodium Thiosulfate L - EDA M - Sodium Sulfite N - None O - MCAA P - Other (specify)
City: Goshen	PO #:						
State, Zip: NY, 10924	PWS #:						
Phone: 845-781-4887	Project #:						
Email: joseph.russo@oubooces.org Maureen.doherty@oubooces.org	Halina.redner@oubooces.org	Additional Contacts:				Other: D-Nitric Acid	
Project Name: Newburgh ECSD	Site: NFA North				Upon Receipt Preservation verified: Y / N		

Sample Date	Sample Time	Sample Identification	Client ID (Lab ID)	Sample Type (C=Comp, G=grab)	Matrix (DW=drinking water, W=water, S=solid, O=waste/oil)	Field Filtered Sample (Yes or No)	Perform MS/MSD (Yes or No)	Chlorine Present (Yes or No)	Lead	Total Number of Containers	Special Instructions/Note:
4/20/21	500	201 B HS #2		G	DW				1	1	
4/20/21	501	201 A HS #1		G	DW				1	1	
4/20/21	501	201 A HS #2		G	DW				1	1	
4/20/21	502	201 A BS		G	DW				1	1	
4/20/21	504	O/S 210 BS #1		G	DW				1	1	
4/20/21	504	O/S 210 BS #2		G	DW				1	1	
4/20/21	505	O/S 210 BF		G	DW				1	1	
4/20/21	506	O/S SECURITY BS #2		G	DW				1	1	
4/20/21	506	O/S SECURITY BS #1		G	DW				1	1	
4/20/21	508	212 CS		G	DW				1	1	
4/20/21	509	216 BS		G	DW				1	1	
4/20/21	510	LIBRARY OFFICE BS		G	DW				1	1	
4/20/21	512	O/S 219 BF		G	DW				1	1	
4/20/21	513	O/S 225 BS		G	DW				1	1	
4/20/21	514	225 CS #1		G	DW				1	1	

Container Code: P=Plastic, A=Amber, V=Vial, G=Glass, B=Bacteria, C=Cube, O=Other, T=Terracore, D=BOD Bottle		P		Container Type	
Preservation Added Upon Receipt:	Manufacturer/lot #:	Date:	Time:	Sample # (s):	
Relinquished by: <i>[Signature]</i>	Date/Time: 4/22/21 0911	Company: OUBOCES	Received by: <i>[Signature]</i>	Date/Time: 4/22/21 911	Company: ETL
Relinquished by:	Date/Time:	Company:	Received by:	Date/Time:	Company:
Relinquished by:	Date/Time:	Company:	Received by:	Date/Time:	Company:
ICE Present: <i>no</i>	Custody Seal No.:	Custody Seals Intact: $\Delta$	Cooler Temperature(s) °C/IR GUN #: 15.9 °C		

**EnviroTest Laboratories, LLC**

315 Fullerton Avenue  
 Newburgh, NY 12550  
 Phone (845) 562-0890 Fax (845) 562-0841

**Chain of Custody Record**



<b>Client Information</b>		Sampler: J DeGraw	Lab PM:	Deliverable Type: Level I, Level II, NYS ASP Cat B EDD (Specify):	JOB #: <b>195784</b> <b>S of G</b>
Client Contact: Kevin Flynn		Phone: 845-781-4887	E-Mail: joseph.russo@ouboces.org Halina.redner@ouboces.org Maureen.doherty@ouboces.org		

Company: Orange-Ulster BOCES		<b>Analysis Requested</b>			Page: Page 1 of 1										
Address: 53 Gibson Road		Due Date Requested: Standard Turn-Around	<table border="1"> <tr><td>Field Filtered Sample (Yes or No)</td><td></td></tr> <tr><td>Perform MS/MSD (Yes or No)</td><td></td></tr> <tr><td>Chlorine Present (Yes or No)</td><td></td></tr> <tr><td>Lead</td><td></td></tr> <tr><td>Total Number of Containers</td><td></td></tr> </table>			Field Filtered Sample (Yes or No)		Perform MS/MSD (Yes or No)		Chlorine Present (Yes or No)		Lead		Total Number of Containers	
Field Filtered Sample (Yes or No)															
Perform MS/MSD (Yes or No)															
Chlorine Present (Yes or No)															
Lead															
Total Number of Containers															
City: Goshen		TAT Requested (days):													
State, Zip: NY, 10924		PO #:													
Phone: 845-781-4887		PWS #:													
Email: joseph.russo@ouboces.org Halina.redner@ouboces.org Maureen.doherty@ouboces.org		Project #:	Preservation Codes: A - HCL L- EDA M B - NaOH - Sodium Sulfite C - Zn Acetate N - None D - Nitric Acid O - MCAA E - H2SO4 P - Other (specify) F - MeOH G - NH4CL H - Ascorbic Acid I - Ice J - DI Water K - Sodium Thiosulfate  Other: <b>D-Nitric Acid</b> Upon Receipt Preservation verified: Y / N												
Project Name: Newburgh ECSD		Additional Contacts:													
Site: NFA North															

Sample Date	Sample Time	Sample Identification	Client ID (Lab ID)	Sample Type (C=comp, G=grab)	Matrix (DW=drinking water, W=water, S=solid, O=waste/oil)	Field Filtered Sample (Yes or No)	Perform MS/MSD (Yes or No)	Chlorine Present (Yes or No)	Lead	Total Number of Containers	Special Instructions/Note:
4/20/21	514	225 CS #2A		G	DW				1	1	
4/20/21	515	225 CS #3		G	DW				1	1	
4/20/21	516	225 CS #2		G	DW				1	1	
4/20/21	519	O/S 310 BF		G	DW				1	1	
4/20/21	520	O/S 310 BS		G	DW				1	1	
4/20/21	521	NURSE BS		G	DW				1	1	
4/20/21	522	NURSE HS		G	DW				1	1	
4/20/21	524	O/S HEALTH BS		G	DW				1	1	
4/20/21	526	O/S MAIN OFFICE BS		G	DW				1	1	
4/20/21	527	MAIN OFFICE BS		G	DW				1	1	
4/20/21	529	O/S 303 BF		G	DW				1	1	
4/20/21	530	O/S 303 BS #1		G	DW				1	1	
4/20/21	530	O/S 303 BS #1		G	DW				1	1	
4/20/21	532	O/S 402 BF		G	DW				1	1	
4/20/21	532	O/S 405 BS #1		G	DW				1	1	

Container Code: P=Plastic, A=Amber, V=Vial, G=Glass, B=Bacteria, C=Cube, O=Other, T=Terracore, D=BOD Bottle

Preservation Added Upon Receipt:	Manufacturer/lot #:	Date:	Time:	Sample # (s):	Container Type
Relinquished by: <i>[Signature]</i>	Date/Time: 4/22/21	0911			
Relinquished by:	Date/Time:	Company: OUBOCES	Received by: <i>[Signature]</i>	Date/Time: 4/22/21 911	Company: ETC
Relinquished by:	Date/Time:	Company:	Received by:	Date/Time:	Company:

ICE Present:  Custody Seal No.: Custody Seals Intact:  Cooler Temperature(s) °C/IR GUN #: 15.91C

**EnviroTest Laboratories, LLC**

315 Fullerton Avenue  
 Newburgh, NY 12550  
 Phone (845) 562-0890 Fax (845) 562-0841

**Chain of Custody Record**



<b>Client Information</b> Client Contact: Kevin Flynn	Sampler: J DeGraw	Lab PM:	Deliverable Type: Level I, Level II, NYS ASP Cat B EDD (Specify):	JOB #:  195784 6 EFG
	Phone: 845-781-4887	E-Mail: joseph.russo@ouboces.org Halina.redner@ouboces.org Maureen.doherty@ouboces.org		

Company: Orange-Ulster BOCES		<b>Analysis Requested</b>				Page: Page 1 of 1
Address: 53 Gibson Road	Due Date Requested: Standard Turn-Around	Field Filtered Sample (Yes or No)	Perform MS/MSD (Yes or No)	Chlorine Present (Yes or No)	Lead	Total Number of Containers
City: Goshen	TAT Requested (days):					
State, Zip: NY, 10924	PO #:					Preservation Codes:  A - HCL B - NaOH C - Zn Acetate D - Nitric Acid E - H2SO4 F - MeOH G - NH4CL H - Ascorbic Acid I - Ice J - DI Water K - Sodium Thiosulfate  L - EDA M - Sodium Sulfite N - None O - MCAA P - Other (specify)
Phone: 845-781-4887	PWS #:					
Email: joseph.russo@ouboces.org Maureen.doherty@ouboces.org	Project Name: Newburgh ECSD					Other: <b>D-Nitric Acid</b>
Project Name: Newburgh ECSD	Project #:					Upon Receipt Preservation verified: Y / N
Site: NFA North	Additional Contacts:					

Sample Date	Sample Time	Sample Identification	Client ID (Lab ID)	Sample Type (C=Comp, G=grab)	Matrix (DW=drinking water, W=water, S=solid, O=waste/oil)	Field Filtered Sample (Yes or No)	Perform MS/MSD (Yes or No)	Chlorine Present (Yes or No)	Lead	Total Number of Containers	Special Instructions/Note:
4/20/21	533	O/S 405 BS #2		G	DW				1	1	
4/20/21	534	O/S 411 BS #1		G	DW				1	1	
4/20/21	534	O/S 411 BS #2		G	DW				1	1	
4/20/21	535	O/S 411 BF		G	DW				1	1	
4/20/21	418	KITCHEN ICE		G	DW				1	1	
4/20/21				G	DW				1	1	
4/20/21				G	DW				1	1	
4/20/21				G	DW				1	1	
4/20/21				G	DW				1	1	
4/20/21				G	DW				1	1	
4/20/21				G	DW				1	1	
4/20/21				G	DW				1	1	
4/20/21				G	DW				1	1	
4/20/21				G	DW				1	1	
4/20/21				G	DW				1	1	

Container Code: P=Plastic, A=Amber, V=Vial, G=Glass, B=Bacteria, C=Cube, O=Other, T=Terracore, D=BOD Bottle		Manufacturer/I of #:		Date:	Time:	Sample # (s):	Container Type
Relinquished by: <i>[Signature]</i>	Date/Time: 4/22/21 0911	Company: OUBOCES	Received by: <i>[Signature]</i>	Date/Time: 4/22/21 911	Company: ETL		
Relinquished by:	Date/Time:	Company:	Received by:	Date/Time:	Company:		
Relinquished by:	Date/Time:	Company:	Received by:	Date/Time:	Company:		
ICE Present: <input checked="" type="checkbox"/>	Custody Seal No.:	Custody Seals Intact: <input checked="" type="checkbox"/>	Cooler Temperature(s) °C/IR GUN #:	15.9 °C			

## LOGIN SAMPLE RECEIPT CHECK LIST

Client: Orange-Ulster BOCES

Job Number: 420-195784-1  
SDG Number: Newburgh ECSD NFA North

**Login Number: 195784**

Question	T/F/NA	Comment
Samples were collected by ETL employee as per SOP-SAM-1	NA	
The cooler's custody seal, if present, is intact.	NA	
The cooler or samples do not appear to have been compromised or tampered with.	True	
Samples were received on ice.	False	
Cooler Temperature is recorded.	True	15.9 C
Cooler Temp. is within method specified range.(0-6 C PW, 0-8 C NPW, or BAC <10 C	False	
If false, was sample received on ice within 6 hours of collection.	False	
Based on above criteria cooler temperature is acceptable.	True	Method does not require cooling
COC is present.	True	
COC is filled out in ink and legible.	True	
COC is filled out with all pertinent information.	True	
There are no discrepancies between the sample IDs on the containers and the COC.	True	
Samples are received within Holding Time.	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
Appropriate sample containers are used.	True	
Sample bottles are completely filled.	True	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
VOA sample vials do not have headspace or bubble is <6mm (1/4") in diameter.	NA	
If necessary, staff have been informed of any short hold time or quick TAT needs	True	
Multiphasic samples are not present.	True	
Samples do not require splitting or compositing.	True	