

April 5, 2024

Maureen Doherty  
NB-Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Project Location: Vails Gate  
Project Number: Newburgh ECSD  
Laboratory Work Order Number: 24C2927

Enclosed are results of analyses for samples received by the laboratory on March 26, 2024. If you have any questions concerning this report, please feel free to contact me.

Sincerely,



Project Manager



NB-Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924  
ATTN: Maureen Doherty

REPORT DATE: 4/5/2024

PURCHASE ORDER NUMBER: A24-00300

PROJECT NUMBER: Newburgh ECSO

**ANALYTICAL SUMMARY**

WORK ORDER NUMBER: 24C2927

The results of analyses performed on the following samples submitted to Pace Analytical Services, LLC - Newburgh are found in this report.

PROJECT LOCATION: Vails Gate

FIELD SAMPLE #	LAB ID:	MATRIX	SAMPLE DESCRIPTION	TEST	SUB LAB
Kitchen Kettle	24C2927-01	Drinking Water		EPA 200.8 Rev 5.4	
Kitchen Prep Sink Island	24C2927-02	Drinking Water		EPA 200.8 Rev 5.4	
Cafe BF	24C2927-03	Drinking Water		EPA 200.8 Rev 5.4	
Cafe DF	24C2927-04	Drinking Water		EPA 200.8 Rev 5.4	
157 After M+ Rooms CS	24C2927-05	Drinking Water		EPA 200.8 Rev 5.4	
by 152 BF #1	24C2927-06	Drinking Water		EPA 200.8 Rev 5.4	
by 152 DF #1	24C2927-07	Drinking Water		EPA 200.8 Rev 5.4	
by 152 BF #2	24C2927-08	Drinking Water		EPA 200.8 Rev 5.4	
by 152 DF #2	24C2927-09	Drinking Water		EPA 200.8 Rev 5.4	
149 CS	24C2927-10	Drinking Water		EPA 200.8 Rev 5.4	
148 CS	24C2927-11	Drinking Water		EPA 200.8 Rev 5.4	
147 CS	24C2927-12	Drinking Water		EPA 200.8 Rev 5.4	
146 CS	24C2927-13	Drinking Water		EPA 200.8 Rev 5.4	
145 CS	24C2927-14	Drinking Water		EPA 200.8 Rev 5.4	
144 CS	24C2927-15	Drinking Water		EPA 200.8 Rev 5.4	
143 teachers lounge CS	24C2927-16	Drinking Water		EPA 200.8 Rev 5.4	
Across f/ Library BF	24C2927-17	Drinking Water		EPA 200.8 Rev 5.4	
Across f/ Library DF	24C2927-18	Drinking Water		EPA 200.8 Rev 5.4	
Rm 136 CS #1	24C2927-19	Drinking Water		EPA 200.8 Rev 5.4	
Big Faculty Rm CS #1	24C2927-20	Drinking Water		EPA 200.8 Rev 5.4	
Big Faculty Rm CS #2	24C2927-21	Drinking Water		EPA 200.8 Rev 5.4	
Rm 133 CS	24C2927-22	Drinking Water		EPA 200.8 Rev 5.4	
Across f/ 131 BF	24C2927-23	Drinking Water		EPA 200.8 Rev 5.4	
Across f/ 131 DF	24C2927-24	Drinking Water		EPA 200.8 Rev 5.4	
Main Office KS	24C2927-25	Drinking Water		EPA 200.8 Rev 5.4	
Rm 131 CS	24C2927-26	Drinking Water		EPA 200.8 Rev 5.4	
Across f/ 125 BF	24C2927-27	Drinking Water		EPA 200.8 Rev 5.4	
Across f/ 125 DF	24C2927-28	Drinking Water		EPA 200.8 Rev 5.4	
Across f/ 123 BF	24C2927-29	Drinking Water		EPA 200.8 Rev 5.4	
Across f/ 123 DF	24C2927-30	Drinking Water		EPA 200.8 Rev 5.4	
Across f/ 109 #1 BF	24C2927-31	Drinking Water		EPA 200.8 Rev 5.4	
Across f/ 109 #2 BF	24C2927-32	Drinking Water		EPA 200.8 Rev 5.4	
Across f/ 109 #2 DF	24C2927-33	Drinking Water		EPA 200.8 Rev 5.4	
Main Office CS #1	24C2927-34	Drinking Water		EPA 200.8 Rev 5.4	
Main Office BF	24C2927-35	Drinking Water		EPA 200.8 Rev 5.4	
Main Office DF	24C2927-36	Drinking Water		EPA 200.8 Rev 5.4	
Across f/ 109 #1 DF	24C2927-37	Drinking Water		EPA 200.8 Rev 5.4	

**CASE NARRATIVE SUMMARY**

All reported results are within defined laboratory quality control objectives unless listed below or otherwise qualified in this report.

The results of analyses reported only relate to samples submitted to the Pace Analytical Services, LLC - Newburgh for testing.  
I certify that the analyses listed above, unless specifically listed as subcontracted, if any, were performed under my direction according to the approved methodologies listed in this document, and that based upon my inquiry of those individuals immediately responsible for obtaining the information, the material contained in this report is, to the best of my knowledge and belief, accurate and complete.



Felicia Morgan-Nichols  
Project Manager



315 Fullerton Avenue \* Newburgh, NY 12550 \* TEL. (845) 562-0890

Project Location: Vails Gate

Sample Description:

Work Order: 24C2927

Date Received: 3/26/2024

Field Sample #: Kitchen Kettle

Sampled: 3/26/2024 08:12

Sample ID: 24C2927-01

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	1.5	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	4/2/24	4/3/24 20:44	JC



315 Fullerton Avenue \* Newburgh, NY 12550 \* TEL. (845) 562-0890

Project Location: Vails Gate

Sample Description:

Work Order: 24C2927

Date Received: 3/26/2024

Field Sample #: Kitchen Prep Sink Island

Sampled: 3/26/2024 08:12

Sample ID: 24C2927-02

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	4/2/24	4/3/24 20:55	JC



315 Fullerton Avenue \* Newburgh, NY 12550 \* TEL. (845) 562-0890

Project Location: Vails Gate

Sample Description:

Work Order: 24C2927

Date Received: 3/26/2024

Sampled: 3/26/2024 08:13

Field Sample #: Cafe BF

Sample ID: 24C2927-03

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	4/2/24	4/3/24 20:57	JC



315 Fullerton Avenue \* Newburgh, NY 12550 \* TEL. (845) 562-0890

Project Location: Vails Gate

Sample Description:

Work Order: 24C2927

Date Received: 3/26/2024

Field Sample #: Cafe DF

Sampled: 3/26/2024 08:13

Sample ID: 24C2927-04

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	4/2/24	4/3/24 20:59	JC



315 Fullerton Avenue \* Newburgh, NY 12550 \* TEL. (845) 562-0890

Project Location: Vails Gate

Sample Description:

Work Order: 24C2927

Date Received: 3/26/2024

Field Sample #: 157 After M+ Rooms CS

Sampled: 3/26/2024 08:16

Sample ID: 24C2927-05

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	4/2/24	4/3/24 21:01	JC





315 Fullerton Avenue \* Newburgh, NY 12550 \* TEL. (845) 562-0890

Project Location: Vails Gate

Sample Description:

Work Order: 24C2927

Date Received: 3/26/2024

Field Sample #: by 152 BF #1

Sampled: 3/26/2024 08:17

Sample ID: 24C2927-06

Sample Matrix: Drinking Water

**Metals Analyses (Total)**

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	4/2/24	4/3/24 21:03	JC



315 Fullerton Avenue \* Newburgh, NY 12550 \* TEL. (845) 562-0890

Project Location: Vails Gate

Sample Description:

Work Order: 24C2927

Date Received: 3/26/2024

Field Sample #: by 152 DF #1

Sampled: 3/26/2024 08:17

Sample ID: 24C2927-07

Sample Matrix: Drinking Water

**Metals Analyses (Total)**

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	4/2/24	4/3/24 21:05	JC



315 Fullerton Avenue \* Newburgh, NY 12550 \* TEL. (845) 562-0890

Project Location: Vails Gate

Sample Description:

Work Order: 24C2927

Date Received: 3/26/2024

Field Sample #: by 152 BF #2

Sampled: 3/26/2024 08:18

Sample ID: 24C2927-08

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	4/2/24	4/3/24 21:07	JC



315 Fullerton Avenue \* Newburgh, NY 12550 \* TEL. (845) 562-0890

Project Location: Vails Gate

Sample Description:

Work Order: 24C2927

Date Received: 3/26/2024

Field Sample #: by 152 DF #2

Sampled: 3/26/2024 08:19

Sample ID: 24C2927-09

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	4/2/24	4/3/24 21:09	JC



315 Fullerton Avenue \* Newburgh, NY 12550 \* TEL. (845) 562-0890

Project Location: Vails Gate

Sample Description:

Work Order: 24C2927

Date Received: 3/26/2024

Sampled: 3/26/2024 08:19

Field Sample #: 149 CS

Sample ID: 24C2927-10

Sample Matrix: Drinking Water

**Metals Analyses (Total)**

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	4/2/24	4/3/24 21:11	JC



315 Fullerton Avenue \* Newburgh, NY 12550 \* TEL. (845) 562-0890

Project Location: Vails Gate

Sample Description:

Work Order: 24C2927

Date Received: 3/26/2024

Field Sample #: 148 CS

Sampled: 3/26/2024 08:20

Sample ID: 24C2927-11

Sample Matrix: Drinking Water

**Metals Analyses (Total)**

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	4/2/24	4/3/24 21:17	JC



315 Fullerton Avenue \* Newburgh, NY 12550 \* TEL. (845) 562-0890

Project Location: Vails Gate

Sample Description:

Work Order: 24C2927

Date Received: 3/26/2024

Field Sample #: 147 CS

Sampled: 3/26/2024 08:20

Sample ID: 24C2927-12

Sample Matrix: Drinking Water

**Metals Analyses (Total)**

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	1.8	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	4/2/24	4/3/24 21:20	JC



315 Fullerton Avenue \* Newburgh, NY 12550 \* TEL. (845) 562-0890

Project Location: Vails Gate

Sample Description:

Work Order: 24C2927

Date Received: 3/26/2024

Sampled: 3/26/2024 08:22

Field Sample #: 146 CS

Sample ID: 24C2927-13

Sample Matrix: Drinking Water

**Metals Analyses (Total)**

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	1.9	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	4/2/24	4/3/24 21:22	JC





315 Fullerton Avenue \* Newburgh, NY 12550 \* TEL. (845) 562-0890

Project Location: Vails Gate

Sample Description:

Work Order: 24C2927

Date Received: 3/26/2024

Field Sample #: 145 CS

Sampled: 3/26/2024 08:23

Sample ID: 24C2927-14

Sample Matrix: Drinking Water

**Metals Analyses (Total)**

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	1.7	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	4/2/24	4/3/24 21:24	JC



Project Location: Vails Gate

Sample Description:

Work Order: 24C2927

Date Received: 3/26/2024

Sampled: 3/26/2024 08:23

Field Sample #: 144 CS

Sample ID: 24C2927-15

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	3.2	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	4/2/24	4/3/24 21:26	JC



315 Fullerton Avenue \* Newburgh, NY 12550 \* TEL. (845) 562-0890

Project Location: Vails Gate

Sample Description:

Work Order: 24C2927

Date Received: 3/26/2024

Field Sample #: 143 teachers lounge CS

Sampled: 3/26/2024 08:24

Sample ID: 24C2927-16

Sample Matrix: Drinking Water

**Metals Analyses (Total)**

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	4/2/24	4/3/24 21:28	JC



315 Fullerton Avenue \* Newburgh, NY 12550 \* TEL. (845) 562-0890

Project Location: Vails Gate

Sample Description:

Work Order: 24C2927

Date Received: 3/26/2024

Field Sample #: Across f/ Library BF

Sampled: 3/26/2024 08:25

Sample ID: 24C2927-17

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	4/2/24	4/3/24 21:30	JC



Project Location: Vails Gate

Sample Description:

Work Order: 24C2927

Date Received: 3/26/2024

Field Sample #: Across f/ Library DF

Sampled: 3/26/2024 08:25

Sample ID: 24C2927-18

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	4/2/24	4/3/24 21:32	JC



315 Fullerton Avenue \* Newburgh, NY 12550 \* TEL. (845) 562-0890

Project Location: Vails Gate

Sample Description:

Work Order: 24C2927

Date Received: 3/26/2024

Field Sample #: Rm 136 CS #1

Sampled: 3/26/2024 08:30

Sample ID: 24C2927-19

Sample Matrix: Drinking Water

**Metals Analyses (Total)**

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	4/2/24	4/3/24 21:34	JC



315 Fullerton Avenue \* Newburgh, NY 12550 \* TEL. (845) 562-0890

Project Location: Vails Gate

Sample Description:

Work Order: 24C2927

Date Received: 3/26/2024

Field Sample #: Big Faculty Rm CS #1

Sampled: 3/26/2024 08:30

Sample ID: 24C2927-20

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	2.3	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	4/2/24	4/3/24 21:40	JC



315 Fullerton Avenue \* Newburgh, NY 12550 \* TEL. (845) 562-0890

Project Location: Vails Gate

Sample Description:

Work Order: 24C2927

Date Received: 3/26/2024

Field Sample #: Big Faculty Rm CS #2

Sampled: 3/26/2024 08:30

Sample ID: 24C2927-21

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	RL	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
									Prepared	Analyzed	
Lead	1.1	1.0	15		µg/L	1		EPA 200.8 Rev 5.4	4/2/24	4/3/24 21:42	JC





315 Fullerton Avenue \* Newburgh, NY 12550 \* TEL. (845) 562-0890

Project Location: Vails Gate

Sample Description:

Work Order: 24C2927

Date Received: 3/26/2024

Field Sample #: Rm 133 CS

Sampled: 3/26/2024 08:32

Sample ID: 24C2927-22

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	1.7	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	4/2/24	4/3/24 21:49	JC



315 Fullerton Avenue \* Newburgh, NY 12550 \* TEL. (845) 562-0890

Project Location: Vails Gate

Sample Description:

Work Order: 24C2927

Date Received: 3/26/2024

Field Sample #: Across f/ 131 BF

Sampled: 3/26/2024 08:33

Sample ID: 24C2927-23

Sample Matrix: Drinking Water

**Metals Analyses (Total)**

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	4/2/24	4/3/24 21:51	JC



315 Fullerton Avenue \* Newburgh, NY 12550 \* TEL. (845) 562-0890

Project Location: Vails Gate

Sample Description:

Work Order: 24C2927

Date Received: 3/26/2024

Field Sample #: Across f/ 131 DF

Sampled: 3/26/2024 08:34

Sample ID: 24C2927-24

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	4/2/24	4/3/24 21:53	JC



315 Fullerton Avenue \* Newburgh, NY 12550 \* TEL. (845) 562-0890

Project Location: Vails Gate

Sample Description:

Work Order: 24C2927

Date Received: 3/26/2024

Field Sample #: Main Office KS

Sampled: 3/26/2024 08:43

Sample ID: 24C2927-25

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	1.4	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	4/2/24	4/3/24 21:55	JC



315 Fullerton Avenue \* Newburgh, NY 12550 \* TEL. (845) 562-0890

Project Location: Vails Gate

Sample Description:

Work Order: 24C2927

Date Received: 3/26/2024

Field Sample #: Rm 131 CS

Sampled: 3/26/2024 08:35

Sample ID: 24C2927-26

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	1.5	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	4/2/24	4/3/24 21:57	JC



315 Fullerton Avenue \* Newburgh, NY 12550 \* TEL. (845) 562-0890

Project Location: Vails Gate

Sample Description:

Work Order: 24C2927

Date Received: 3/26/2024

Field Sample #: Across f/ 125 BF

Sampled: 3/26/2024 08:26

Sample ID: 24C2927-27

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	4/2/24	4/3/24 22:03	JC



315 Fullerton Avenue \* Newburgh, NY 12550 \* TEL. (845) 562-0890

Project Location: Vails Gate

Sample Description:

Work Order: 24C2927

Date Received: 3/26/2024

Field Sample #: Across f/ 125 DF

Sampled: 3/26/2024 08:26

Sample ID: 24C2927-28

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	4/2/24	4/3/24 22:05	JC



315 Fullerton Avenue \* Newburgh, NY 12550 \* TEL. (845) 562-0890

Project Location: Vails Gate

Sample Description:

Work Order: 24C2927

Date Received: 3/26/2024

Field Sample #: Across f/ 123 BF

Sampled: 3/26/2024 08:37

Sample ID: 24C2927-29

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	4/2/24	4/3/24 22:07	JC





315 Fullerton Avenue \* Newburgh, NY 12550 \* TEL. (845) 562-0890

Project Location: Vails Gate

Sample Description:

Work Order: 24C2927

Date Received: 3/26/2024

Field Sample #: Across f/ 123 DF

Sampled: 3/26/2024 08:37

Sample ID: 24C2927-30

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	4/2/24	4/3/24 22:09	JC



315 Fullerton Avenue \* Newburgh, NY 12550 \* TEL. (845) 562-0890

Project Location: Vails Gate

Sample Description:

Work Order: 24C2927

Date Received: 3/26/2024

Field Sample #: Across f/ 109 #1 BF

Sampled: 3/26/2024 08:38

Sample ID: 24C2927-31

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	4/2/24	4/3/24 22:11	JC



315 Fullerton Avenue \* Newburgh, NY 12550 \* TEL. (845) 562-0890

Project Location: Vails Gate

Sample Description:

Work Order: 24C2927

Date Received: 3/26/2024

Field Sample #: Across f/ 109 #2 BF

Sampled: 3/26/2024 08:39

Sample ID: 24C2927-32

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	4/2/24	4/3/24 22:14	JC



315 Fullerton Avenue \* Newburgh, NY 12550 \* TEL. (845) 562-0890

Project Location: Vails Gate

Sample Description:

Work Order: 24C2927

Date Received: 3/26/2024

Field Sample #: Across f/ 109 #2 DF

Sampled: 3/26/2024 08:39

Sample ID: 24C2927-33

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	4/2/24	4/3/24 22:16	JC



315 Fullerton Avenue \* Newburgh, NY 12550 \* TEL. (845) 562-0890

Project Location: Vails Gate

Sample Description:

Work Order: 24C2927

Date Received: 3/26/2024

Field Sample #: Main Office CS #1

Sampled: 3/26/2024 08:42

Sample ID: 24C2927-34

Sample Matrix: Drinking Water

**Metals Analyses (Total)**

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	4/2/24	4/3/24 22:18	JC



315 Fullerton Avenue \* Newburgh, NY 12550 \* TEL. (845) 562-0890

Project Location: Vails Gate

Sample Description:

Work Order: 24C2927

Date Received: 3/26/2024

Field Sample #: Main Office BF

Sampled: 3/26/2024 08:41

Sample ID: 24C2927-35

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	4/2/24	4/3/24 22:20	JC



315 Fullerton Avenue \* Newburgh, NY 12550 \* TEL. (845) 562-0890

Project Location: Vails Gate

Sample Description:

Work Order: 24C2927

Date Received: 3/26/2024

Field Sample #: Main Office DF

Sampled: 3/26/2024 08:41

Sample ID: 24C2927-36

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	4/2/24	4/3/24 22:26	JC



Project Location: Vails Gate

Sample Description:

Work Order: 24C2927

Date Received: 3/26/2024

Field Sample #: Across f/ 109 #1 DF

Sampled: 3/26/2024 08:38

Sample ID: 24C2927-37

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	4/2/24	4/3/24 22:28	JC



**FLAG/QUALIFIER SUMMARY**

- \* QC result is outside of established limits.
  - † Wide recovery limits established for difficult compound.
  - ‡ Wide RPD limits established for difficult compound.
  - # Data exceeded client recommended or regulatory level
  - ND Not Detected
  - RL Reporting Limit is at the level of quantitation (LOQ)
  - DL Detection Limit is the lower limit of detection determined by the MDL study
  - MCL Maximum Contaminant Level
- Percent recoveries and relative percent differences (RPDs) are determined by the software using values in the calculation which have not been rounded.
- No results have been blank subtracted unless specified in the case narrative section.



CERTIFICATIONS

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 Rev 5.4 in Drinking Water	

Lead NB-CT,NB-NJ,NB-NY

Pace Analytical Services, LCC operates under the following certifications and accreditations:

Code	Description	Number	Expires
NB-CT	Connecticut Department of Public Health	PH-0823	09/30/2024
NB-NJ	New Jersey DEP	NY015 NELAP	06/30/2023
NB-NY	New York State Department of Health	10142 NELAP	04/1/2024

**Pace® Location Requested (City/State):**  
**CHAIN-OF-CUSTODY Analytical Request Document**

Chain-of-Custody is a LEGAL DOCUMENT - Complete all relevant fields

**Company Name:** Orange-Ulster BOCES  
**Street Address:** 53 Gibson Road  
 Goshen, NY 10924  
**Contact/Report to:** Maureen Doherty  
**Phone #:** 845-781-4887  
**E-Mail:** Maureen.Doherty@oudboces.org  
**CC E-Mail:** Halina.redner@oudboces.org

**Customer Project #:**  
**Project Name:** Newburgh ESSD  
**Site Collection Info/Facility ID (as applicable):**  
**Invoice E-mail:** halina.redner@oudboces.org  
**Purchase Order # (if applicable):** A24-00300  
**Quote #:**

**Time Zone Collected:** [ ] AK [ ] PT [ ] MT [ ] CT [ ] ET  
**County / State origin of sample(s):** Orange County / New York

**Data Deliverables:** [ ] Level II [ ] Level III [ ] Level IV  
 [ ] EQUS  
 [ ] Other: \_\_\_\_\_  
**Regulatory Program (DW, RCRA, etc.) as applicable:** DOH  
**Rush (Pre-approval required):** [ ] Same Day [ ] 1 Day [ ] 2 Day [ ] 3 Day Other \_\_\_\_\_  
**Date Results Requested:** \_\_\_\_\_  
**Field Filtered (if applicable):** [ ] Yes [ ] No  
**Analysis:** \_\_\_\_\_  
**Reportable:**  Yes [ ] No  
**DW PWSID # or WW Permit # as applicable:** \_\_\_\_\_

\*Matrix Codes (Insert in Matrix box below): Drinking Water (DW), Ground Water (GW), Wastewater (WW), Product (P), Soil/Solid (SS), Oil (O), Wipe (WP), Tissue (T), Biosolids (B), Vapor (V), Surface Water (SW), Sediment (SED), Sludge (SL), Cask (CK), Leachate (LL), Biosolid (BS), Other (OT)

Customer Sample ID	Matrix *	Comp / Grab	Composite Start Date	Time	Collected or Composite End Date	Time	# Cont.	Residual Chlorine Result	Units
1	Kitchen Kettle	DW	G	3/26	8/2				
2	Kitchen Prep Sink Island	DW	G	3/26	8/2				
3	Cafe BF	DW	G	3/26	8/3				
4	Cafe DF	DW	G	3/26	8/3				
5	157 After M+ Rooms CS	DW	G	3/26	8/6				
6	by 152 BF #1	DW	G	3/26	8/7				
7	by 152 DF #1	DW	G	3/26	8/7				
8	by 152 BF #2	DW	G	3/26	8/8				
9	by 152 DF #2	DW	G	3/26	8/9				
10	149 CS	DW	G	3/26	8/9				

**Additional Instructions from Pace®:**  
 Collected by: *Bryon Wicks*  
 Printed Name: \_\_\_\_\_  
 Signature: \_\_\_\_\_

Relinquished by/Company (Signature)	Date/Time	Received by/Company (Signature)	Date/Time
<i>[Signature]</i>	3/26/24 12:16	<i>[Signature]</i>	3/26/24 12:16
<i>[Signature]</i>	3/26/24 12:16	<i>[Signature]</i>	3/26/24 12:16



LAB USE ONLY - Aftix Workorder/Login Label Here  
 24C2927  
 Scan QR Code for instructions

Specify Container Size **	Identify Container Preservative Type***	Analysis Requested
3		
2		

Lead Testing	Proj Mgr	ActNum / Client ID	Table #	Profile / Template	Preserv / Bottle Ord. ID	Sample Comment



Thermometer ID	Correction Factor (°C)	Obs. Temp. (°C)	Corrected Temp. (°C)	On Ice
		12.16	12.16	<input checked="" type="checkbox"/>

**Pace® Location Requested (City/State):**  
**CHAIN-OF-CUSTODY Analytical Request Document**  
 Chain-of-Custody is a LEGAL DOCUMENT - Complete all relevant fields

Company Name: Orange-Ulster BOCES  
 Street Address: 53 Gibson Road, Goshen, NY 10924  
 Contact/Report to: Maureen Doherty  
 Phone #: 845-781-4887  
 E-Mail: Maureen.Doherty@ouboces.org  
 CC E-Mail: Halina.redner@ouboces.org

Customer Project #: \_\_\_\_\_  
 Project Name: Newburg ECSO  
 Site Collection Info/Facility ID (as applicable): \_\_\_\_\_  
 Invoice to: Halina Redner  
 Invoice E-mail: halina.redner@ouboces.org  
 Purchase Order # (if applicable): A24-00300  
 Quote #: \_\_\_\_\_

Time Zone Collected: [ ] AK [ ] PT [ ] MT [ ] CT [ ] ET  
 Country / State origin of sample(s): Orange County / New York  
 Reportable:  Yes [ ] No

Data Deliverables: [ ] Level II [ ] Level III [ ] Level IV  
 [ ] EQUIS  
 [ ] Other: \_\_\_\_\_  
 Regulatory Program (DW, RCRA, etc.) as applicable:  DW PWSID # or WW Permit # as applicable:  
 DOH  
 Rush (Pre-approval required): [ ] Same Day [ ] 1 Day [ ] 2 Day [ ] 3 Day Other: \_\_\_\_\_  
 Date Results Requested: \_\_\_\_\_  
 Field Filtered (if applicable): [ ] Yes  No  
 Analysis: \_\_\_\_\_

\*Matrix Codes (Insert in Matrix box below): Drinking Water (DW), Ground Water (GW), Product (P), Soil/Solid (SS), Oil (OL), Wipe (WP), Tissue (TS), Bioassay (B), Vapor (V), Surface Water (SW), Sediment (SED), Sludge (SL), Cask (CK), Leachate (LL), Biosolid (BS), Other (O)

Customer Sample ID	Matrix *	Comp / Grab	Composite Start Date	Time	Collected or Composite End Date	Time	# Cont.	Residual Chlorine Result	Units
11	148 CS	DW	G		3/26	8:20			
12	147 CS	DW	G		3/26	8:20			
13	146 CS	DW	G		3/26	8:22			
14	145 CS	DW	G		3/26	8:23			
15	144 CS	DW	G		3/26	8:23			
16	143 teachers lounge CS	DW	G		3/26	8:24			
17	Across f/ Library BF	DW	G		3/26	8:25			
18	Across f/ Library DF	DW	G		3/26	8:25			
19	Rm 135 CS #1	DW	G						
20	Rm 135 CS #2	DW	G						

Additional Instructions from Pace®: \_\_\_\_\_  
 Collected By: *Bryan Weiss*  
 Printed Name: \_\_\_\_\_  
 Signature: \_\_\_\_\_

Received By/Company (Signature)	Date/Time	Received By/Company (Signature)	Date/Time
<i>[Signature]</i>	3/26/24 12:16	<i>[Signature]</i>	3/26/24 12:16
<i>[Signature]</i>	3/26/24 16:00	<i>[Signature]</i>	3/26/24 16:00



LAB USE ONLY - Aftix Workflow Login Label Here  
 Scan QR Code for Instructions  
 24C2927

Specify Container Size **	Identity Container Preservative Type***	Analysis Requested
3		
2		

Lab Use Only	Sample Comment
ActNum / Client ID: Table #: Profile / Template: Prelog / Bottle Ord. ID:	Preservation non-conformance identified for sample.

# Coders	Thermometer ID:	Correction Factor (°C):	Obs. Temp. (°C):	Corrected Temp. (°C):	Tracking Number:

Company Name: Orange-Ulster BOCES  
 Street Address: 53 Gibson Road, Goshen, NY 10924  
 Contact/Report to: Maureen Doherty  
 Phone #: 845-781-4887  
 E-Mail: Maureen.Doherty@oubooces.org  
 Ce E-Mail: Hallina.Redner@oubooces.org

Customer Project #: \_\_\_\_\_  
 Project Name: Newburgh ESCD  
 Invoice to: Hallina Redner  
 Invoice E-mail: hallina.redner@oubooces.org  
 Purchase Order # (if applicable): A24-00300  
 Quote #: \_\_\_\_\_

Time Zone Collected: [ ] AK [ ] PT [ ] MT [ ] CT [ ] ET  
 Data Deliverables: [ ] Level II [ ] Level III [ ] Level IV  
 [ ] EQUIS  
 [ ] Other: \_\_\_\_\_

Regulatory Program (DW, RCRA, etc.) as applicable:  DW PWSID # or WW Permit # as applicable: \_\_\_\_\_  
 DOH  
 Rush (Pre-approval required): [ ] Same Day [ ] 1 Day [ ] 2 Day [ ] 3 Day Other: \_\_\_\_\_  
 Date Results Requested: \_\_\_\_\_  
 Field Filtered (if applicable): [ ] Yes [ ] No  
 Analysis: \_\_\_\_\_

Country/State origin of sample(s): Orange County / New York  
 Reportable:  Yes [ ] No  
 \*Mark Coles (Invert in Matrix box below): Drinking Water (DW), Ground Water (GW), Wastewater (WW), Product (P), Soil/Solid (SS), Oil (OL), Wipe (WP), Tissue (TS), Bioassay (B), Vapor (V), Surface Water (SW), Sediment (SED), Sludge (SL), Cank (CK), Leachate (LL), Biosolid (BS), Other (OT)

Customer Sample ID	Matrix *	Comp / Grab	Composite Start Date	Time	Collected or Composite End Date	Time	# Cont.	Result	Units	Needal Chlorine
Rm 136 CS # 1	DW	G	3/26	8:30						
Rm 136 CS # 2	DW	G	3/26	8:30						
Big Faculty Rm CS # 1	DW	G	3/26	8:30						
Big Faculty Rm CS # 2	DW	G	3/26	8:30						
Across-from Health office BF # 1	DW	G								
Across-from Health office DF # 1	DW	G								
Across-from Health office BF # 2	DW	G								
Across-from Health office DF # 2	DW	G								
Rm 133 CS	DW	G	3/26	8:32						
Across fl 131 BF	DW	G	3/26	8:33						

Additional Instructions from Pace\*: \_\_\_\_\_  
 Collected By: Dryan Welsch  
 Printed Name: \_\_\_\_\_  
 Signature: \_\_\_\_\_

Relinquished by/Company: (Signature) \_\_\_\_\_ Date/Time: 3/26/24 1:16  
 Relinquished by/Company: (Signature) \_\_\_\_\_ Date/Time: \_\_\_\_\_  
 Relinquished by/Company: (Signature) \_\_\_\_\_ Date/Time: \_\_\_\_\_  
 Relinquished by/Company: (Signature) \_\_\_\_\_ Date/Time: \_\_\_\_\_



LAB USE ONLY: Arfita Workorder/Login Label Here  
 Scan QR Code for Instructions  
24C2927

Specify Container Size **	Identify Container Preservative Type***	Analysis Requested
3		
2		

Lab Use Only	Sample Comment
Project Mgr: _____ Account / Client ID: _____ Table #: _____ Profile / Template: _____ Prelog / Bottle Ord. ID: _____	

# Coolers:	Thermometer ID:	Correction Factor (°C):	Obs. Temp. (°C):	Corrected Temp. (°C):	On Ice

Customer Remarks / Special Conditions / Possible Hazards: \_\_\_\_\_  
 Tracking Number: \_\_\_\_\_  
 Delivered by: [ ] In-Person [ ] Courier  
 [ ] FedEx [ ] UPS [ ] Other



Pace® Location Requested (City/State):  
 Chain-of-Custody is a LEGAL DOCUMENT - Complete all relevant fields

**CHAIN-OF-CUSTODY Analytical Request Document**

LAB USE ONLY - Affix Workorder/Logn Label Here

Company Name: Orange-Ulster BOCES  
 Street Address: 53 Gibson Road, Goshen, NY 10924  
 Contact/report to: Maureen Doherty  
 Phone #: 845-781-4887  
 E-Mail: Maureen.Doherty@oubooces.org  
 CC E-Mail: Halina.Redner@oubooces.org  
 Invoice to: Halina Redner  
 Invoice E-mail: halina.redner@oubooces.org  
 Purchase Order # (if applicable): A24-00300  
 Quote #:

Customer Project #: \_\_\_\_\_  
 Project Name: Newburg ESCD  
 Site Collection Info/Facility ID (as applicable):  
 Vails Gate  
 Country / State origin of sample(s): Orange County / New York  
 Reportable  Yes  No

Time Zone Collected:  AK  PR  MT  CT  ET  
 Regulatory Program (DW, RCRA, etc.) as applicable: DOH  
 Rush (Pre-approval required):  Same Day  1 Day  2 Day  3 Day Other \_\_\_\_\_  
 Date Results Requested: \_\_\_\_\_  
 Analysis:  Yes  No

\*Matrix Codes (insert in Matrix back-body): Drinking Water (DW), Ground Water (GW), Wastewater (WW), Product (P), Soil/Solid (SS), Oil (O), Vapor (V), Surface Water (SW), Sediment (SED), Sludge (S), Cask (C), Leachate (L), Biosolid (BS), Other (O)

Customer Sample ID	Matrix *	Comp / Grab	Composite Start Date	Time	Collected or Composite End Date	Time	# Cont.	Result	Residual Chlorine Units
24	Across fl/ 131 DF	DW	G		3/26	834			
25	Main Office KS	DW	G		3/26	843			
26	Rm 131 CS	DW	G		3/26	835			
27	Across fl/ 125 BF	DW	G		3/26	826			
28	Across fl/ 125 DF	DW	G		3/26	826			
29	Across fl/ 123 BF	DW	G		3/26	837			
30	Across fl/ 123 DF	DW	G		3/26	837			
31	Across fl/ 109 #1 BF	DW	G		3/26	836			
32	Across fl/ 109 #2 BF	DW	G		3/26	839			
33	Across fl/ 109 #2 DF	DW	G		3/26	839			

Collected By: *Bryon Wilts*  
 Printed Name: *Bryon Wilts*  
 Signature: *[Signature]*

Requisitioned by/Company: (Signature)	Date/Time	Received by/Company: (Signature)	Date/Time	Requisitioned by/Company: (Signature)	Date/Time	Received by/Company: (Signature)	Date/Time
<i>[Signature]</i>	3/26/24 1216	<i>[Signature]</i>	3/26/24 1216	<i>[Signature]</i>	3/26/24 1216	<i>[Signature]</i>	3/26/24 1216
<i>[Signature]</i>	3/26/24 1216	<i>[Signature]</i>	3/26/24 1216	<i>[Signature]</i>	3/26/24 1216	<i>[Signature]</i>	3/26/24 1216



24C2927  
 Scan QR Code for Instructions

Specify Container Size **	Identify Container Preservative Type***	Analysis Requested
3		
2		

Lead Testing	Thermometer ID	Correction Factor (°C)	Obs. Temp. (°C)	Corrected Temp. (°C)	Tracking Number

Lab Use Only	Sample Comment
Acetinum / client ID: Table #: Profile / Template: Prefig. / bottle Ord. ID:	Preservation non-conformance identified for sample.



Pace® Location Requested (City/State):  
 Pace® Newburgh, NY

**CHAIN-OF-CUSTODY Analytical Request Document**

Chain-of-Custody is a LEGAL DOCUMENT - Complete all relevant fields

Company Name: Orange-Ulster BOCES  
 Street Address: 53 Gibson Road, Goshen, NY 10924  
 Contact/Report To: Maureen Doherty  
 Phone #: 845-781-4887  
 E-Mail: Maureen.Doherty@oubooces.org  
 CC E-Mail: Halina.redner@oubooces.org

Customer Project #: \_\_\_\_\_  
 Project Name: Newburgh ECSS  
 Invoice to: Halina Redner  
 Invoice E-mail: halina.redner@oubooces.org  
 Purchase Order # (if applicable): A24-00300  
 Quote #: \_\_\_\_\_

Site Collection Info/Facility ID (as applicable):  
 Vails Gate  
 County / State origin of sample(s): Orange County / New York

Time Zone Collected: [ ] AK [ ] PT [ ] MT [ ] CT [ ] ET  
 Data Deliverables: [ ] Level II [ ] Level III [ ] Level IV  
 Regulatory Program (DW, RCRA, etc.) as applicable:  DW PWSID # or WW Permit # as applicable:  Yes [ ] No

Rush (Pre-approval required): [ ] Same Day [ ] 1 Day [ ] 2 Day [ ] 3 Day Other \_\_\_\_\_  
 Date Results Requested: \_\_\_\_\_  
 Field Filtered (if applicable): [ ] Yes  No  
 Analysis: \_\_\_\_\_

\* Matrix Codes (Insert in Matrix box below): Drinking Water (DW), Ground Water (GW), Wastewater (WW), Product (P), Soil/Solid (SS), Oil (O), Wipe (W), Tissue (TS), Biosessy (B), Vapor (V), Surface Water (SW), Sediment (SD), Sludge (SL), Cank (CK), Leachate (L), Biosolid (BS), Other (OT)

Customer Sample ID	Matrix *	Comp / Grab	Composite Start		Collected or Composite End		# Cont.	Residual Chlorine Result	Units
			Date	Time	Date	Time			
34 Main Office CS #1	DW	G	3/26	1216	3/26	842			X
35 Main Office BF	DW	G	3/26	841	3/26	841			X
36 Main Office DF	DW	G	3/26	841	3/26	843			X
37 Main Office KS	DW	G	3/26	843	3/26	843			X
	DW	G							X
	DW	G							X
	DW	G							X
	DW	G							X
	DW	G							X

Additional Instructions from Pace®: \_\_\_\_\_  
 Collected By: *Byron W. W154*  
 Printed Name: \_\_\_\_\_  
 Signature: \_\_\_\_\_

Relinquished by/Company: [Signature]	Date/Time:	Received by/Company: [Signature]	Date/Time:
<i>Maureen Doherty</i>	3/26/24	<i>Byron W. W154</i>	3/26/24
<i>Halina Redner</i>	3/26/24	<i>Byron W. W154</i>	3/26/24



LAB USE ONLY - Arlix Workorder/Lab Label Here  
 24C2927  
 Scan QR Code for instructions

Specify Container Size **	Identify Container Preservative Type***	Analysis Requested
3		
2		

Lab Use Only	
ActNum / Client ID:	
Table #:	
Profile / Template:	
Proj. Mgr.:	
Sample Comment:	

Lead Testing

Customer Remarks / Special Conditions / Possible Hazards: \_\_\_\_\_

# Coolers:	Thermometer ID:	Correction Factor (°C):	Obs. Temp (°C):	Corrected Temp (°C):	Tracking Number:
					Pace

Submitting a sample via this chain of custody constitutes a acknowledgment and acceptance of the Pace® Terms and Conditions found at <https://www.paceobcs.com/resource-library/resource/pace-terms-and-conditions/>

*did not receive sample labeled "Main Office KS(37)"*  
*did receive sample labeled "Across F/109 #1 DF"*

Sample Condition Upon Receipt Form (SCUR)

Project # 24C2927  
 Client: OWBOOS

Vaults Gate

Date and Initials of person:

Examining contents: \_\_\_\_\_

Label: \_\_\_\_\_

Deliver to location: Bloom/ylburg

pH: \_\_\_\_\_

Thermometer Used: —

Date: 3/26/24 Time: 12:16 Initials: JE

State of Origin: NY

Cooler #1 Temp. °C \_\_\_\_\_ (Visual) \_\_\_\_\_ (Correction Factor) \_\_\_\_\_ (Actual)  Samples on ice, cooling process has begun

Courier:  Fed Ex  UPS  USPS  Client  Commercial  Pace  Other \_\_\_\_\_

Shipping Method:  First Overnight  Priority Overnight  Standard Overnight  Ground  Other \_\_\_\_\_

Tracking # \_\_\_\_\_

Custody Seal on Cooler/Box Present:  Yes  No Seals intact:  Yes  No Ice: Wet Blue Melted None

Packing Material:  Bubble Wrap  Bubble Bags  None  Other \_\_\_\_\_

Samples were collected by Pace employee  Yes  No  N/A

Comments:		
Chain of Custody Present	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
Chain of Custody Filled Out	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
Relinquished Signature on COC	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
Sampler Name and Signature on COC	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
Samples Arrived within Hold Time	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
Rush TAT requested on COC	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> N/A	
Sufficient Volume	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
Correct Containers Used	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
Containers Intact	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
Sample Labels match COC (sample IDs & date/time of collection)	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
All containers needing acid/base preservation have been checked.	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	Preservation Information: Preservative: _____
All Containers needing preservation are found to be in compliance with EPA recommendation:	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	Lot #/Trace #: _____ Date: _____ Time: _____
Exceptions: Vials, Microbiology, O&G, Metals		Initials: _____
Headspace in VOA Vials? (>6mm):	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	
Trip Blank Present:	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	

Additional Login Comments:  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

Client notification/ Resolution  
 Person Contacted: \_\_\_\_\_ Date/Time: \_\_\_\_\_  
 Comments/Resolution: \_\_\_\_\_